

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month October, 2022				Day : Friday				Date : 14.10.22			
Probable Maximum Demand : 13200 MW				Probable Maximum Generation : 12880 MW				Rule Curve = 107.20 ft.			
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 98.61 ft.		Today = 98.61 ft.					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	13.10.22 (Yesterday)		14.10.22 (Today)		13.10.22 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation	Machines shut down (MW)	
(A) Plants in operation:											
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	100	100	100	100		
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Under maint.
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	81	84	75	84		
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0		Contract Expired
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	278	268	270	270		
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225	Gas Shortage
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	407	402	400	400		
11	Siddhirganj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	213	205	200	205		STG Under maint.
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0	335	Under maint.
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55		
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	65	92	8	92		
16	Narshingsi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	19	19	19		
17	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	50	52	50	52		
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	14	14	14	14		
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	40	49	40	50		
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	105	90	105		
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	132	64	132		
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54		
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	245	296	250	300		
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	124	127	90	127		
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	210	51	150	150		
27	Bramhangsan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	97	50	50	100		
28	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	100	50	100	100		
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	35	55		
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55		
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	74	93	17	93		
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	108	162	90	162		
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	15	0	30	0		
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	0	0	0		
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	65	90	8	90		
36	Meghnaghat 100 MW(IEEL)	HFO (NENP)	12x8.9	100	100	33	81	15	81		
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0		
Dhaka Zone Total			6004	5847	2839	2999	2530	3203	435	1370	
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	156	155	154	155		Unit 1 under rehabilitation
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0		
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	8	25		
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	6	0	20	0		
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	44	44	25	44		
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	89	105	105	105		
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	228	229	225	225		
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	211	285	200	285		
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	90	90	32	90		
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	51	17	51		
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	7	22	22	22		
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	14	14	14	14		
*	Malancha, Ctp EP2 (United)	Gas	5x8.73+3x9.34			2	15	5	30		
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	12	0	12	96	Fuel oil shortage
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54		
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	105	105	105	105		
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	100	100	50	100		
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	56	66	66	66		
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107		
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0		
Chattogram Zone Total			2442	2382	1315	1479	1214	1490	276	330	
58	Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	39	50	38	50		
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	180	207	180	207		
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	270	280	300	300		
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	270	280	300	300		
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCCL)	1x284	284	284	0	0	0	0	284	Gas Shortage
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	10	10	10	10	45	Gas Shortage
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187	Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51		
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	125	43	43	43		
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	44	0	44		
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	82	81	80	81		
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	44	100	18	100		
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	13	22	22	22		
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11		
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	16	25	25	25		
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	16	52	8	52		
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	21	21	21	21		
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	39x1.4+40x1.515+15x1.058	200	200	102	109	100	100		
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	112	17	114		
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	9	9	9	104	Fuel Oil Shortage
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35		
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	36	115	35	115		
**	Import (Tripura)	India		160	160	146	162	143	166		
Cumilla Zone Total			3193	3169	1501	1827	1454	1864	754	0	
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	36	69	65	80	133	Gas Shortage
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	13	13	13	13		
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	99	109	90	109		
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	58	127	100	127	73	Fuel oil shortage
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0		
86	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	46	0	50	0		
87	Tangail 22 MW PP(PPLGL)	HFO (IPP)	4x6.7	22	22	12	12	12	12		
Mymensingh Zone Total			622	614	265	330	332	341	206	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	13.10.22 (Yesterday)		14.10.22 (Today)		13.10.22 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :				
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date	
88	Fenchugonj	CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30	40	GT-1 Under maint.		
89	Fenchugonj	CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	30	30	60	GT-4 Under maint.		
90	Fenchugonj	51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	5	0	0	0	51	Gas Shortage		
91	Kushiera	163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0	109	STG Under maint.		
92	Hobiganj	11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	5	0	5	6	Gas Shortage		
93	Shahjibazar	GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	62	61	60	61				
94	Shahjibazar	330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330	Under maint.		
95	Shahjibazar	66MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	10	81	10	81				
96	Sylhet	225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	140	135	135	135	96	ST Under maint.		
97	Sylhet	20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	0	0	20	Gas Shortage		
98	Sylhet	10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
99	Shahjahanulla	25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	0	0	0	25	Gas Shortage		
100	Bibiana-II	341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	270	280	280				
101	Bibiyan-II	400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	409	408	400	400				
102	Bibiyan South	383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400				
103	Shahjibazar	100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0	100	Under project work		
104	Sylhet	50MW PP (EPL)	Gas (NENP)	2x27	50	50	0	6	0	0	44	Gas Shortage		
105	Fenchugonj	44MW (Energyprima)	Gas (NENP)	12'3.3-5'2	50	50	5	0	0	0	50	Gas Shortage		
Sylhet Zone Total						2522	2477	1391	1436	1355	1432	305	680	
106	Bheramara	GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
107	Bheramara	410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	230	215	210	215	195	Gas Shortage		
108	Fairdipor	50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	44	0	44				
109	Gopalganj	100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	70	0	70				
110	Khulna	225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	120	217	120	120				
111	Noapara	100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	10	0	50				
112	Rupsha	105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	60	35	90				
113	Madhumati	100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	85	15	85				
114	Mongla Orion	100 MW Solar PP	Solar (IPP)		100	100	79	0	100	0				
115	Khulna	115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	66	16	66				
116	Noapara	40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	8	0	8	32	Fuel oil shortage		
	Rampal	1320 MW	Coal (BIFPCL)				0	0	0	0				
	Khulna	330 MW CCPP	Gas/HSD (BPDB)				0	0	0	0				
**	Bheramara	(HVCDC)	India	1000	1000	917	911	935	935					
Khulna Zone Total						2388	2384	1346	1686	1431	1683	227	0	
117	Barisal	110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	16	16	16	94	Line Overload		
118	Bhola	33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	21	31	16	31				
119	Bhola	225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	59	85	85	85	109	Gas Shortage		
120	Payra	1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	680	980	1000	1000				
121	Potukhalhi	150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0	150	Line Overload		
122	Bhola	220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	170	223	222	222				
Barishal Zone Total						1958	1958	946	1335	1339	1354	109	244	
123	a) Baghabari	71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage		
	b) Baghabari	100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Gas Shortage		
124	Baghabari	50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	32	0	32				
125	Baghabari	200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	20	0	100				
126	Bera	70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	0	71	Under maint.		
127	Chapainawabganj	100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	85	0	85				
128	Katakhal	50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	0	32				
129	Katakhal	50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0	50	Fuel Oil Shortage		
130	Santahar	50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	0	32				
131	Sirajgonj	225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	164	182	170	180				
132	Sirajgonj	225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	130	220	0	0	220	Running on HSD		
133	Sirajgonj	225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	142	154	150	154	66	Gas Shortage		
134	Sirajgonj	400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	363	330	320	330	84	Gas Shortage		
135	Bogra	22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	22	21	22				
136	Uliapara	11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
137	Natore	52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	43	0	43				
138	Bagura	113 MW (Confidence) U-1	HFO (IPP)	6'18.55	113	113	35	113	113	113				
139	Bagura	113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	113	113	113				
140	Sirajgonj	6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0				
Rajshahi Zone Total						2129	2129	903	1389	904	1247	591	71	
141	a) Barapukuria	TPP Unit-1	Coal (PDB)	1 x 125	125	85	80	81	80	81				
	b) Barapukuria	TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling		
142	Barapukuria	275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0	274	Under maint.		
143	Rangpur	20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur	113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	56	113	56	113				
145	Saidpur	20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Majpara	Tatulia 5 MW Solar PP (Sympla Power)	Solar (IPP)	1 x 8	8	8	3	0	8	0				
147	Thakurgaon	119MW PP (Energygrip)	HFO (IPP)	6'20	115	115	0	72	0	72				
148	Lalmohithal	30 MW Solar (Intraco)	Solar (IPP)	1'30	30	30	11	0	12	0				
Rangpur Zone Total						830	750	150	266	156	266	0	359	
Sub-total: Plants in operation						22088	21710	10656.0	12747	10715	12880	2903	3054	
(B) Plants under long term maintenance/ contract expired														
149	Jamulpur	95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
150	Katpotti	52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
151	Bosila	108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
152	Keraniganj	100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
153	Bogura	20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
154	Amihura	30 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired						424	0	0	0	0	0			
Gross Total						22512	21710	10656	12747	10715	12880	2903	3054	
(C) Actual data of 13.10.22 (Yesterday) Thursday :														
01.	Max. Demand at eve. peak (Generation end)	:	12856	MW, at =	20:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	12414	MW, at =	20:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	
03.	Highest Generation (Generation end)	:	12747	MW, at =	20:00 hrs	Dhaka	4584	4584	0	Mymensingh	1007	927	80	
04.	Minimum Generation (Generation end)	:	9623	MW, at =	7:00 hrs	Chattogram	1312	1312	0	Sylhet	502	502	0	
05.	Day-peak Generation (Generation end)	:	10656	MW, at =	12:00 hrs	Khulna	1430	1430	0	Barishal	366	366	0	
06.	Evening-peak Generation (Generation end)	:	12747	MW, at =	20:00 hrs	Rajshahi	1235	1235	0	Rangpur	727	727	0	
07.	Evening Peak Load-shed (Sub-station end)	:	100	MW, at =	20:00 hrs	Cumilla	1252	1232	20					
08.	Minimum Generation Forecast up to 8:00 hrs.	:	9364	MW, at =	5:00 hrs									
09.	Generation shortfall at evening peak due to :	:				13.	Fuel cost :	(a) Gas = 144589249 Taka (b) Oil = 1074812668 Taka	(c) Coal = 192630531 Taka Total = 1412032448 Taka			100		
	a) Gas/LF limitation	:	2903	MW		14.	Maximum Temperature in Dhaka was : 33.3° C							
	d) Coal supply Limitation	:	0	MW		15.	Export through East-West interconnections :							
	b) Low water level in Kaptai lake	:	0	MW		At evening peak-hour	:	10656	MW, at	20:00 hrs				
	c) Plants under shut down/ maintenance	:	3054	MW		Maximum	:	800	MW, at	7:00 hrs				
10.	Total Energy (Generation + India Import)	:	262.65	MKWh		Energy	:	0	MKWh					
	By Gas = 132.035 MKWh			By Oil = 78.090 MKWh										
	By Coal = 22.071 MKWh			By Hydro = 3.655 MKWh										
	By Solar= 1.201 MKWh													
11.	Total Gas Supplied	:	996.45	MMCFD										
(D) Forecast of 14.10.22 (Today) Friday :														
01.	Maximum Demand	:	13200	MW	(Generation end)	04.	Maximum Load-shed							
02.	Maximum Generation	:	12880	MW	(Generation end)	05.	Total Generation							
03.	Reserve / Shortage	:	-320	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka : 30.8° C							

#Remarks