

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month October, 2022					Day : Saturday				Date : 15.10.22							
Probable Maximum Demand : 13500 MW					Probable Maximum Generation : 12813 MW											
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 98.61 ft		Today = 98.54 ft		Rule Curve = 107.20 ft							
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	14.10.22 (Yesterday)		15.10.22 (Today)		14.10.22 (Yesterday)		Status of Machines under shut-down/ Maintenance					
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :							
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation	Machines shut down						
												MW	(MW)	Description/ Remarks	Probable start-up date	
(A) Plants in operation:																
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work				
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	100	100	100	100							
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0		190	Under maint.				
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	Under maint.				
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	78	84	78	84							
5	Tong 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	Under maint.				
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0			Contract Expired				
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	322	307	320	330							
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225		Gas Shortage				
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling				
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	409	407	400	400							
11	Siddhirganj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage				
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	220	218	200	220			STG Under maint.				
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0		335	Under maint.				
14	Madangan-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55							
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	65	92	8	92							
16	Narshingsi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	19	19							
17	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	51	54	50	52							
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	33	33							
19	Rugganji 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	21	21	21	21							
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	49	48	48	48							
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	88	88	88							
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	132	32	132							
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54							
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	243	295	250	300							
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	94	127	90	127							
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	13	0	150							
27	Bramhangon 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	50	0	50							
28	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	50	0	50							
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	35	55							
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55							
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	73	93	17	93							
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	90	162	90	162							
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	28	0	30	0							
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	54	16	54							
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	65	90	8	90							
36	Meghnaghat 100 MW(IEEL)	HFO (NENP)	12x8.9	100	100	68	84	15	92							
37	Madangan 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0							
Dhaka Zone Total			6004	5847	2507	3065	2280	3231	435	1370						
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	154	154	154	154			Unit 1 under rehabilitation				
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage				
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.				
40	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0							
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	5	24	5	25							
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0							
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	44	44	25	44							
44	Sikalbaha 105 MW PP (Baraka Sikabaha)	HFO (IPP)	6x18.415	105	105	105	105	105	105							
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.				
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	219	227	225	225							
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	210	285	200	285							
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	76	90	32	90							
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	50	17	51							
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	29	29	29	29							
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	12	12	12	12							
*	Malancha, Cig EPZ (United)	Gas	5x8.73+3x9.34			20	37	5	20							
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	5	0	10	103		Fuel oil shortage				
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54							
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	105	105	105	105							
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	83	90	90	100							
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	66	76	66	75							
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	92	107	107	107							
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0							
Chattogram Zone Total			2442	2382	1315	1494	1256	1491	283	330						
58	Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage				
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	10	10	10	10							
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	181	192	180	200							
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	240	270	270	290							
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	280	280	280	280							
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCCL)	1x284	284	284	14	13	0	0	271		Gas Shortage				
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	5	5	10	10	50		Gas Shortage				
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187		Gas Shortage				
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51							
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	43	43	43	43							
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	32	46	16	44							
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	82	82	80	81							
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	51	100	51	100							
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22							
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11							
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	24	25	25	25							
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	43	8	43							
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	21	21	21	21							
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+40x1.515+15x1.058	200	200	0	110	0	100							
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	101	17	100							
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	8	8	9	9	105		Fuel Oil Shortage				
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35							
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	34	115	35	115							
**	Import (Tirupura)	India		160	160	108	162	143	166							
Cumilla Zone Total			3193	3169	1285	1753	1325	1764	747	0						
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	41	99	65	80	103		Gas Shortage				
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	13	13	13	13							
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	108	115	90	115							
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	68	116	100	127	84		Fuel oil shortage				
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	0	0	1.6	0							
86	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	27	0	50	0							
87	Tangail 22 MW PP(PGL)	HFO (IPP)	4x6.7	22	22	6	12	12	12							
Mymensingh Zone Total			622	614	263	355	332	347	187	0						

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	14.10.22 (Yesterday)		15.10.22 (Today)		14.10.22 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :				
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date	
88	Fenchugonj	CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	GT-1 Under maint.	
89	Fenchugonj	CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	30	30		60	GT-4 Under maint.	
90	Fenchugonj	51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	0	0	0	0	51		Gas Shortage	
91	Kushnara	163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0	109	54	STG Under maint.	
92	Hobiganj	11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	0	0	0	11		Gas Shortage	
93	Shahjibazar	GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	64	63	60	61				
94	Shahjibazar	330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar	66MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	10	81	0	81				
96	Sylhet	225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	140	140	140	140		91	ST Under maint.	
97	Sylhet	20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	18	18	18				
98	Sylhet	10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
99	Shahjahanulla	25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	0	0	0	25		Gas Shortage	
100	Bibiana-II	341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	290	280	280				
101	Bibiyan-II	400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	409	409	400	400				
102	Bibiyan South	383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	397	400	400	400				
103	Shahjibazar	100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Sylhet	50MW PP (EPL)	Gas (NENP)	2x27	50	50	6	0	0	0	50		Gas Shortage	
105	Fenchugonj	44MW (Energyprima)	Gas (NENP)	12x3.3+5x2	50	50	0	0	0	0	50		Gas Shortage	
Sylhet Zone Total						2522	2477	1411	1471	1368	1450	296	675	
106	Bheramara	GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
107	Bheramara	410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	200	225	200	215	185		Gas Shortage	
108	Fairpur	50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	36	0	44				
109	Gopalganj	100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	47	0	48				
110	Khulna	225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	120	153	120	120				
111	Noapara	100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	0	50				
112	Rupsha	105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	93	35	90				
113	Madhumati	100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	85	15	85				
114	Mongla Orion	100 MW Solar PP	Solar (IPP)		100	100	87	0	100	0				
115	Khulna	115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	66	16	66				
116	Noapara	40 MW PP (Khanjahan Ali)	HFO (NENP)	5x8.5	40	40	0	8	0	8	32		Fuel oil shortage	
	Rampal	1320 MW	Coal (BIFPCL)				0	0	0	0				
	Khulna	330 MW CCPP	Gas/HSD (BPDB)				0	0	0	0				
**	Bheramara	(HVCDC)	India		1000	1000	910	921	940	940				
Khulna Zone Total						2388	2384	1317	1634	1426	1666	217	0	
117	Barisal	110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	0	16		94	Line Overload	
118	Bhola	33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	18	28	16	28				
119	Bhola	225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	86	81	85	85	113		Gas Shortage	
120	Payra	1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	500	830	1000	1000				
121	Potukhalai	150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0		150	Line Overload	
122	Bhola	220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	166	220	222	222				
Barishal Zone Total						1958	1958	770	1175	1323	1351	113	244	
123	a) Baghabari	71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari	100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
124	Baghabari	50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	24	0	32				
125	Baghabari	200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	100				
126	Bera	70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	0		71	Under maint.	
127	Chapainawabganj	100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	84	0	85				
128	Katakhal	50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	24	0	32				
129	Katakhal	50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0	50		Fuel Oil Shortage	
130	Santahar	50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	0	32				
131	Sirajgonj	225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	157	181	170	180				
132	Sirajgonj	225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0	0	220		Running on HSD	
133	Sirajgonj	225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	135	161	150	154	59		Gas Shortage	
134	Sirajgonj	400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	388	350	320	330	64		Gas Shortage	
135	Bogra	22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	21	22	21	22				
136	Uliapara	11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
137	Natore	52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	34	0	43				
138	Bagura	113 MW (Confidence) U-1	HFO (IPP)	6x18.55	113	113	35	113	113	113				
139	Bagura	113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	26	113	113	113				
140	Sirajgonj	6.55 MW Solar	Solar (NWPGL)	1x6	6	6	1	0	6	0				
Rajshahi Zone Total						2129	2129	774	1149	904	1247	564	71	
141	a) Barapukuria	TPP Unit-1	Coal (PDB)	1 x 125	125	85	79	82	80	81				
	b) Barapukuria	TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
142	Barapukuria	275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0		274	Under maint.	
143	Rangpur	20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur	113 MW PP (Confidence)	HFO (IPP)	7x16x 2x3	113	113	20	113	56	113				
145	Saidpur	20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Maipara	Tatulia 5 MW Solar PP (Sympha Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0				
147	Thakurgaon	119MW PP (Energygac)	HFO (IPP)	6x20	115	115	0	72	0	72				
148	Lalmohithal	30 MW Solar (Intraco)	Solar (IPP)	1x30	30	30	30	0	12	0				
Rangpur Zone Total						830	750	136	267	156	266	0	359	
Sub-total: Plants in operation						22088	21710	9778.0	12363	10370	12813	2842	3049	
(B) Plants under long term maintenance/ contract expired														
149	Jamulpur	95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
150	Katpotti	52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
151	Bosila	108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
152	Keraniganj	100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
153	Bogura	20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
154	Amihura	30 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired						424	0	0	0	0	0			
Gross Total						22512	21710	9778	12363	10370	12813	2842	3049	
(C) Actual data of 14.10.22 (Yesterday) Friday :														
01.	Max. Demand at eve. peak (Generation end)	:	12596	MW, at =	20:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	11986	MW, at =	20:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	
03.	Highest Generation (Generation end)	:	12391	MW, at =	22:00 hrs	Dhaka	4190	4183	7	Mymensingh	1058	889	169	
04.	Minimum Generation (Generation end)	:	9364	MW, at =	8:00 hrs	Chattogram	1232	1232	0	Sylhet	451	442	9	
05.	Day-peak Generation (Generation end)	:	9778	MW, at =	12:00 hrs	Khulna	1489	1489	0	Barishal	350	350	0	
06.	Evening-peak Generation (Generation end)	:	12363	MW, at =	20:00 hrs	Rajshahi	1239	1239	0	Rangpur	716	716	0	
07.	Evening Peak Load-shed (Sub-station end)	:	215	MW, at =	20:00 hrs	Cumilla	1261	1231	30					
08.	Minimum Generation Forecast up to 8:00 hrs.	:	9697	MW, at =	5:00 hrs									
09.	Generation shortfall at evening peak due to :	:				13.	Fuel cost :							
	a) Gas/LF limitation	:	2842	MW			(a) Gas =	142581228	Taka	(c) Coal =	180486963	Taka		
	d) Coal supply Limitation	:	0	MW			(b) Oil =	1005658901	Taka	Total =	1328727092	Taka		
	b) Low water level in Kaptai lake	:	0	MW										
	c) Plants under shut down/ maintenance	:	3049	MW										
10.	Total Energy (Generation + India Import)	:	256.83	MKWh		14.	Maximum Temperature in Dhaka was :							
	By Gas =	129.776	MKWh	By Oil =	74.575	MKWh								
	By Coal =	21.744	MKWh	By Hydro =	3.736	MKWh	15.	Export through East-West interconnections :						
	By Solar =	1.500	MKWh				At evening peak-hour	:	9778	MW, at	20:00 hrs			
							Maximum	:	800	MW, at	7:00 hrs			
11.	Total Gas Supplied	:	1003.90	MMCFD			Energy	:	0	MKWh				
(D) Forecast of 15.10.22 (Today) Saturday :														
01.	Maximum Demand	:	13500	MW	(Generation end)	04.	Maximum Load-shed							
02.	Maximum Generation	:	12813	MW	(Generation end)	05.	Total Generation							
03.	Reserve / Shortage	:	-687	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :							