

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month October, 2022					Day : Wednesday				Date : 19.10.22			
Probable Maximum Demand : 13800 MW					Probable Maximum Generation : 12325 MW				Rule Curve = 107.70 ft.			
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 98.00 ft				Today = 97.90 ft			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	18.10.22 (Yesterday)		19.10.22 (Today)		18.10.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation	Machines shut down (MW)		
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	100	118	100	100			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Under maint.	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	79	82	80	82			
5	Tong 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0		Contract Expired	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	227	196	200	200	164	Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	210	190	200	200	260	Gas Shortage	
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	366	344	340	344			
11	Siddhirganj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	144	135	150	135		STG Under maint.	
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0	335	Under maint.	
14	Madangan-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	40	55	50	55			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	75	92	74	92			
16	Narshingsi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	16	16	16			
17	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	53	50	50	50			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
19	Rugganji 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	8	12	12	12			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	40	49	49	49			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	88	88	88			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	132	50	132			
23	Kamalshat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	54	17	54			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	293	293	245	300			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	144	147	70	147			
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	156	150	0	150			
27	Bramhangon 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	50	50	0	50			
28	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	50	50	0	50			
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	55	35	55			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	74	92	17	92			
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	162	90	162			
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	33	0	30	0			
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	18	36	17	17			
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	70	88	70	88			
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	66	92	62	92			
37	Madanganji 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0			
Dhaka Zone Total					6004	5847	2555	2916	2180	2900	634	1370
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	156	156	154	156		Unit 1 under rehabilitation	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	4	0	5	0				
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	18	25	25	25			
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	15	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	33	44	44	44			
44	Sikalbaha 105 MW PP (Baraka Sikabaha)	HFO (IPP)	6x18.415	105	105	68	105	105	105			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	225	228	225	225			
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	177	300	200	300			
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	76	90	76	90			
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	17	51			
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	8	37	37	37			
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	16	16	12	16			
*	Malancha, Ctp EP2 (United)	Gas	5x8.73+3x9.34			2	29	5	20			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	12	0	12	96	Fuel oil shortage	
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	36	54			
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	34	105	105	105			
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	100	100	90	100			
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	55	70	66	70			
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107			
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0			
Chattogram Zone Total					2442	2382	1148	1529	1329	1517	276	330
58	Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	10	44	5	44			
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	165	209	180	209			
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	200	90	270	310			
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	280	0	0	0			
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCCL)	1x284	284	284	149	288	284	0			
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	2	52	5	52			
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	100	100	187	Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	63	88	43	88			
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	35	33	33	33			
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	83	76	75	76			
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	51	51	51			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11			
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	8	25	25	25			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	52	8	52			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	15	21	21	21			
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+40x1.515+15x1.058	200	200	50	107	0	100			
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	93	17	93			
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	0	9	0	0	104	Fuel Oil Shortage	
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	54	36	54			
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	38	97	53	100			
**	Import (Tirupura)	India		160	160	146	156	143	166			
Cumilla Zone Total					3193	3169	1378	1637	1433	1658	425	0
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	33	49	50	50	153	Gas Shortage	
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	13	15	13	15			
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	89	108	90	108			
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	48	116	70	116	84	Fuel oil shortage	
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
86	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	53	0	50	0			
87	Tangail 22 MW PP(PGL)	HFO (IPP)	4x6.7	22	22	12	12	12	12			
Mymensingh Zone Total					622	614	250	300	287	301	237	0

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	18.10.22 (Yesterday)		19.10.22 (Today)		18.10.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	MW	Machines shut down (MW)		
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	GT-1 Under maint.	
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	30	30		60	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakattullah)	Gas (RPP)	19x2.90	51	51	0	0	0	0	51		Gas Shortage	
91	Kushiera 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0	109	54	STG Under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0	11		Gas Shortage	
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	60	60	60				
94	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	81	0	81				
96	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	140	140	130	140		91	ST Under maint.	
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	0	0	0	25		Gas Shortage	
100	Bibiya-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	280	305	300	305				
101	Bibiya-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	410	411	400	400				
102	Bibiya South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	0	0	0	0	50		Gas Shortage	
105	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12'3.3x5'2	50	50	0	0	0	0	50		Gas Shortage	
Sylhet Zone Total						2522	2477	1378	1485	1378	1474	296	675
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
107	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	215	205	200	205	205		Gas Shortage	
108	Fairdpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	33	0	33				
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	40	0	40				
110	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	120	120				
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	50	0	50				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	35	90	50	90				
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	85	105	15	105				
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	88	0	100	0				
115	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	16	16	16	16	99		Fuel oil shortage	
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	8	0	8	32		Fuel oil shortage	
	Rampal 1320 MW	Coal (BIFPCL)				0	0	0	0				
	Khulna 330 MW CAPP	Gas/HSD (BIFPCL)				0	0	0	0				
**	Bheramara (H/DC)	India		1000	1000	921	921	939	939				
Khulna Zone Total						2388	2384	1360	1468	1440	1606	336	0
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	16	0	16		94	Line Overload	
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	18	27	16	27				
119	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	87	86	85	86	108		Gas Shortage	
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	800	1060	1000	1000				
121	Potukhalhi 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0		150	Line Overload	
122	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220				
Barishal Zone Total						1958	1958	1141	1409	1321	1349	108	244
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	32	0	32				
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	94	0	100				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	0		71	Under maint.	
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	86	0	86				
128	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	0	32				
129	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	32	42	0	42				
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	0	32				
131	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	178	180	170	180				
132	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
133	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	152	147	140	150	73		Gas Shortage	
134	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	334	305	320	305	109		Gas Shortage	
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	19	22	20	22				
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	34	0	34				
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6'18.55	113	113	95	113	113	113				
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	77	113	113	113				
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0				
Raishahi Zone Total						2129	2129	911	1243	893	1252	573	71
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	83	81	80	81				
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0		274	Under maint.	
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	106	113	44	113				
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Mejpara, Tulsia 9 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0				
147	Thakurgaon 115MW PP (Energygad)	HFO (IPP)	6'20	115	115	0	74	0	74				
148	Lalmoshai 30 MW Solar (Intraco)	Solar (IPP)	1'30	30	30	34	0	12	0				
Rangpur Zone Total						830	750	230	268	144	268	0	359
Sub-total: Plants in operation						22088	21710	10351.0	12255	10405	12325	2885	3049
(B) Plants under long term maintenance/ contract expired													
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
150	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
151	Bosila 108MW PPI(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
153	Bogra 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
154	Amiura 30 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 1/10/2022	
Sub-Total: Plants under long term maintenance/ contract expired						424	0	0	0	0	0		
Gross Total						22512	21710	10351	12255	10405	12325	2885	3049
(C) Actual data of 18.10.22 (Yesterday) Tuesday :													
01.	Max. Demand at eve. peak (Generation end)	:	13660	MW, at =	20:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	13119	MW, at =	20:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	12255	MW, at =	20:00 hrs	Dhaka	4900	4692	208	Mymensingh	1070	810	260
04.	Minimum Generation (Generation end)	:	9668	MW, at =	6:00 hrs	Chattogram	1297	1081	216	Sylhet	563	438	125
05.	Day-peak Generation (Generation end)	:	10351	MW, at =	12:00 hrs	Khulna	1515	1515	0	Barishal	369	369	0
06.	Evening-peak Generation (Generation end)	:	12255	MW, at =	20:00 hrs	Rajshahi	1349	1187	162	Rangpur	792	678	114
07.	Evening Peak Load-shed (Sub-station end)	:	1295	MW, at =	20:00 hrs	Cumilla	1265	1055	210				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	9665	MW, at =	5:00 hrs								
09.	Generation shortfall at evening peak due to :	:				13. Fuel cost :							
a) Gas/LF limitation	:	2885	MW			(a) Gas =	131872382	Taka	(c) Coal =	204285867	Taka		
d) Coal supply Limitation	:	0	MW			(b) Oil =	1014894992	Taka	Total =	1351053240	Taka		
b) Low water level in Kaptai lake	:	0	MW										
c) Plants under shut down/ maintenance	:	3049	MW			14. Maximum Temperature in Dhaka was : 33.4° C							
10. Total Energy (Generation + India Import)	:	255.72	MKWh			15. Export through East-West interconnections :							
By Gas =	124.328	MKWh	By Oil =	74.900	MKWh	At evening peak-hour :							
By Coal =	25.593	MKWh	By Hydro =	3.739	MKWh	Maximum :							
By Solar =	1.383	MKWh				Energy :							
11. Total Gas Supplied	:	946.10	MMCFD										
(D) Forecast of 19.10.22 (Today) Wednesday :													
01.	Maximum Demand	:	13800	MW	(Generation end)	04.	Maximum Load-shed	:	1359	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	12325	MW	(Generation end)	05.	Total Generation	:	287.96	MKWh			
03.	Reserve / Shortage	:	-1475	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	31.9° C				