

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9364667, 9551095

Month October, 2022				Day : Thursday				Date : 20.10.22			
Probable Maximum Demand : 13800 MW				Probable Maximum Generation : 12761 MW				Rule Curve = 107.80 ft.			
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 97.90 ft.				Today = 97.81 ft.			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	19.10.22 (Yesterday)		20.10.22 (Today)		19.10.22 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation	Machines shut down (MW)	
(A) Plants in operation:											
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	100	100	100	100		
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	90	170		
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	68	84	80	84		
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0		Contract Expired
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	218	223	220	220	137	Gas Shortage
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	200	190	190	190	260	Gas Shortage
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	357	367	360	360		
11	Siddhirganj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	135	148	150	150		STG Under maint.
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0	335	Under maint.
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	45	55	45	55		
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	75	92	74	92		
16	Narshingsi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	16	19	16	16		
17	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	51	54	50	50		
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	12	14	12	12		
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	48	49	49	49		
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	88	88	88		
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	132	50	132		
23	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	54	0	54		
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	270	296	245	300		
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	130	149	70	147		
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	220	155	300	150		
27	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	91	50	100	50		
28	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	90	50	90	50		
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	35	35	55		
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	17	35		
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	74	92	17	92		
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	162	108	162		
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	32	0	30	0		
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17		
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	71	88	70	88		
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	67	85	62	85		
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0		
Dhaka Zone Total			6004	5847	2629	2916	2768	3086	607	1180	
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	154	156	154	156		Unit 1 under rehabilitation
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	4	0	5	0			
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25		
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	10	0	20	0		
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	25	44	44	44		
44	Sikalbaha 105 MW PP (Baraka Sikabaha)	HFO (IPP)	6x18.415	105	105	56	105	105	105		
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	221	227	225	225		
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	142	300	200	300		
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	90	25	90		
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	16	51	17	51		
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	37	37	37	37		
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	16	16	12	16		
*	Malancha, Ctp EPZ (United)	Gas	5x8.73+3x9.34			2	26	5	20		
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	12	0	12	96	Fuel oil shortage
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	36	54	36	54		
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	68	105	105	105		
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	100	25	100		
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	33	68	66	70		
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107		
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0		
Chattogram Zone Total			2442	2382	1002	1523	1213	1517	276	330	
58	Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	51	48	48	48		
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	122	207	180	209		
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	240	280	270	280		
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	0	0	0	0	360	Under maint.
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCCL)	1x284	284	284	413	288	336	412		
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	30	30	30	30		
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	45	8	8	8	187	Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51		
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	52	83	68	88		
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	42	0	0	42		
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	83	44	50	50		
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	51	17	50		
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	22	22	22		
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11		
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	8	25	25	25		
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	52	8	52		
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	21	21	21	21		
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+40x1.515+15x1.098	200	200	53	110	0	100		
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	111	17	110		
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	0	0	0	0	113	Fuel Oil Shortage
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	36	54		
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	52	96	53	100		
**	Import (Tripura)	India		160	160	150	162	143	166		
Cumilla Zone Total			3193	3169	1512	1735	1394	1929	434	360	
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	33	102	50	102	100	Gas Shortage
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	19	13	19		
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	88	107	90	108		
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	48	107	70	116	93	Fuel oil shortage
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0		
86	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	52	0	50	0		
87	Tangail 22 MW PP(PPLGL)	HFO (IPP)	4x6.7	22	22	12	12	12	12		
Mymensing Zone Total			622	614	251	347	287	357	193	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	19.10.22 (Yesterday)		20.10.22 (Today)		19.10.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	MW	Machines shut down (MW)		
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	GT-1 Under maint.	
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	41	41	41		49	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	0	0	0	0	51		Gas Shortage	
91	Kushiana 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0	109	54	STG Under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	5	5	5	6		Gas Shortage	
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	57	63	60	60				
94	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	81	0	81				
96	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	140	135	130	140		96	ST Under maint.	
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	0	0	0	25		Gas Shortage	
100	Bibiya-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	275	300	305				
101	Bibiya-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	395	408	400	400				
102	Bibiya South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	383	400	400	400				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	0	0	0	0	50		Gas Shortage	
105	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12'3.3x5'2	50	50	0	0	0	0	50		Gas Shortage	
Sylhet Zone Total						2522	2477	1353	1466	1394	1490	291	669
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
107	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	200	200	200	205	210		Gas Shortage	
108	Fairdipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	27	0	33				
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	76	0	40				
110	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	0				
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	50	0	50				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	55	91	50	90				
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	67	105	67	105				
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	83	0	100	0				
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	32	0	32	83		Fuel oil shortage	
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	8	0	8	32		Fuel oil shortage	
	Rampal 1320 MW	Coal (BIFPCL)				0	0	0	0				
	Khulna 330 MW CAPP	Gas/HSD (BFPDB)				0	0	0	0				
**	Bheramara (HVDC) India			1000	1000	920	920	938	938				
Khulna Zone Total						2388	2384	1325	1509	1355	1501	325	0
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	16	0	16		94	Line Overload	
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	21	31	16	27				
119	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	83	85	85	86	109		Gas Shortage	
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	770	1000	1000	1000				
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0		150	Line Overload	
122	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	222	220	220				
Barishal Zone Total						1958	1958	1110	1354	1321	1349	109	244
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	32	0	32				
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	54	0	100				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	0		71	Under maint.	
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	85	0	86				
128	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	0	32				
129	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	8	42	8	42				
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	31	0	32				
131	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	170	176	170	180				
132	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
133	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	148	143	140	150	77		Gas Shortage	
134	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	299	295	320	305	119		Gas Shortage	
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	22	20	22				
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	0	8				
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6'18.55	113	113	50	113	113	113				
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	43	113	113	113				
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0				
Raishahi Zone Total						2129	2129	749	1157	901	1226	587	71
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	83	82	80	81				
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0		274	Under maint.	
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	90	113	70	113				
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Mejpara, Tulsia 9 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0				
147	Thakurgaon 115MW PP (Energygao)	HFO (IPP)	6'20	115	115	0	112	0	112				
148	Lalmoshai 30 MW Solar (Intraco)	Solar (IPP)	1'30	30	30	33	0	12	0				
Rangpur Zone Total						830	750	213	307	170	306	0	359
Sub-total: Plants in operation						22088	21710	10144.0	12314	10803	12761	2822	3213
(B) Plants under long term maintenance/ contract expired													
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
150	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
151	Bosila 108MW PPI(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
153	Boqura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
154	Amiura 30 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 1/10/2022	
Sub-Total: Plants under long term maintenance/ contract expired						424	0	0	0	0	0		
Gross Total						22512	21710	10144	12314	10803	12761	2822	3213
(C) Actual data of 19.10.22 (Yesterday) Wednesday :													
01.	Max. Demand at eve. peak (Generation end)	:	13019	MW, at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	12528	MW, at =	21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	12314	MW, at =	21:00 hrs	Dhaka	4709	4564	145	Mymensingh	1057	926	131
04.	Minimum Generation (Generation end)	:	9393	MW, at =	9:00 hrs	Chattogram	1232	1125	107	Sylhet	558	480	78
05.	Day-peak Generation (Generation end)	:	10144	MW, at =	12:00 hrs	Khulna	1418	1418	0	Barishal	370	370	0
06.	Evening-peak Generation (Generation end)	:	12314	MW, at =	21:00 hrs	Rajshahi	1226	1226	0	Rangpur	691	691	0
07.	Evening Peak Load-shed (Sub-station end)	:	650	MW, at =	21:00 hrs	Cumilla	1268	1079	189				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	9346	MW, at =	5:00 hrs								
09.	Generation shortfall at evening peak due to :	:				13. Fuel cost : (a) Gas = 128961884 Taka (c) Coal = 220443889 Taka (b) Oil = 1039341841 Taka Total = 1388747614 Taka							
	a) Gas/LF limitation	:	2822	MW									
	d) Coal supply Limitation	:	0	MW									
	b) Low water level in Kaptai lake	:	0	MW									
	c) Plants under shut down/ maintenance	:	3213	MW									
10.	Total Energy (Generation + India Import)	:	256.16	MKWh									
	By Gas = 124.701 /MKWh			By Oil = 75.385 MKWh									
	By Coal = 25.165 MKWh			By Hydro = 3.724 MKWh									
	By Solar = 1.425 /MKWh												
11.	Total Gas Supplied	:	981.00	MMCFD									
(D) Forecast of 20.10.22 (Today) Thursday :													
01.	Maximum Demand	:	13800	MW	(Generation end)	04.	Maximum Load-shed	:	958	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	12761	MW	(Generation end)	05.	Total Generation	:	287.07	MKWh			
03.	Reserve / Shortage	:	-1039	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	32.6° C				