

Date : 21-Oct-22

Page -2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CCGP-Unit-3 (GT	PDB	1'260	260	0	0	Under maint.
2	Ghorasal Repowered CCGP Unit-4	PDB	1'210	180	100	2399000	Line O/L
3	Ghorasal 365 MW CCGP Unit-7	PDB	1'243+1'122	365	0	0	Under maint.
4	Ghorashal 78.5 MW PP(MAX)	QRPP	2'40	0	0	0	
4	Ghorashal 108MW PP (Regent)	IPP	34'3.35	108	84	1912136	Engine problem
5	Haripur G1TPP	SBU, PDB	2'32	20	0	0	Under maint.
6	Haripur 412 MW CCGP	EGCB	1'273+1'139	412	405	9539580	
7	Haripur 360MW CCGP(HPL)	IPP	1'235+1'125	360	253	5930000	Gas shortage
8	Meghnaghat 450 MW CCGP(MPL)	IPP	2'150+1'150	450	225	4846000	Gas shortage
9	Meghnaghat 100 MW(IEL)	NENP	12'8.9	100	83	1475520	Engine problem
10	Meghnaghat CCGP(Summit)	IPP	2'110+1'110	335	0	0	Gas shortage
11	Madanganj 102 PP(Summit)	NENP	6'17	102	0	0	Under maint.
12	Madanganj-55 MW PP(Summit)	IPP	3'17.08+1'11.3	55	55	1318422	
13	Keraniganj 100 MW PP (Powerpac)	QRPP	8'13.45	0	0	0	Contract Expired
14	Narshingdi 22 MW PP (Doreen)	SIPP, REB	8'2.90	22	19	413856	Engine problem
15	210 MW Siddhirgonj TPP	PDB	1'210	115	0	0	Under maint.
16	Siddhirgonj 2'120 MW GTTP	EGCB	2'105	210	0	0	Gas shortage
17	Siddhirgonj 100 PP(Dutch Bangla)	NENP	12'8.9	100	87	1604160	Engine problem
18	Siddhirgonj 335 MW CCGP	EGCB	1'217+1'118	335	166	3976074	Gas shortage
19	Gagnagar 102 MW PP (Digital Power)	IPP	12'8.924	102	92	1737216	Engine problem
20	Katpotti 52 MW PP (Sirha)	IPP	7'7.9	0	0	0	Fuel shortage
21	Kamalaghat 54 MW PP(Banco Energy)	IPP	3'18	54	54	664920	
22	Kodda 150MW PP	BPDB-RPCL	9'17.06	149	132	964320	Engine problem
23	Manikganj 55 MW PP (Northern)	IPP	3'19.3	55	55	913686	
24	Nababganj 55 MW PP (Southern power)	IPP	3'19.3	55	55	913476	
25	Bosila 108MW PP(CLLC)	IPP	12'8.775+1'3.5	0	0	0	
26	Summit Power (Madhabadi+Ashulia)	SIPP, REB	3'3.67+4'8.73	80	46	1073980	Engine problem
27	Maona 33 MW PP(Summit)	SIPP,REB	4'8.73	33	33	729360	
28	Rupganj 33 MW PP(Summit)	SIPP,REB	4'8.73	33	13	336900	Engine problem
29	Gazipur 52 MW PP	RPCL	6'8.9	52	49	1093920	0.00
30	Tongi 80 MW GTPP	PDB	1' 105	105	0	0	Under maint.
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18'17.076	300	294	4069745	
32	Keraniganj 300 MW PP (APR)	IPP	256'1.4	300	78	221020	Fuel conservation
33	Bramhanganj 100 MW PP (Aggreko)	IPP	114'0.959	100	50	243106	Fuel conservation
34	Aurahati 100MW PP (Aggreko)	IPP	0.85'23+0.95'91	100	50	217089	Fuel conservation
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	8'18.45+8.97	149	125	2519424	Engine problem
36	Gazipur 100 MW PP	RPCL	6'17.5	105	88	2102400	Engine problem
37	Meghnaghat 104 MW PP (OPCL)	IPP	18.5'6	104	92	1767360	Engine problem
38	Manikgonj 162MW PP(MPGL)	IPP	9'18	162	162	1949760	
39	Spectra Solar Plant Ltd.	IPP	35	35	0	229653	
40	Kanchan Purbachal Power Generation Ltd.	IPP	18.4'3	55	54	1239840	
Dhaka area Total				5847	3174	60654333	
41	Chattogram TPP-1	PDB	1'210	180	0	0	Machine problem
42	Chattogram TPP-2	PDB	1'210	180	0	0	Gas shortage
42	Raozan 25 MW PP	RPCL	3'8.9	25	25	568985	
43	Teknaf 20MW PP (Solartech)	IPP	0	20	0	128115	
44	Patenga 50MW PP (Baraka)	IPP	8'6.98	50	44	792000	Engine problem
45	Kaptai Hydro. Unit-1,2,3,4, 5	PDB	2'40+3'50	230	155	3690982	Low water level
46	Sikalbaha 225MW	PDB	1'150+1'175	225	150	3539646	ST Under maint
47	Sikalbaha Peaking GT	PDB	1'150	150	0	0	Under maint.
48	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	6'17.5	105	105	1786472	
49	Hafizabari 100 MW peaking PP	PDB	11'8.9	98	37	861888	Fuel shortage
50	Dohazari-Kalaish 100 MW Peaking	PDB	8'17	102	51	629994	Fuel shortage
51	Juldah 100 MW Unit-1 (Acorn)	NENP	8'13.45	100	56	919200	Fuel shortage
52	Juldah 100 MW PP Unit-3 (Acorn)	IPP	8'13.5	100	90	951360	Engine problem
53	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8'2.90	22	16	380256	Engine problem
*	Malancha, Clg. EPZ (Unlited)		5'8.73+3'9.34	0	34	775200	
54	Chattogram 108 MW PP (ECPV)	IPP	16'7	108	12	79680	Fuel shortage
55	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	28879	
56	Anwara 300 MW PP (Unlited)	IPP	17'17+24	300	301	3683345	
57	Jodiac Power	IPP	3'18.55+1'3.6	54	54	1367459	
58	Karnaphuli Power Ltd.	IPP	18.415'6+6.5	110	105	1769738	
59	Juldah unit-2 (Acorn)	IPP	8'13.6	100	100	960000	
60	Anlima Energy Ltd.	IPP	6'21.2	116	107	2566800	Engine problem
Mrshara 150 MW				BPDB-RPCL	18.5'9	0	On test.
Chattogram area Total				2382	1442	25477999	
61	Ashuganj TPP Unit- 3	APSCL	1'150	0	0	0	Contract Expired
	Ashuganj TPP Unit- 4	APSCL	1'150	0	0	0	Contract Expired
	Ashuganj TPP Unit- 5	APSCL	1'150	134	0	0	Gas shortage
62	Ashuganj 225 MW CCGP	APSCL	1'142+1'175	221	208	4608000	Gas shortage
63	Ashuganj 450 MW CCGP(North)	APSCL	1'360	360	0	0	Gas shortage
64	Ashuganj 450 MW CCGP(South)	APSCL	1'360	360	310	6971000	Gas shortage
	Ashuganj 420 MW CCGP(East)	APSCL	284'1+136'1	284	203	6635000	On test.
65	Ashuganj 50 MW PP	APSCL	14'3.968	45	45	864216	
66	Ashuganj 55 MW PP (Precision)	QRPP	15'4	55	30	362880	Gas shortage
67	Ashuganj 195MW PP (APSCL-Unlited)	IPP	20'9.73+1'16	195	8	217454	Gas shortage
68	Ashuganj 51 MW PP (Midland)	IPP	6'9.34	51	51	1183862	
69	Ashuganj 150MW PP (Midland)	IPP	23'7.015	150	73	1671054	Fuel shortage
70	Titas 50 MW Peaking PP	PDB	6'8.92	52	0	98192	Fuel shortage
71	Chandpur 150 MW CCGP	PDB	1'106+1'57	163	50	1184410	Machine problem
72	Chandpur 200MW (Desh energy)	IPP	12'18.4	200	51	642720	Fuel shortage
73	Feni 22MW PP (Doreen)	SIPP, PDB	8'2.90	22	21	503136	
74	Feni 11 MW PP (Doreen)	SIPP, REB	4'2.90	11	11	174240	
**	Import (Tripura)	Imported power	0	160	158	3326400	
	Jangalia 33MW PP (Summit)	SIPP, PDB	4'8.73	33	25	550000	Engine problem
76	Jangalia 52 MW PP (Lakshnavi)	IPP	6'8.92	52	43	746669	Engine problem
77	Cumilla 25 MW PP (Summit)	SIPP, REB	3'3.67+2'6.97	25	15	373430	Engine problem
78	Daudkandi 200 MW PP (B.Trac)	IPP	154'1.4	200	70	121728	Fuel conservation
79	Feni Lanka Power	IPP	7'18.415+1'9.78	114	111	1121760	
80	Chowmuhani 113 MW	IPP	12'9.78+2'3.1	113	0	53760	Fuel shortage
81	Bhairab 54.5 MW	IPP	3'18.2	54	35	833080	Engine problem
82	Chandpur 115(Doreen)	IPP	4'18.5+2'22.5	115	115	1680580	
Cumilla Area Total				3169	1633	33933551	
83	RPCL 210MW CCGP	IPP	4'35+1'70	202	48	1541780	Gas shortage
84	Tangail 22 MW PP (Doreen)	SIPP, PDB	8'2.90	22	18	416880	Gas shortage
85	Jamalpur 95 MW PP(Powerpac)	IPP	12'8.924	0	0	0	Under maint.
86	Sarishabari 3 MW Solar Plant	IPP	1'3	3	0	7050	
87	Mymensingh 200 MW PP (Unlited)	IPP	9'78.21	200	100	1456200	Fuel shortage
88	Jamalpur 115 MW PP (Unlited)	IPP	9'78.12	115	115	2288400	Engine problem
89	Sutakhal 50 MW Solar PP	IPP	50	50	0	377630	
90	Tangail Pali Power Gen 22 MW	IPP	4'6.7	22	12	193200	Engine problem
Mymensingh Area Total				614	293	6284120	
91	Fenchugonj CCGP Phase-1	PDB	2'32+1'33	70	30	715000	Machine problem
92	Fenchugonj CCGP Phase-2	PDB	2'35+1'35	90	41	935160	Machine problem
93	Kushkhara 163 MW CCGP (KP)	IPP	1'109+1'54	163	0	0	Gas shortage
94	Shahjibazar 330 MW CCGP	PDB	3'110	330	0	0	Under maint.
95	Fenchugonj 51 MW PP (Barakatullah)	RPP	19'2.90	51	0	129000	Gas shortage
	Fenchuganj 44MW (Energyprima)	NENP	12'3.3+5'2	50	0	0	Gas shortage
96	Hobiganj 11MW PP Confidence-E	SIPP, REB	4'2.90	11	5	120240	Engine problem
97	Shahjibazar GTPP Unit- 8 & 9	PDB	2'35	66	63	1442112	
98	Shahjibazar 80MW PP (Shahjibazar)	RPP	3'22.90	86	81	536640	
99	Shahjibazar 100 MW GTPP	PDB	1'100	100	0	0	Under maint.
100	Sylhet 225 MW CCGP	PDB	1'142+1'89	231	130	2752680	ST Under maint
101	Sylhet 20 MW GTPP	PDB	1'20	20	19	431000	
	Sylhet 50MW PP (EPL)	NENP	27'2	50	0	107000	Gas shortage
102	Shahjahanulla 25 MW PP	SIPP, REB	3'9.34	25	0	0	Gas shortage
103	Bibiana-II 341 MW CCGP (Summit)	IPP	1'222+1'119	341	280	7176500	FGMO
104	Bibiyan-III 400 MW CCGP	PDB	400 MW	400	408	9619000	
105	Sylhet 10MW PP (Desh)	RPP	6'1.95	10	10	241020	
106	Bibiyan South 400 MW	PDB	400 MW	383	400	9345200	
Sylhet Area Total				2477	1467	33552752	
107	Bheramara GTPP Unit-3	PDB	1'20	16	0	0	Fuel shortage
**	Bheramara (HVDC)	Imported power	2'500	1000	919	22248000	
108	Khulna 115 PP MW (KPCL-2)	NENP	7'17	115	49	269760	Fuel shortage
109	Fardpur 50 MW Peaking PP	PDB	8'6.88	54	40	184320	Engine problem
110	Khulna 225 MW CCGP	NWPGCL	1'150+1'175	230	0	0	Fuel shortage
111	Gopalganj 100 MW Peaking PP	PDB	16'6.98	109	70	381312	Engine problem
112	Bheramara 410 MW CCGP	NWPGCL	1'278+1'132	410	205	5078016	Gas shortage
	Noapara 40 MW PP (Khanjahan Ali)	NENP	5'8.5	40	8	77250	Fuel shortage
113	Noapara 100 MW PP (Bangla Trac)	IPP	70'1.4	100	50	29760	Fuel conservation
114	Rupsha 105 MW PP (Orion rupsha)	IPP	6'18.445	105	72	1216800	Engine problem
115	Madhumati 100 MW PP	NWPGCL	6'18	105	105	1685952	
116	Mongla Orion 100 MW Solar PP	IPP	100	100	0	601920	
	Khulna 330 MW CCGP (OIL)	BPDB	1'220+1'110	0	0		