

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9364667, 9551095

Month October, 2022				Day : Monday				Date : 24.10.22			
Probable Maximum Demand : 8500 MW				Probable Maximum Generation : 11815 MW							
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 97.21 ft.		Today = 97.02 ft.		11815 MW		Rule Curve = 108.20 ft.	
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	23.10.22 (Yesterday)		24.10.22 (Today)		23.10.22 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation	Machines shut down (MW)	
(A) Plants in operation:											
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	100	100	100	100		
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180		
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	81	84	80	84		
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0		Contract Expired
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	228	228	220	228	132	Gas Shortage
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	215	215	200	215	235	Gas Shortage
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115 Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	351	373	350	370		
11	Siddhirganj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	153	154	150	154		STG Under maint.
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0		335 Under maint.
14	Madangan-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55		
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	75	92	74	92		
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	19	19		
17	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	44	48	40	48		
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
19	Ruggan 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	14	15	12	17		
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	42	49	41	49		
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	88	88	88		
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	132	16	132		
23	Kamalshat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54		
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	165	258	160	260		
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	101	134	80	134		
26	Keraniganj 300 MW PP (APR)	HSO (IPP)	256x1.4	300	300	254	232	0	150		
27	Bramhangon 100 MW PP (Aggreko)	HSO (IPP)	23x0.85+91x.959	100	100	90	90	0	50		
28	Aurahi 100MW PP (Aggreko)	HSO (IPP)	23x0.85+91x.959	100	100	87	90	0	50		
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	35	55		
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	35	35		
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	73	92	74	92		
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	162	35	162		
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	11	0	30	0		
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	54	54	54	54		
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	71	89	63	89		
36	Meghnaghat 100 MW(IEEL)	HFO (NENP)	12x8.9	100	100	59	83	67	83		
37	Madangan 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0		
Dhaka Zone Total				6004	5847	2797	3293	2308	3132	577	1180
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	121	156	155	156		Unit 1 under rehabilitation
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180 Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	1	0	5	0		
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	25	25	25		
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	8	0	20	0		
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	25	44	32	44		
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	51	105	51	105		
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150 Under maint.
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	151	150	150		
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	141	195	140	195		
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	90	25	90		
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	16	51	17	51		
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	31	25	24	25		
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0		
*	Malancha, Ctp EP2 (United)	Gas	5x8.73+3x9.34			3	15	10	15		
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0	108	Fuel oil shortage
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54		
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	70	105	61	105		
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	100	25	100		
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	33	80	33	80		
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	89	107	107	107		
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0		
Chattogram Zone Total				2442	2382	710	1303	934	1302	288	330
58	Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	30	10	10	10		
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	95	140	120	140	81	Gas Shortage
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	250	355	260	300		
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	0	0	200	250		360 Under maint.
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCCL)	1x284	284	284	402	120	0	0		
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	5	5	5	5	50	Gas Shortage
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187	Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	0	0	0	0		
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	48	48	48	48		
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	43	43	40	43		
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	49	50	50	50		
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	200	17	100		
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22		
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	11	11		
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	8	25	25	25		
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	34	8	34		
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	14	20	12	20		
76	Daudkandi 200 MW PP (B.Trac)	HSO (IPP)	99x1.4+40x1.515+15x1.058	200	200	122	122	0	100		
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	34	111	17	111		
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	0	0	0	0	113	Fuel Oil Shortage
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35		
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	50	115	53	115		
**	Import (Tripura)	India		160	160	152	154	143	166		
Cumilla Zone Total				3193	3169	1402	1627	1084	1593	565	360
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	33	103	70	100	99	Gas Shortage
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	19	18	19		
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	46	97	90	97		
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	49	88	48	88	112	Fuel oil shortage
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0		
86	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	15	0	50	0		
87	Tangail 22 MW PP(PGCL)	HFO (IPP)	4x6.7	22	22	12	12	12	12		
Mymensingh Zone Total				622	614	175	319	290	316	211	0

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	23.10.22 (Yesterday)		24.10.22 (Today)		23.10.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	MW	Machines shut down (MW)		
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	GT-1 Under maint.	
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	41	41	41	41		49	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	0	0	0	0	51		Gas Shortage	
91	Kushiana 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0	109	54	STG Under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0	11		Gas Shortage	
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	57	58	60	60				
94	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	20	81	0	81				
96	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	115	107	130	130		124	ST Under maint.	
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	0	0	0	25		Gas Shortage	
100	Bibiya-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	250	300	300				
101	Bibiyan-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	410	407	400	400				
102	Bibiyan South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	395	394	380	383				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	0	0	0	0	50		Gas Shortage	
105	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12'3.3x5'2	50	50	7	0	0	0	50		Gas Shortage	
Sylhet Zone Total						2522	2477	1393	1396	1369	1453	296	697
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
107	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	195	200	190	200	210		Gas Shortage	
108	Fairdipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	32	0	32				
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	76	0	76				
110	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	0				
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	50	0	50				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	55	75	50	75				
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0				
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	11	0	100	0				
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	16	0	16	99		Fuel oil shortage	
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	8	0	8	32		Fuel oil shortage	
	Rampal 1320 MW	Coal (BIFPCL)				303	337	0	0				
	Khulna 330 MW CAPP	Gas/HSD (BFPDB)				0	0	0	0				
**	Bheramara (H/DC)	India		1000	1000	918	918	937	937				
Khulna Zone Total						2388	2384	1482	1712	1277	1394	341	0
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	5	16	0	16		94	Line Overload	
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	20	27	16	27				
119	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	65	60	60	60	134		Gas Shortage	
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	610	660	1000	1000				
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0		150	Line Overload	
122	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	200	220	100	220				
Barishal Zone Total						1958	1958	900	983	1176	1323	134	244
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	32	0	32				
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	100	0	100				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	0		71	Under maint.	
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	86	0	86				
128	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	0	32				
129	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	42	42	16	42				
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	25	0	25				
131	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
132	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0	0	220		Gas Shortage	
133	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	144	148	140	148	72		Gas Shortage	
134	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	292	296	280	300	118		Gas Shortage	
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	22	20	22				
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	16	0	8				
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6'18.55	113	113	113	113	113	113				
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	106	113	113	113				
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	2	0	6	0				
Raishahi Zone Total						2129	2129	728	1036	689	1032	791	71
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	80	82	80	82				
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0		274	Under maint.	
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	107	113	90	113				
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Majpara, Tulsia 9 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0				
147	Thakurgaon 115MW PP (Energygao)	HFO (IPP)	6'20	115	115	0	75	70	75				
148	Lalmoshai 30 MW Solar (Intraco)	Solar (IPP)	1'30	30	30	36	0	12	0				
Rangpur Zone Total						830	750	230	270	260	270	0	359
Sub-total: Plants in operation						22088	21710	9817.0	11939	9397	11815	3203	3241
(B) Plants under long term maintenance/ contract expired													
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
150	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
151	Bosila 108MW PPI(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
153	Boqura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
154	Amiura 30 MW PP(Sinha)	HFO (QRPP)	7x7.79	30	0	0	0	0	0			Contract Expired on 1/10/2022	
Sub-Total: Plants under long term maintenance/ contract expired						424	0	0	0	0	0		
Gross Total						22512	21710	9817	11939	9397	11815	3203	3241
(C) Actual data of 23.10.22 (Yesterday) Sunday :													
01.	Max. Demand at eve. peak (Generation end)	:	13060	MW, at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	12476	MW, at =	21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	11939	MW, at =	21:00 hrs		MW	MW	MW		MW	MW	MW
04.	Minimum Generation (Generation end)	:	8928	MW, at =	9:00 hrs	Dhaka	4746	4578	168	Mymensingh	984	762	222
05.	Day-peak Generation (Generation end)	:	9817	MW, at =	12:00 hrs	Chattogram	1303	1110	193	Sylhet	518	495	23
06.	Evening-peak Generation (Generation end)	:	11939	MW, at =	21:00 hrs	Khulna	1383	1273	110	Barishal	312	312	0
07.	Evening Peak Load-shed (Sub-station end)	:	1033	MW, at =	21:00 hrs	Rajshahi	1281	1141	140	Rangpur	723	675	48
08.	Minimum Generation Forecast up to 8:00 hrs.	:	8027	MW, at =	5:00 hrs	Cumilla	1226	1097	129				
09.	Generation shortfall at evening peak due to :	:				Total 12476 11443 1033							
a)	Gas/LF Limitation	:	3203	MW		13. Fuel cost : (a) Gas = 126394646 Taka (c) Coal = 163239794 Taka							
d)	Coal supply Limitation	:	0	MW		(b) Oil = 973801408 Taka Total = 1263435848 Taka							
b)	Low water level in Kaptai lake	:	0	MW									
c)	Plants under shut down/ maintenance	:	3241	MW									
10.	Total Energy (Generation + India Import)	:	248.11	MKWh		14. Maximum Temperature in Dhaka was : 30.3° C							
	By Gas = 121.363 /MKWh			By Oil = 69.977 /MKWh		15. Export through East-West interconnections :							
	By Coal = 26.789 /MKWh			By Hydro = 3.478 /MKWh		At evening peak-hour : 9817 MW, at 21:00 hrs							
	By Solar = 0.655 /MKWh					Maximum : 120 MW, at 18:00 hrs							
11.	Total Gas Supplied	:	919.67	MMCFD		Energy : 0 /MKWh							
(D) Forecast of 24.10.22 (Today) Monday :													
01.	Maximum Demand	:	8500	MW (Generation end)		04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	11815	MW (Generation end)		05.	Total Generation	:	176.64	MKWh			
03.	Reserve / Shortage	:	3315	MW (Generation end)		06.	Probable Max. Temperature in Dhaka :		23.3° C				