

Till now the maximum generation is :-		14782.0		21:00 Hrs on 16-Apr-22		Reporting Date : 25-Oct-22	
The Summary of Yesterday's 24-Oct-22 Generation & Demand				Today's Actual Min Gen. & Probable Gen. & Demand			
Day Peak Generation	: 8146.0 MW	Hour :	9:00	Min. Gen. at	3:00	2828 MW	
Evening Peak Generation	: 5652.0 MW	Hour :	18:00	Available Max Generation		11962 MW	
E.P. Demand (at gen end)	: 5652.0 MW	Hour :	18:00	Max Demand (Evening)		11000 MW	
Maximum Generation	: 9759.0 MW	Hour :	1:00	Reserve(Generation end)		962 MW	
Total Gen. (MKWH)	: 167.2	System Load Factor	: 71.38%	Load Shed	:	0 MW	
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR							
Export from East grid to West grid :- Maximum		120 MW	at	18:00	Energy	MKWHR.	
Import from West grid to East grid :- Maximum		MW	at	-	Energy	- MKWHR.	
level of Kaptai Lake at 6:00 A.M on 25-Oct-22							
Actual	: 96.82	Ft.(MSL)		Rule curve	: 108.30	Ft.(MSL)	
Gas Consumed :	Total = 648.30	MMCFD.		Oil Consumed (PDB) :			
				HSD :		Liter	
				FO :		Liter	
Cost of the Consumed Fuel (PDB+)	Gas :	Tk105,454,134		Oil :	Tk337,743,509	Total :	Tk576,561,149
	Coal :	Tk133,363,506					
Load Shedding & Other Information							
Area	Yesterday			Today			
	Estimated Demand (S/S end)			Estimated Shedding (S/S end)		Rates of Shedding	
	MW		MW	MW		(On Estimated Demand)	
Dhaka	0	0:00	4259	0		0%	
Chittagong Area	0	0:00	1206	0		0%	
Khulna Area	0	0:00	1592	0		0%	
Rajshahi Area	0	0:00	1413	0		0%	
Cumilla Area	0	0:00	1203	0		0%	
Mymensingh Area	0	0:00	994	0		0%	
Sylhet Area	0	0:00	444	0		0%	
Barisal Area	0	0:00	362	0		0%	
Rangpur Area	0	0:00	784	0		0%	
Total	0		12257	0			
Information of the Generating Units under shut down.							
Planned Shut-Down				Forced Shut-Down			
				1) Barapukuria ST: Unit- 2 2) Ghorasal-3, 7 3) Ashuganj-5 4) Baghabari-71,100 MW 5) Raozan unit-1 & 2 6) Siddhirganj 210 MW . 7) Shajibazar 330 MW 8) Sirajganj-2			
Additional Information of Machines, lines, Interruption / Forced Load shed etc.							
a) Shahjibazar 132/33 kV T-2 transformer tripped at 08:46 due to 33 kV Hobiganj feeder fault and was switched on at 08:56.				About 09 MW power interruption occurred under Shahjibazar S/S area from 08:46 to 08:56.			
b) Rangpur 132/33 kV T-2 transformer was under shut down from 08:42 to 14:28 for A/M.				About 10 MW power interruption occurred under Rangpur S/S area from 08:42 to 14:28.			
c) Madunaghat-Chandraghona 132 kV Ckt-1,2 was under shut down from 09:30 to 11:41 for project work.							
d) Kodda-Rajendrapur 132 kV Ckt-2 tripped at 09:56 showing dist Z1 at Rajendrapur end and was switched on at 10:29.							
e) Daudkandi-Cumilla(N) 132 kV Ckt-1 tripped at 09:28 showing SOTF at Daudkandi end and was switched on at 15:17.							
f) Gopalganj 132/33 kV T-1,T-2 transformer 33 kV side tripped at 08:56 due to 33 kV T1 B phase CB burst and was switched on at T-2 transformer at 09:23.				About 24MW power interruption occurred under Gopalganj S/S area from 08:56 to 09:23.			
g) Daudkandi 132/33 kV T-1 & T-2 transformer 33 kV side tripped at 10:45 due to 33 kV PBS feeder fault and were switched on at 10:57.				About 72MW power interruption occurred under Daudkandi S/S area from 10:45 to 10:57.			
h) Faridpur 132/33 kV T-1 & T-2 transformer tripped at 09:47 due to 33 kV Harukandi feeder fault and were switched on at 10:03.				About 50MW power interruption occurred under Faridpur S/S area from 09:47 to 10:03.			
i) Saidpur 132/33 kV T-3 transformer was under shut down from 08:25 to 16:09 for A/M.							
j) Pabna 132/33 kV T-3 transformer was under shut down from 10:13 to 11:11 for C/M.							
k) Pabna 132/33 kV T-2 transformer was under shut down from 11:11 to 15:26 for C/M.							
l) Ashuganj 225 MW CCPP ST was synchronized at 08:38.							
m) Ashuganj(N) GT was synchronized at 09:47.							
n) Bhola Notun Biddut GT-1 was under shut down at 08:53							
o) Bhola CCPP GT-2 tripped at 08:58 due to GBC trip.							
p) Rampal #01 shut down at 10:01 due to bad weather							
q) Bhola Notun Biddut STG tripped at 09:40 and was synchronized at 14:29.							
r) Ghorasal #04 was shut down at 15:44 due to bad weather.							
s) Hasnabad 33 kV main bus,T1 & T5 transformer tripped at 14:23 due to 33 kV Pagla feeder fault and were switched on at 14:40.				About 40 MW power interruption occurred under Hasnabad S/S area from 14:23 to 14:40.			
t) Joydevpur 132/33 kV T-4 transformer tripped at 15:49 due to 33 kV Sreepur feeder fault and was switched on at 17:01.				About 21 MW power interruption occurred under Joydevpur S/S area from 15:49 to 17:01.			
u) Cumilla(S) 132/33 kV T-1 transformer tripped at 16:04 showing lockout,O/C relay and was switched on at 16:23.							
v) Bagerhat-Bandharia 132 kV Ckt tripped at 15:40 showing dist Z1 from both end and was switched on at 18:29.							
w) Tongi-Bashundhara 132 kV Ckt-1 tripped at 16:21 showing dist C-phase at Tongi end & dist Z1 at Bashundhara end and was switched on at 16:31.							
x) Bhulta 132/33 kV T-1 transformer tripped at 16:36 showing Gen trip, differential A,C,Buchholtz & PRD							
y) Siddhirganj 335 MW GT tripped at 16:37 due to line breaker trip.							
z) Shyampur-Fatullah 132 kV Ckt-2 tripped at 18:57 due to bad weather and was switched on at 10:37(25-10-22)							
aa) Cumilla(N) 132/33 kV T-3 & T-4 transformer tripped at 19:40 and were switched on at 19:58.							
ab) Maniknagar-Matuaail 132 kV Ckt-2 tripped at 19:57 due to bad weather.							
ac) Bibiyana-Kaliakoir 400 kV Ckt-2 tripped at 22:02 from both end showing dist Z1 CN at both end and was switched on at 23:57.							
ad) Ashuganj-Kishoreganj 132 kV Ckt-2 tripped at 23:06 from both end showing dist BC-phase from both end.							
ae) Daudkandi-Cumilla(N) 132 kV Ckt-1,2 tripped at 22:21 due to tree fall in the line and were switched on at 04:09,04:15 respectively..							
af) Feni-Chowmuhoni 132 kV Ckt-1 tripped at 21:16 from both end showing dist Z-1, BC-phase at Feni end & SOTF at Chowmuhoni end							
ag) Chandpur-Kachua 132 kV Ckt-1 tripped at 21:35 from both end as a tree broken on this line and was switched on at 06:50(25-10-22).							
ah) Kallyanpur 132/33 kV T-2 transformer tripped at 22:02 showing Buchholtz relay and was switched on at 11:38(25-10-22).							
ai) Rampura-Bashundhara 132 kV Ckt-1,2 tripped at 01:13 from both end showing dist Z3 at Rampura end & dist Z-1 at Bashundhara end and were switched on at 01:27.				About 35 MW power interruption occurred under Bashundhara S/S area from 01:13 to 01:27.			
aj) Sylhet-Chatrak 132 kV Ckt-1 tripped at 02:34 from both end showing dist Z2,B-phase and was switched on at 02:44(25-10-22).							
ak) Tongi-Kabirpur 132 kV Ckt-2 tripped at 22:52 from Tongi end showing dist Z1,B-phase and was switched on at 23:04.							
al) Naogaon-Joypurhat 132 kV Ckt tripped at 23:04 from Naogaon end showing dist 3-phase and was switched on at 23:15.							
am) Siddhirganj-Matuaail 132 kV Ckt tripped at 23:40 and was switched on at 23:57.							
an) Ghorasal-Ashuganj(S) 230 kV Ckt-2 tripped at 21:24 from Ghorasal end and was switched on at 12:35(25-10-22).							
Sub Divisional Engineer		Executive Engineer		Superintendent Engineer			
Network Operation Division		Network Operation Division		Load Despatch Circle			