

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month October, 2022					Day : Friday				Date : 28.10.22				
Probable Maximum Demand : 11000 MW					Probable Maximum Generation : 11915 MW					Rule Curve = 108.50 ft.			
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 96.78 ft		Today = 96.60 ft						
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	27.10.22 (Yesterday)		28.10.22 (Today)		27.10.22 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :				
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation	Machines shut down (MW)			
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		Evacuation Problem		
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	110	180	180	180				
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1 x 126	365	365	0	0	0	0	365	Under maint.		
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	12	83	80	80				
5	Tong 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.		
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0		Contract Expired		
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	260	262	300	300				
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225	Gas Shortage		
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	398	402	400	400				
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage		
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0		STG Under maint.		
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	130	140	125	125	195	Gas Shortage		
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	45	30	55	55				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	66	83	74	92				
16	Narshingsi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	16	16	16				
17	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	47	49	51	53				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	30	30	33	33				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	32	41	41	49				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	16	88	88	88				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	64	110	16	110				
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	227	275	225	275				
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	95	117	80	134				
26	Keranigonj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	180	53	0	150				
27	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	90	50	0	50				
28	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	90	50	0	50				
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	17	17	17				
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55				
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	74	92	74	92				
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	162	35	162				
33	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	30	0	30	0				
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	54	54	54	54				
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	70	88	63	90				
36	Meghnaghat 100 MW(IEEL)	HFO (NENP)	12x8.9	100	100	67	78	70	94				
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0				
Dhaka Zone Total					6004	5847	2568	2917	2417	3116	630	845	
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	153	152	152	152			Unit 1 under rehabilitation	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0				
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	21	25	25	25				
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0				
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	26	44	30	44				
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	51	105	70	105				
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.	
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	151	151	150	150	74		STG Under maint.	
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	123	283	140	283				
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	50	38	50				
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	16	51	17	51				
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	24	23	23	23				
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0	22		Gas Shortage	
*	Malancha, Ctp EP2 (United)	Gas	5x8.73+3x9.34			2	9	20	40				
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	2	0	0	106		Fuel oil shortage	
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54				
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	70	105	61	105				
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	50	25	50				
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	22	55	22	55				
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107				
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0				
Chattogram Zone Total					2442	2382	894	1266	959	1294	308	404	
58	Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	5	5	5	5	40		Gas Shortage	
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	200	123	150	200	98		Gas Shortage	
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	230	160	0	0	200		Gas Shortage	
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	280	280	260	280	80		Gas Shortage	
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCCL)	1x284	284	284	0	75	270	270	209		Gas Shortage	
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	5	5	5	5	50		Gas Shortage	
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187		Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	0	0	0	0	51		Gas Shortage	
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	63	78	70	103				
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	37	40	44				
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0				
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	34	167	100	200				
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	19	19	19				
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11				
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	8	13	32	32				
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	43	8	43				
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	6	15	15	15	10		Gas Shortage	
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	39x1.4+40x1.515+15x1.058	200	200	0	50	0	100				
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	114	114	114				
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	0	0	0	0	113		Fuel Oil Shortage	
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35				
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	75	115	53	115				
**	Import (Tajura)	India		160	160	124	124	143	166				
Cumilla Zone Total					3193	3169	1114	1477	1338	1765	1172	0	
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	34	45	90	110	157		Gas Shortage	
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	18	18				
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	49	99	90	97				
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	58	89	45	88	111		Fuel oil shortage	
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
86	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	51	0	50	0				
87	Tangail 22 MW PP(PGL)	HFO (IPP)	4x6.7	22	22	12	12	12	12				
Mymensingh Zone Total					622	614	224	263	307	325	268	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	27.10.22 (Yesterday)		28.10.22 (Today)		27.10.22 (Yesterday)		Status of Machines under shut-down/ Maintenance			
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation		Description/ Remarks	Probable start-up date		
						Day	Evening	Day	Evening	MW	Machines shut down (MW)				
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	GT-1 Under maint.			
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42		48	GT-4 Under maint.			
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	11	11	11	11	40		Gas Shortage			
91	Kushiana 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0	109	54	STG Under maint.			
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	5	5	5						
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	20	32	32	32						
94	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.			
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	20	81	72	81						
96	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	185	185	190	190						
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	19	18	19	19						
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10						
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	8	8	8	17		Gas Shortage			
100	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	270	290	300						
101	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	408	400	400	400						
102	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400						
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work			
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	11	11	11	11	39		Gas Shortage			
105	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12'3.3-5'2	50	50	10	10	10	10	40		Gas Shortage			
Sylhet Zone Total						2522	2477	1469	1513	1530	1549	245	572		
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0						
107	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	165	175	200	200	235		Gas Shortage			
108	Fairdipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	39	0	39						
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	74	0	75						
110	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	0						
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	30	0	50						
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	56	56	75	55						
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0						
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	85	0	100	0						
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	16	32	0	32	83		Fuel oil shortage			
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	0	0	8	40		Fuel oil shortage			
	Rampal 1320 MW	Coal (BIFPCL)				0	0	0	0						
	Khulna 330 MW CAPP	Gas/HSD (BFPDB)				180	0	0	0						
**	Bheramara (HVDC)	India		1000	1000	900	902	924	924						
Khulna Zone Total						2388	2384	1402	1308	1299	1383	358	0		
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	0	16		110	Line Overload			
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	17	22	16	22						
119	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	0	64	87	87	130		Gas Shortage			
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	680	810	810	810						
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0		150	Line Overload			
122	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	221	222	170	220						
Barishal Zone Total						1958	1958	918	1118	1083	1155	130	260		
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage			
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage			
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	32	0	32						
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	50	0	100						
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	22	0	22		49	Under maint.			
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	87	0	86						
128	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	8	32	0	32						
129	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	34	34	34	42						
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	27	0	27						
131	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage			
132	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage			
133	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	127	128	150	150	92		Gas Shortage			
134	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	207	214	260	260	200		Gas Shortage			
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	0	0	20	22						
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	0	0	11	11	11		Gas Shortage			
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	8	8	8						
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6'18.55	113	113	113	113	113	113						
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	113	113	113	113						
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	3	0	6	0						
Raishahi Zone Total						2129	2129	613	860	715	1018	904	49		
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	82	81	80	82						
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling			
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0		274	Under maint.			
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	106	110	100	113						
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
146	Mejpara, Tulsia 9 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0						
147	Thakurgaon 115MW PP (Energygripa)	HFO (IPP)	6'20	115	115	112	115	70	115						
148	Lalmohaihat 30 MW Solar (Intraco)	Solar (IPP)	1'30	30	30	16	0	12	0						
Rangpur Zone Total						830	750	322	306	270	310	0	359		
Sub-total: Plants in operation						22088	21710	9524.0	11028	9918	11915	4015	2489		
(B) Plants under long term maintenance/ contract expired															
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0						
150	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0						
151	Bosilia 108MW PPI(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0						
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0						
153	Boqura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020			
154	Amirjura 30 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 1/10/2022			
Sub-Total: Plants under long term maintenance/ contract expired						424	0	0	0	0	0				
Gross Total						22512	21710	9524	11028	9918	11915	4015	2489		
(C) Actual data of 27.10.22 (Yesterday) Thursday :															
01.	Max. Demand at eve. peak (Generation end)	:	11028	MW, at =	19:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand at eve. peak (Sub-station end)	:	10633	MW, at =	19:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW		
03.	Highest Generation (Generation end)	:	11028	MW, at =	19:00 hrs	Dhaka	4245	4245	0	Mymensingh	831	831	0		
04.	Minimum Generation (Generation end)	:	7595	MW, at =	6:00 hrs	Chattogram	1148	1148	0	Sylhet	415	415	0		
05.	Day-peak Generation (Generation end)	:	9524	MW, at =	12:00 hrs	Khulna	1159	1159	0	Barishal	232	232	0		
06.	Evening-peak Generation (Generation end)	:	11028	MW, at =	19:00 hrs	Rajshahi	1089	1089	0	Rangpur	650	650	0		
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at =	19:00 hrs	Cumilla	863	863	0						
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7289	MW, at =	5:00 hrs										
09.	Generation shortfall at evening peak due to :	:				Total							10633	10633	0
	a) Gas/LF limitation	:	4015	MW		(a) Gas = 120754984 Taka							177793874	Taka	
	d) Coal supply Limitation	:	0	MW		(b) Oil = 809978605 Taka							Total =	1108527463	Taka
	b) Low water level in Kaptai lake	:	0	MW											
	c) Plants under shut down/ maintenance	:	2489	MW		Maximum Temperature in Dhaka was :							30.8° C		
10.	Total Energy (Generation + India Import)	:	221.78	MKWh		Export through East-West interconnections :									
	By Gas =	111.634	MKWh	By Oil =	61.535	At evening peak-hour :							9524	MW, at	19:00 hrs
	By Coal =	20.410	MKWh	By Hydro =	3.679	Maximum :							296	MW, at	7:00 hrs
	By Solar =	1.446	MKWh			Energy :							0	MKWh	
11.	Total Gas Supplied	:	849.49	MMCFD											
(D) Forecast of 28.10.22 (Today) Friday :															
01.	Maximum Demand	:	11000	MW (Generation end)		04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)				
02.	Maximum Generation	:	11915	MW (Generation end)		05.	Total Generation	:	221.22	MKWh					
03.	Reserve / Shortage	:	915	MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	:	29.6° C						