

**Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation
Tel: 9364667, 9551095

Month October, 2022				Day: Sunday				Date: 30.10.22					
Probable Maximum Demand: 12800 MW				Probable Maximum Generation: 11892 MW									
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 96.38 ft Today = 96.13 ft Rule Curve = 108.80 ft									
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	29.10.22 (Yesterday)		30.10.22 (Today)		29.10.22 (Yesterday) Gen. shortfall for:		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gas/Coal/Oil/Water Limitation	Machines shut down	Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	MW	(MW)			
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0			Line Overload	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180				
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	Under maint.	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	80	79	80	80				
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	Under maint.	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			Contract Expired	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	306	272	350	300				
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225		225	Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	405	416	400	400				
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0		210	Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0		335	Gas Shortage	
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	143	135	134	134		200	Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	40	55	55	55				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	58	92	74	92				
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	16	19	16	16				
17	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	32	34	51	53				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	30	33	33	33				
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	32	6	33	33				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	41	0	49				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	88	88	88				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	48	71	48	90				
23	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	211	276	225	275				
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	65	117	80	149				
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	22	0	150				
27	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	50	0	50				
28	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	50	0	50				
29	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	35	35	55				
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55				
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	10	89	74	92				
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	162	35	162				
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	33	0	30	0				
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	36	54	54	54				
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	72	90	63	90				
36	Meghnaghat 100 MW(IEEL)	HFO (NENP)	12x8.9	100	100	66	80	70	80				
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0				
Dhaka Zone Total				6004	5847	2280	2880	2485	3144	970	845		
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	154	152	152	152			Unit 1 under rehabilitation	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0				
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	17	17	17				
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	20	20	19	0	20	0					
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	40	44	30	44				
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	51	98	70	105				
45	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.	
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	151	152	150	150		73	STG Under maint.	
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	123	286	140	283				
48	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	25	50	38	50				
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	57	17	57				
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	14	21	21	21				
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0		22	Gas Shortage	
*	Malancha, Clq EPZ (United)	Gas	5x8.73+3x9.34			2	2	7	15				
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0		108	Fuel oil shortage	
53	Sikalbaha 54 MW PP(Jodac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54				
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	105	105	70	105				
55	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	25	50	25	50				
56	Juldah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	22	55	22	55				
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	88	107	88	107				
	Mirsharal 150 MW	HFO (BRPgen)	9x18.5			5	0	0	0				
Chattogram Zone Total				2442	2382	916	1250	926	1259	310	403		
58	Ashuganj TPP Unit- 5	Gas (APSCl)	1 x 150	150	134	0	0	0	0		134	Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCl)	14x3.968	50	45	50	51	50	50				
60	Ashuganj 225 MW CCPP	Gas (APSCl)	1x142+1*75	221	221	198	210	180	200				
61	Ashuganj 450 MW CCPP(South)	Gas (APSCl)	1x360	360	360	0	0	0	0		360	Under maint.	
62	Ashuganj 450 MW CCPP(North)	Gas (APSCl)	1x361	360	360	345	310	320	320				
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCl)	1x284	284	284	0	0	0	0		284	Gas Shortage	
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	50	30	50	50				
65	Ashuganj 195MW PP (APSCl-United)	Gas (IPP)	20*9.73+1*16	195	195	187	130	185	185		65	Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	0	0	0	0		51	Gas Shortage	
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	41	85	70	85				
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	47	0	47				
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163	Under maint.	
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	51	177	100	200				
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	18	19	19				
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	10	11	11				
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	17	33	33	33				
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	34	43	8	43				
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	21	15	18				
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+60x1.515+15x1.058	200	200	0	50	0	100				
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	114	114	114				
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	0	0	0	9		113	Fuel Oil Shortage	
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	9	20	35	35				
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	57	115	53	115				
**	Import (Tripura)	India		160	160	128	148	143	166				
Cumilla Zone Total				3193	3169	1223	1612	1386	1800	647	523		
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	33	50	90	110		152	Gas Shortage	
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	18	18	18				
83	Jamalpur 115 MW PP (Unitec)	HFO (IPP)	12x9.87	115	115	49	99	90	98				
84	Mymensingh 200 MW PP (Unitec)	HFO (IPP)	21x9.780	200	200	48	84	45	88		116	Fuel oil shortage	
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
86	Sutahali 50 MW Solar PP	Solar (IPP)	1x50	50	50	54	0	50	0				
87	Tangail 22 MW PP(RPCL)	HFO (IPP)	4x6.7	22	22	12	12	12	12				
Mymensingh Zone Total				622	614	217	263	307	326	268	0		

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	29.10.22 (Yesterday)		30.10.22 (Today)		29.10.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Oil/Water Limitation		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	MW	MW		
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	G1- Under maint.
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	43	43	43	43		47	G1- Under maint.
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	50	53	50	50			
91	Kushiara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0	109	54	STG Under maint.
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	11	11	11			
93	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	63	62	66	65			
94	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	25	81	0	81			
96	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	0	0	0	0			
97	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	18	19	19	19			
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10			
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	16	8	16	9		Gas Shortage
100	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	270	305	300			
101	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	416	410	400	400			
102	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	392	400	400	400			
103	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	25	27	11	11	23		Gas Shortage
105	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12'3.3x5'2	50	50	46	46	42	42			
Sylhet Zone Total												
106	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
107	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	190	170	200	225	240		Gas Shortage
108	Fariapur 50 MW Peaking PP	HFO (PDB)	8x6.98	50	50	0	42	0	39			
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	64	0	75			
110	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150+1x75	225	220	0	0	0	0			
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	50	0	50			
112	Rupsha 105 MW PP (Orion upsha)	HFO (IPP)	6x18.445	105	105	17	76	75	55			
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.445	105	105	0	0	0	0			
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	91	0	100	0			
115	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	0	32	0	32	83		Fuel oil shortage
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	0	0	8	40		Fuel oil shortage
	Rampal 1320 MW	Coal (BIFPCL)				0	0	0	0			
	Khulna 330 MW CAPP	Gas/HSD (BFPCL)				0	0	0	0			
**	Bheramara (HVDC)	India		1000	1000	904	897	925	925			
Khulna Zone Total												
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	0	16		110	Line Overload
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	13	17	16	22			
119	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	86	88	87	87	106		Gas Shortage
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	660	810	810	810			
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0		150	Line Overload
122	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	222	195	220			
Barishal Zone Total												
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	50	50	0	32	0	32			
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	20	0	100			
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	24	0	22		47	Under maint.
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	86	0	86			
128	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	0	32			
129	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	25	34	34	42			
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	35	0	35			
131	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage
132	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage
133	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	148	131	157	157	89		Gas Shortage
134	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	264	204	260	210			Gas Shortage
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	0	0	0	0	22		Gas Shortage
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	0	0	11	11	11		Gas Shortage
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	8	8			
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6'18.55	113	113	70	95	113	113			
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6'18.55	113	113	113	113	113	113			
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0			
Raishahi Zone Total												
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	77	80	80	82	933	47	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0		274	Under maint.
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	38	100	100	113			
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
146	Majpara, Tulsia 8 MW Solar PP (Simpa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0			
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6'20	115	115	10	115	70	115			
148	Almohitha 30 MW Solar (Intraco)	Solar (IPP)	1'30	30	30	35	0	12	0			
Rangpur Zone Total												
Sub-total: Plants in operation												
(B) Plants under long term maintenance/ contract expired												
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			
150	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
151	Bosilia 108MW PPI(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0			
153	Boqura 20 MW PP (Energyprima)	Gas (NENP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020
154	Amirua 30 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 1/10/2022
Sub-Total: Plants under long term maintenance/ contract expired												
Gross Total												
(C) Actual data of 29.10.22 (Yesterday) Saturday :												
01.	Max. Demand at eve. peak (Generation end)	: 11060 MW, at = 19:00 hrs										
02.	Max. Demand at eve. peak (Sub-station end)	: 10649 MW, at = 19:00 hrs										
03.	Highest Generation (Generation end)	: 11060 MW, at = 19:00 hrs										
04.	Minimum Generation (Generation end)	: 7120 MW, at = 5:00 hrs										
05.	Day-peak Generation (Generation end)	: 9040 MW, at = 12:00 hrs										
06.	Evening-peak Generation (Generation end)	: 11060 MW, at = 19:00 hrs										
07.	Evening Peak Load-shed (Sub-station end)	: 0 MW, at = 19:00 hrs										
08.	Minimum Generation Forecast up to 8:00 hrs.	: 7713 MW, at = 5:00 hrs										
09.	Generation shortfall at evening peak due to :											
a)	Gas/LF limitation	: 3738 MW										
d)	Coal supply Limitation	: 0 MW										
b)	Low water level in Kaptai lake	: 0 MW										
c)	Plants under shut down/ maintenance	: 3008 MW										
10.	Total Energy (Generation + India Import)	: 217.55 MKWh										
	By Gas = 115.656 MKWh	By Oil = 51.684 MKWh										
	By Coal = 21.767 MKWh	By Hydro = 3.662 MKWh										
	By Solar = 1.595 MKWh											
11.	Total Gas Supplied	: 884.80 MMCFD										
(D) Forecast of 30.10.22 (Today) Sunday :												
01.	Maximum Demand	: 12800 MW (Generation end)										
02.	Maximum Generation	: 11892 MW (Generation end)										
03.	Reserve / Shortage	: -908 MW (Generation end)										
04.	Maximum Load-shed	: 837 MW At evening peak (Sub-station end)										
05.	Total Generation	: 251.78 MKWh										
06.	Probable Max. Temperature in Dhaka :	: 31.5° C										
Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :												
Zone Demand MW Supply MW Load Shed MW Zone Demand MW Supply MW Load Shed MW												
Dhaka 4148 4148 0 Mymensingh 833 833 0												
Chattogram 1183 1183 0 Sylhet 449 449 0												
Khulna 1135 1135 0 Barishal 237 237 0												
Rajshahi 1071 1071 0 Rangpur 630 630 0												
Cumilla 964 964 0												
Total 10649 10649 0												
Fuel cost : (a) Gas = 125891675 Taka (c) Coal = 187053312 Taka												
(b) Oil = 687166211 Taka Total = 100011198 Taka												
Maximum Temperature in Dhaka was : 31.4° C												
Export through East-West interconnections :												
At evening peak-hour : 9040 MW, at 19:00 hrs												
Maximum : 168 MW, at 19:30 hrs												
Energy : 0 MKWh												

#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation