

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month November, 2022				Day : Wednesday				Date : 02.11.22				
Probable Maximum Demand : 12500 MW				Probable Maximum Generation : 12164 MW								
Water Level of Kaptai Lake at 06:00 AM				Today = 95.46 ft				Rule Curve = 108.90 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	01.11.22 (Yesterday)		02.11.22 (Today)		01.11.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Water Limitation MW		Machines shut down (MW)	
					Day	Evening	Day	Evening			Description/ Remarks	Probable start-up date
(A) Plants in operation:												
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work
2	a) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0			Line Overload
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	Under maint.
4	Ghorasahi 108MW PP (Regent)	Gas (IPP)	3x3.35	108	108	71	73	73	73			
5	Tong 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0			Contract Expired
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	286	247	250	250	113		Gas Shortage
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	200	200	200	250		Gas Shortage
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	410	400	400	400			
11	Siddhirganj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335		Gas Shortage
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	75	140	140	140	195		Gas Shortage
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	58	92	60	92			
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	16	16	16	16			
17	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	49	50	50	50			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	30	26	33	33			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	34	41	49	49			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	88	88	88			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	132	132	115	132			
23	Karnalaghat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	261	276	225	275			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	118	135	122	149			
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	213	155	150	150			
27	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	90	50	50	50			
28	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	83	50	50	50			
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	25	55			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	73	93	74	92			
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	162	35	162			
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	28	0	30	0			
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	15	17	54			
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	71	90	70	90			
36	Meghnaghat 100 MW(HEL)	HFO (NENP)	12x8.9	100	100	67	90	60	92			
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0			
Dhaka Zone Total			6004	5847	2885	3053	2702	3119	1208	740		
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	152	152	152	152			Unit 1 under rehabilitation
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	4	0	5	0				
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	25	25	25			
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	20	0				
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	12	40	44	44			
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	68	105	70	105			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	150	151	150	150		74	STG Under maint.
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	123	302	140	300			
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	50	25	50			
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	15	51	17	51			
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	24	22	22	22			
51	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0	22		Gas Shortage
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	7	5	10			
52	Chattogram 168 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0	108		Fuel oil shortage
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	36	36	54	54			
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	68	105	70	105			
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	50	25	50			
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	22	55	22	55			
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107			
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0			on test
Chattogram Zone Total			2442	2382	870	1258	953	1280	310	404		
58	Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	48	51	50	50			
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+175	221	221	200	188	180	200			
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	0	0	0	0	360		Under maint.
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	350	305	280	300			
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCCL)	1x284	284	284	0	0	0	0	284		Gas Shortage
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	25	25	15	25			
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+1'16	195	195	167	180	180	180			
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	0	0	0	0	51		Gas Shortage
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	58	78	70	85			
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	37	40	45	45			
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	45	50	50	50	57		ST Under maint.
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	51	180	100	180			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	22	22	22			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	10	10			
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	7	33	33	33			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	43	8	43			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	21	21	15	21			
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+60x1.915+15x1.098	200	200	125	100	100	100			
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	17	114	114	114			
78	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	0	0	0	9	113		Fuel Oil Shortage
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	35			
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	55	115	53	115			
**	Impoqet (Tripura)	India		160	160	138	160	143	166			
Cumilla Zone Total			3193	3169	1398	1732	1485	1783	582	417		
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	33	51	70	70	151		Gas Shortage
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	18	18			
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	49	98	90	100			
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	52	88	45	88	112		Fuel oil shortage
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
86	Sutahkhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	0	0	50	0			
87	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	12	12	12	12			
Mymensingh Zone Total			622	614	218	267	287	288	263	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	01.11.22 (Yesterday)		02.11.22 (Today)		01.11.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	GT-1 Under maint.	
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	43	43	43	43		47	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	0	0	0	0	51		Gas Shortage	
91	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0	109	54	STG Under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	10				
93	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	59	63	66	65				
94	Shajbazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	81	0	81				
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	145	145	145	145		86	ST Under maint.	
97	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	18	18	18	18				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	8	8	8	17		Gas Shortage	
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	290	300	290				
101	Bibiyan-II 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	404	403	400	400				
102	Bibiyan South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	388	400	400	400				
103	Shahjibazar 100 MW GTTP	Gas (NENP)	1x100	100	100	0	0	0	0		100	Under project work	
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	0	0	0	0	50		Gas Shortage	
105	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	0	0	0	0	50		Gas Shortage	
Sylhet Zone Total						2522	2477	1405	1491	1420	1500	277	657
106	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
107	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	170	175	190	190	235		Gas Shortage	
108	Fairpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	32	0	35				
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	65	0	65				
110	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	0				
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	50	0	50				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	56	94	60	94				
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0				
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	84	0	100	0				
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	49	0	32	66		Fuel oil shortage	
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	8	0	8	32		Fuel oil shortage	
	Rampal 1320 MW	Coal (BIFPCL)				0	0	0	0				
	Khulna 330 MW CCPP	Gas/HSD (BPD)				0	0	0	0				
**	Bheramara (H/DC)	India		1000	1000	912	920	940	940				
Khulna Zone Total						2388	2384	1222	1393	1290	1414	333	0
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	24	0	24		86	Line Overload	
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	17	23	16	22				
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	65	65	65	65	129		Gas Shortage	
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	850	950	810	950				
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0		150	Line Overload	
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	160	222	220	220				
Barishal Zone Total						1958	1958	1092	1284	1111	1281	129	236
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	32	0	32				
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	52	0	100				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	11	0	20	60		Under maint.	
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	87	0	86				
128	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	16	32	0	32				
129	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0	50		Fuel Oil Shortage	
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	25				
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	165	158	165	180	52		Gas Shortage	
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0	0	220		Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0		220	Under maint.	
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	202	206	200	250	208		Gas Shortage	
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	0	0	0	0	22		Gas Shortage	
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0	11		Gas Shortage	
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	8	8	8				
138	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6'18.55	113	113	57	113	113	113				
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	94	95	95				
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0				
Raishahi Zone Total						2129	2129	488	793	587	941	734	280
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	79	80	80	80				
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	174	250	250	100		Under maint.	
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	56	70	100	113				
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0				
147	Thakurgaon 119MW PP (Energygac)	HFO (IPP)	6'20	115	115	0	115	113	115				
148	Lalmohithai 30 MW Solar (Intraco)	Solar (IPP)	1'30	30	30	35	0	12	0				
Rangpur Zone Total						830	750	177	439	563	558	0	185
Sub-total: Plants in operation						22088	21710	9755.0	11710	10398	12164	3836	2919
(B) Plants under long term maintenance/ contract expired													
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
150	Katpolti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
151	Boalia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
153	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0				Contract Expired on 12/11/2020
154	Amirura 30 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0				Contract Expired on 11/01/2022
Sub-Total: Plants under long term maintenance/ contract expired						424	0	0	0	0	0		
Gross Total						22512	21710	9755	11710	10398	12164	3836	2919
(C) Actual data of 01.11.22 (Yesterday) Tuesday :													
01.	Max. Demand at eve. peak (Generation end)	:	12350	MW, at =	20:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	11866	MW, at =	20:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	11710	MW, at =	20:00 hrs	Dhaka	4619	4517	102	Mymensingh	944	876	68
04.	Minimum Generation (Generation end)	:	8587	MW, at =	8:00 hrs	Chattogram	1394	1394	0	Sylhet	460	431	29
05.	Day-peak Generation (Generation end)	:	9755	MW, at =	12:00 hrs	Khulna	1284	1163	121	Barishal	320	320	0
06.	Evening-peak Generation (Generation end)	:	11710	MW, at =	20:00 hrs	Rajshahi	1072	987	85	Rangpur	667	589	78
07.	Evening Peak Load-shed (Sub-station end)	:	590	MW, at =	20:00 hrs	Cumilla	1106	999	107				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	8712	MW, at =	5:00 hrs					Total	11866	11276	590
09.	Generation shortfall at evening peak due to :	:				13.	Fuel cost :	(a) Gas = 124405349 Taka (b) Oil = 976317969 Taka		(c) Coal = 223408451 Taka Total = 1324131769 Taka			
	a) Gas/LF limitation	:	3836	MW		14.	Maximum Temperature in Dhaka was :	33.3° C					
	d) Coal supply Limitation	:	0	MW		15.	Export through East-West interconnections :						
	b) Low water level in Kaptai lake	:	0	MW			At evening peak-hour	:	9755	MW, at	20:00 hrs		
	c) Plants under shut down/ maintenance	:	2919	MW			Maximum	:	70	MW, at	18:00 hrs		
10.	Total Energy (Generation + India Import)	:	238.66	MKWh			Energy	:	0	MKWh			
	By Gas = 113.479 MKWH			By Oil = 69.834 MKWh									
	By Coal = 26.010 MKWH			By Hydro = 3.677 MKWh									
	By Solar= 1.514 MKWH												
11.	Total Gas Supplied	:	877.97	MMCFD									
(D) Forecast of 02.11.22 (Today) Wednesday :													
01.	Maximum Demand	:	12500	MW	(Generation end)	04.	Maximum Load-shed	:	310	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	12164	MW	(Generation end)	05.	Total Generation	:	254.76	MKWh			
03.	Reserve / Shortage	:	-336	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	30.9° C				

#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helatur Rahman)
Deputy Secretary, Generation