

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 3-Nov-22

Page -2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CCPP-Unit-3 (GT	PDB	1'260	260	0	0	Under maint.
2	Ghorasal Repowered CCPP Unit-4	PDB	1'210	180	0	0	Machine problem
3	Ghorasal 365 MW CCPP Unit-7	PDB	1'243+1'122	365	0	0	Under maint.
	Ghorashal 78.5 MW PP(MAX)	QRPP	2'40	0	0	0	
4	Ghorashal 108MW PP (Regent)	IPP	34'3.35	108	73	1689450	Engine problem
5	Haripur GTPP	SBU, PDB	2'32	20	0	0	Under maint.
6	Haripur 412 MW CCPP	EGCB	1'273+1'139	412	362	8984580	Gas shortage
7	Haripur 360MW CCPP(HPL)	IPP	1'235+1'125	360	202	5116000	Gas shortage
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2'150+1'150	450	170	4176500	Gas shortage
9	Meghnaghat 100 MW(IEI)	NENP	12'8.9	100	84	1458240	Engine problem
10	Meghnaghat CCPP(Summit)	IPP	2'110+1'110	335	135	3286575	Gas shortage
11	Madanganj 102 PP(Summit)	NENP	6'17	0	0	0	Under maint.
12	Madanganj-55 MW PP(Summit)	IPP	3'17.08+1'11.3	55	55	1283012	
13	Keraniganj 100 MW PP (Powerpac)	QRPP	8'13.45	0	0	0	Contract Expired
14	Narsingdi 22 MW PP (Doreen)	SIPP, REB	8'2.90	22	19	423252	Engine problem
15	210 MW Siddhirgonj TPP	PDB	1'210	115	0	0	Under maint.
16	Siddhirgonj 2'120 MW GTTP	EGCB	2'105	210	0	0	Gas shortage
17	Siddhirgonj 100 PP(Dutch Bangla)	NENP	12'8.9	100	88	1622400	Engine problem
18	Siddhirgonj 335 MW CCPP	EGCB	1'217+118	335	0	0	Gas shortage
19	Gagnagar 108 MW PP (Digital Power)	IPP	12'8.924	102	92	1571184	Engine problem
20	Katpotti 52 MW PP (Sirsha)	IPP	7'7.9	0	0	0	Fuel shortage
21	Kamalaghat 54 MW PP(Banco Energy)	IPP	3'18	54	54	657000	
22	Kodda 150MW PP	BPDB-RPCL	9'17.08	149	132	2986560	Engine problem
23	Manikganj 55 MW PP (Northern)	IPP	3'19.3	55	55	880508	
24	Nababganj 55 MW PP (Southern power)	IPP	3'19.3	55	55	905789	
25	Bosila 108MW PP(CLC)	IPP	12'8.775+1'3.5	0	0	0	
26	Summit Power (Madhabdi+Ashulia)	SIPP, REB	3'3.67+4'8.73	80	50	1174260	Engine problem
27	Meena 33 MW PP(Summit)	SIPP, REB	4'8.73	33	33	627900	
28	Ruganaj 33 MW PP(Summit)	SIPP, REB	4'8.73	22	22	671300	Engine problem
29	Gazipur 52 MW PP	RPCL	6'8.9	52	49	1094880	Engine problem
30	Tongi 80 MW GTTP	PDB	1' 105	105	0	0	Under maint.
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18'17.076	300	258	5901379	Engine problem
32	Keraniganj 300 MW PP (APR)	IPP	256'1.4	300	22	728223	Fuel conservation
33	Bramhanagar 100 MW PP (Aggreko)	IPP	114'9.959	100	40	498545	Fuel conservation
34	Aurahati 100MW PP (Aggreko)	IPP	0.85'23+0.95'91	100	25	432744	Fuel conservation
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	8'18.45+8.97	149	149	3428496	
36	Gazipur 100 MW PP	RPCL	6'17.5	105	88	1816500	Engine problem
37	Meghnaghat 104 MW PP (OPCL)	IPP	18.5'6	104	92	1672320	Fuel shortage
38	Manikgonj 162MW PP(MPGL)	IPP	9'18	162	162	1922400	
39	Spectro Solar Plant Ltd.	IPP	35	35	0	167143	
40	Kanchan Purbachal Power Generation Ltd.	IPP	18.4'3	55	17	431640	Fuel shortage
Dhaka area Total				5847	2763	60051534	
41	Chattogram TPP-1	PDB	1'210	180	0	0	Machine problem
42	Chattogram TPP-2	PDB	1'210	180	0	0	Gas shortage
43	Racozan 25 MW PP	RPCL	3'8.9	25	25	618656	
43	Teknaf 20MW PP (Solaritech)	IPP	0	20	0	128250	
44	Palenga 50MW PP (Baraka)	IPP	8'6.98	50	44	721920	Engine problem
45	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2'40+3'50	230	154	3650636	Low water level
46	Sikalbaha 225MW	PDB	1'150+1'175	225	151	3579381	ST Under maint.
47	Sikalbaha Peaking GT	PDB	1'150	150	0	0	Under maint.
48	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	6'17.5	105	105	1788981	
49	Hathazari 100 MW peaking PP	PDB	11'8.9	98	22	531408	Fuel shortage
50	Dohazari -Kalash 100 MW Peaking	PDB	6'17	102	49	605648	Fuel shortage
51	Juldah 100 MW Unit-1 (Accorn)	NENP	8'13.45	100	46	684960	Fuel shortage
52	Juldah 100 MW PP Unit-3 (Accorn)	IPP	8'13.5	100	50	744000	Fuel shortage
53	Barabkundia 22 MW PP (Regent)	SIPP, PDB	8'2.90	22	0	0	Engine problem
54	Malancha, Ctr. EPZ Unit-2	IPP	5'8.73+9.34	0	2	342720	
54	Chattogram 108 MW PP (ECPV)	IPP	16'7	108	0	0	Fuel shortage
55	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	23039	
56	Anwara 300 MW PP (United)	IPP	17'17+24	300	283	3108764	Engine problem
57	Jodiac Power	IPP	3'18.55+1'3.6	54	36	912476	Engine problem
58	Kanapathuli Power Ltd.	IPP	18.415'6+8.5	110	110	1800683	
59	Juldah unit-2 (Accorn)	IPP	8'13.6	100	50	747840	Engine problem
60	Anilima Energy Ltd.	IPP	8'21.2	116	107	2343491	Engine problem
	Minsharai 150 MW	BPDB-RPCL	18.5'9	0	0	5018	On test.
Chattogram area Total				2382	1234	22335871	
61	Ashuganj TPP Unit- 3	APSCL	1'150	0	0	0	Contract Expired
	Ashuganj TPP Unit- 4	APSCL	1'150	0	0	0	Contract Expired
	Ashuganj TPP Unit- 5	APSCL	1'150	134	0	0	Gas shortage
62	Ashuganj 225 MW CCPP	APSCL	1'142+1'175	221	179	4438000	Gas shortage
63	Ashuganj 450 MW CCPP(North)	APSCL	1'360	360	280	7392800	Gas shortage
64	Ashuganj 450 MW CCPP(South)	APSCL	1'360	360	0	0	Gas shortage
	Ashuganj 420 MW CCPP(East)	APSCL	284'1+136'1	284	0	0	On test.
65	Ashuganj 50 MW PP	APSCL	14'3.968	45	51	1147824	
66	Ashuganj 55 MW PP (Precision)	QRPP	15'4	55	31	896160	Gas shortage
67	Ashuganj 195MW PP (APSCL-United)	IPP	20'9.73+1'16	195	195	4666909	
68	Ashuganj 51 MW PP (Midland)	IPP	6'9.34	51	0	0	Gas shortage
69	Ashuganj 150MW PP (Midland)	IPP	23'7.015	150	92	1727927	Fuel shortage
70	Titas 50 MW Peaking PP	PDB	6'8.92	52	45	591728	Engine problem
71	Chandpur 150 MW CCPP	PDB	1'106+1'57	163	50	1179010	Machine problem
72	Chandpur 200MW (Desh energy)	IPP	12'18.4	200	146	1535040	Engine problem
73	Feni 22MW PP (Doreen)	SIPP, PDB	8'2.90	22	0	255636	Engine problem
74	Feni 11 MW PP (Doreen)	SIPP, REB	4'2.90	11	10	249480	
**	Import (Tripura)	Imported power	0	160	140	3100800	
75	Jangalia 33MW PP (Summit)	SIPP, PDB	4'8.73	33	16	517600	Engine problem
76	Jangalia 52 MW PP (Lakshani)	IPP	8'9.92	52	43	499531	Engine problem
77	Qumilla 25 MW PP (Summit)	SIPP, REB	3'3.67+2'6.97	25	21	463240	Engine problem
78	Daudkandi 200 MW PP (B.Trac)	IPP	154'1.4	200	80	492864	Fuel conservation
79	Feni Lanka Power	IPP	7'18.415+1'9.78	114	114	790020	
80	Chowmuhani 113 MW	IPP	12'9.78+2'3.1	113	0	26040	Fuel shortage
81	Bhairab 54.5 MW	IPP	3'18.2	54	35	528120	Fuel shortage
82	Chandpur 115 (Doreen)	IPP	4'18.5+2'22.5	115	115	1707840	
Cumilla Area Total				3169	1643	32176569	
83	RPCL 210MW CCPP	IPP	4'35+1'70	202	44	1571520	Gas shortage
84	Tangail 22 MW PP (Doreen)	SIPP, PDB	8'2.90	22	15	368280	Engine problem
85	Jamalpur 95 MW PP(Powerpac)	IPP	12'8.924	0	0	0	Under maint.
86	Sarishabari 3 MW Solar Plant	IPP	1'3	3	0	11000	
87	Mymensingh 200 MW PP (United)	IPP	9'78'21	200	87	1399200	Fuel shortage
88	Jamalpur 115 MW PP (United)	IPP	9'78'12	115	99	1436800	Engine problem
89	Sutiakhali 50 MW Solar PP	IPP	50	50	0	267780	
90	Tangail Pali Power Gen 22 MW	IPP	4'6.7	22	12	291120	Engine problem
Mymensingh Area Total				614	257	5347700	
91	Fenchuganj CCPP Phase-1	PDB	2'32+1'33	70	30	717000	Machine problem
92	Fenchuganj CCPP Phase-2	PDB	2'35+1'35	90	42	963480	Machine problem
93	Kushiara 163 MW CCPP (KP)	IPP	1'109+1'54	163	0	0	Gas shortage
94	Shajibazar 330 MW CCPP	PDB	3'110	330	0	0	Under maint.
95	Fenchuganj 51 MW PP (Barakattullah)	RPP	19'2.90	51	0	0	Gas shortage
	Fenchuganj 44MW (Energyprima)	NENP	12'3.3+5'2	50	0	0	Gas shortage
	Hobiganj 11MW PP Confidence-E	SIPP, REB	4'2.90	11	0	0	Gas shortage
97	Shajibazar GTTP Unit- 3 & 9	PDB	2'35	86	69	1436352	Gas shortage
98	Shajibazar 86MW PP (Shajibazar)	RPP	32'2.90	86	81	679680	
99	Shajibazar 100 MW GTTP	PDB	1'100	100	0	0	Under maint.
100	Sylhet 225 MW CCPP	PDB	1'142+1'89	231	145	3412110	ST Under maint.
101	Sylhet 20 MW GTTP	PDB	1'20	20	18	425000	
102	Sylhet 50MW PP (EPL)	NENP	2'72	50	0	0	Gas shortage
102	Shahjahanulla 25 MW PP	SIPP, REB	3'9.34	25	8	47040	Gas shortage
103	Bibiana-II 341 MW CCPP (Summit)	IPP	1'222+1'119	341	270	7046500	FGMO
104	Bibiyana-III 400 MW CCPP	PDB	400 MW	400	407	9587000	
105	Sylhet 10MW PP (Desh)	RPP	6'1.95	10	10	235440	
106	Bibiyana South 400 MW	PDB	400 MW	383	392	9204400	
Sylhet Area Total				2477	1472	33754002	
107	Bheramara GTTP Unit-3	PDB	1'20	16	0	0	Fuel shortage
**	Bheramara (HVDC)	Imported power	2'500	1000	925	21103272	
108	Khulna 115 PP MW (KPCL-2)	NENP	7'17	115	49	403200	Fuel shortage
109	Faridpur 50 MW Peaking PP	PDB	8'6.89	54	43	126720	Engine problem
110	Khulna 225 MW CCPP	NWPGCL	1'150+1'175	230	0	0	Fuel shortage
111	Gopaldang 100 MW Peaking PP	PDB	16'8.98	109	72	299776	Fuel shortage
112	Bheramara 410 MW CCPP	NWPGCL	1'278+1'132	410	190	4934016	Gas shortage
	Noapara 40 MW PP (Khanjahan Ali)	NENP	5'8.5	40	8	39375	Fuel shortage
113	Noapara 100 MW PP (Bangla Trac)	IPP	70'1.4	100	50	89280	Fuel conservation
114	Rupsha 105 MW PP (Orion rupsha)	IPP	6'18.445	105	94	1332000	Engine problem
115	Madhumati 105 MW PP	NWPGCL	6'18	105	0	0	Fuel shortage
116	Mongia Orion 100 MW Solar PP	IPP	100	100	0	384480	
	Khulna 330 MW CCPP (DIL)	BPDB	1'220+1'110	0	0	0	On test.
	Rampal 1320 MW (BIFPCL)	NTPC&BPDB					