

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month November, 2022		Day : Friday				Date : 04.11.22					
Probable Maximum Demand :		11000 MW				Probable Maximum Generation : 12211 MW					
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 95.36 ft				Today = 95.12 ft					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	03.11.22 (Yesterday)		04.11.22 (Today)		03.11.22 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)	
(A) Plants in operation:											
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work
2	a) Ghorasal Repowered CAPP Unit-4 b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	180	0	0	0	0		Line Overload
3	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	67	73	73	73		
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		Contract Expired
7	Haripur 360MW CAPP(HPL)	Gas (IPP)	1x235+1x125	360	360	219	202	230	230	158	Gas Shortage
8	Meghnaghat 450 MW CAPP(MPL)	Gas (IPP)	2x140+1x170	450	450	180	170	190	190	280	Gas Shortage
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Haripur 412 MW CAPP	Gas (EGCB)	1x273+1x139	412	412	380	362	370	370		
11	Siddhirganj 2120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage
12	Siddhirganj 335 MW CAPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	Gas Shortage
13	Meghnaghat CAPP(Summit)	Gas (IPP)	2x110+1x110	335	335	135	135	135	135	200	Gas Shortage
14	Madanganj 55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	40	55	55	55		
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.324	102	102	58	92	60	92		
16	Narshingdi 22 MW PP (Doreen)	Gas (SIIP, REB)	8x2.90	22	22	19	19	16	16		
17	Summit Power,(Madhabdi-Ashulia)	Gas (SIIP, REB)	6x3.67+7x6.73	80	80	49	50	50	50		
18	Maona 33 MW PP(Summit)	Gas (SIIP, REB)	4x8.73	33	33	33	33	33	33		
19	Rugganj 33 MW PP(Summit)	Gas (SIIP, REB)	4x8.73	33	33	24	22	33	33		
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	49	49	49	49		
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	70	88	70	88		
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	106	132	115	132		
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54		
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	255	258	240	280		
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	149	95	149		
26	Kerangon 300 MW PP (APR)	HSD (IPP)	25x12.4	300	300	173	22	150	150		
27	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	90	40	50	50		
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	76	25	50	50		
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	35	55		
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55		
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	74	92	74	92		
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	162	35	162		
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	17	0	30	0		
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17		
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	70	88	70	90		
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	59	84	70	92		
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0		
Dhaka Zone Total				6004	5847	2711	2763	2627	3022	1288	740
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	152	154	154	154		Unit 1 under rehabilitation
39	a) Chattogram TPP-1 b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0	180	Under maint.
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25		
42	Teknaf 20MW PP (Solarsat)	Solar (IPP)	1x20	20	20	19	0	20	0		
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	25	44	24	44		
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	51	105	70	105		
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
46	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	151	151	150	150	74	STG Under maint.
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	122	283	125	300		
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	50	25	50		
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	16	49	17	51		
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	23	22	22	22		
51	Barabkunda 22 MW PP (Regent)	Gas (SIIP, PDB)	8x2.90	22	22	0	0	0	0	22	Gas Shortage
52	Malancha, Cig EPZ (United)	Gas	5x8.73+3x9.34			2	2	30	30		
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0	108	Fuel oil shortage
54	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	36	36	36	54		
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	71	110	70	105		
56	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	50	25	50		
57	Juldah 100 MW Unit-1 (Acom)	HFO (ORPP)	8x13.45	100	100	33	46	22	55		
58	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	90	107	107	107		
59	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0		on test
Chattogram Zone Total				2442	2382	870	1234	927	1302	310	404
60	Ashuganj TPP Unit-5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage
61	Ashuganj 50 MW PP	Gas (APSCL)	14x3.969	53	45	42	51	45	45		
62	Ashuganj 225 MW CAPP	Gas (APSCL)	1x142+1x75	221	221	207	179	175	190		
63	Ashuganj 450 MW CAPP(South)	Gas (APSCL)	1x360	360	360	0	0	0	0	360	Under maint.
64	Ashuganj 450 MW CAPP(North)	Gas (APSCL)	1x361	360	360	280	280	300	300		
65	Ashuganj 420 MW CAPP(East) GT	Gas (APSCL)	1x284	284	284	0	0	0	0	284	Gas Shortage
66	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	5	31	50	50		
67	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	185	195	160	160		
68	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	0	0	0	0	51	Gas Shortage
69	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	69	92	64	100		
70	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	29	45	32	32		
71	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	50	50	50	50	57	ST Under maint.
72	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	51	146	51	180		
73	Feni 22MW PP (Doreen)	Gas (SIIP, PDB)	8x2.90	22	22	21	0	22	22		
74	Feni 11 MW PP (Doreen)	Gas (SIIP, REB)	4x2.90	11	11	10	10	10	10		
75	Jangalia 33MW PP (Summit)	Gas (SIIP, PDB)	4x8.73	33	33	8	16	33	33		
76	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	43	8	43		
77	Cumilla 25 MW PP (Summit)	Gas (SIIP, REB)	3x3.67+2x6.97	25	25	19	21	15	21		
78	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+40x1.515+15x1.054	200	200	100	80	100	100		
79	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	114	17	114		
80	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	0	0	0	9	113	Fuel Oil Shortage
81	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	35	17	35		
82	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	53	115	53	115		
83	Impoprt (Tirupura)	India		160	160	136	140	143	166		
Cumilla Zone Total				3193	3169	1290	1643	1325	1775	582	417
84	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	34	44	34	100	158	Gas Shortage
85	Tangail 22 MW PP (Doreen)	Gas (SIIP, PDB)	8x2.90	22	22	15	15	18	18		
86	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	49	99	50	90		
87	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	48	87	48	98	113	Fuel oil shortage
88	Saishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0		
89	Sutiekhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	42	0	50	0		
90	Tangail 22 MW PP(PGCL)	HFO (IPP)	4x8.7	22	22	12	12	12	12		
Mymensingh Zone Total				622	614	201	257	214	318	271	0

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	03.11.22 (Yesterday)		04.11.22 (Today)		03.11.22 (Yesterday)		Status of Machines under shut-down/ Maintenance			
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date		
						Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)				
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30			40	GT-1 Under maint.		
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	43	42	43	43			48	GT-4 Under maint.		
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	0	0	0	0						
91	Kushara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0	109	54		STG Under maint.		
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0						
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	62	69	66	65						
94	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0			330	Under maint.		
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	3x2.90	86	86	0	81	0	81						
96	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	145	145	145	145			86	ST Under maint.		
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18						
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10						
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	8	0	8	17			Gas Shortage		
100	Bibiya-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	270	300	300						
101	Bibiya-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	410	407	400	400						
102	Bibiya South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	400	392	400	400						
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			100	Under project work		
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	0	0	0	0	50			Gas Shortage		
105	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	0	0	0	0	50			Gas Shortage		
Sylhet Zone Total				2522	2477	1407	1472	1412	1500	226	658				
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0						
107	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	195	190	190	190	220			Gas Shortage		
108	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	43	0	35						
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	72	0	65						
110	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	0						
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	50	0	50						
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	58	94	60	94						
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0						
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	89	0	100	0						
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	32	49	0	32	66			Fuel oil shortage		
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	8	0	8	32			Fuel oil shortage		
117	Rampal 1320 MW	Coal (BIFPCL)				0	0	0	0						
118	Khulna 330 MW CAPP	Gas/HSD (PDB)				0	0	0	0						
**	Bheramara (HVDC) India			1000	1000	925	925	935	935						
Khulna Zone Total				2388	2384	1299	1431	1285	1409	318	0				
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	0	16			110	Line Overload		
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	17	18	16	22						
119	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	67	68	65	65	126			Gas Shortage		
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	670	820	850	950						
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0			150	Line Overload		
122	Barisal Electric 307 MW	Coal (IPP)				0	0	0	0						
122	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	215	220	220						
Barishal Zone Total				1958	1958	974	1121	1151	1273	126	260				
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71			Gas Shortage		
123	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100			Gas Shortage		
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	32	0	32						
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	80	0	100						
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	11	0	22			60	Under maint.		
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	86	0	86						
128	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	5	32	0	32						
129	Katakali 50 MW PP (Northern)	HFO (ORPP)	6x8.9	50	50	0	25	0	42	25			Fuel Oil Shortage		
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	35	0	34						
131	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	171	170	160	160						
132	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220			Gas Shortage		
133	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0			220	Under maint.		
134	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	270	243	270	270				Gas Shortage		
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	0	5	20	20	17			Gas Shortage		
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	0	11	5	5	0			Gas Shortage		
137	Natore 52 MW PP (Rajlanika)	HFO (IPP)	6x8.92	52	52	0	21	8	43						
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6'18.55	113	113	95	113	95	113						
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	94	35	95						
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	3	0	6	0						
Raishahi Zone Total				2129	2129	579	958	599	1054	433	280				
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	82	75	80	80						
141	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0			85	Under Overhauling		
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	250	250	250				Under maint.		
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	50	71	55	113						
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
146	Majpara, Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0						
147	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6'20	115	115	51	114	113	115						
148	Lalmonirhat 30 MW Solar (Intraco)	Solar (IPP)	1'30	30	30	32	0	12	0						
Rangpur Zone Total				830	750	471	510	518	558	0	85				
Sub-total: Plants in operation				22088	21710	9802.0	11389	10058	12211	3554	2844				
(B) Plants under long term maintenance/ contract expired															
149	Jamalpur 95 MW PP(Powertac)	HFO (IPP)	12x8.924	95	0	0	0	0	0						
150	Kaipoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0						
151	Bosha 100MW PP(PCL)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0						
152	Kerangonj 100 MW PP (Powertac)	HFO (ORPP)	8x13.45	100	0	0	0	0	0						
153	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0				Contract Expired on 12/11/2020		
154	Amhura 30 MW PP(Sinha)	HFO (ORPP)	7x7.79	50	0	0	0	0	0				Contract Expired on 11/01/2022		
Sub-Total: Plants under long term maintenance/ contract expired				424	0	0	0	0	0	0	0	0	0		
Gross Total				22512	21710	9802	11389	10058	12211	3554	2844				
(C) Actual data of 03.11.22 (Yesterday) Thursday :															
01.	Max. Demand at eve. peak (Generation end)	:	11389	MW,	at =	19:00	hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	10937	MW,	at =	19:00	hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	11389	MW,	at =	19:00	hrs	Dhaka	4305	4305	0	Mymensingh	830	830	0
04.	Minimum Generation (Generation end)	:	8666	MW,	at =	6:00	hrs	Chattogram	1376	1376	0	Sylhet	444	444	0
05.	Day-peak Generation (Generation end)	:	9802	MW,	at =	12:00	hrs	Khulna	1091	1091	0	Barishal	267	267	0
06.	Evening-peak Generation (Generation end)	:	11389	MW,	at =	19:00	hrs	Rajshahi	1014	1014	0	Rangpur	609	609	0
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW,	at =	19:00	hrs	Cumilla	1002	1002	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7698	MW,	at =	5:00	hrs					Total	10937	10937	0
09.	Generation shortfall at evening peak due to :	:										(c) Coal =	21584835	Taka	
a)	Gas/LF limitation	:	3554	MW								(b) Oil =	888514596	Taka	
d)	Coal supply Limitation	:	0	MW								Total =	1230005644	Taka	
b)	Low water level in Kaptai lake	:	0	MW											
c)	Plants under shut down/ maintenance	:	2844	MW											