

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month November, 2022					Day : Saturday		Date : 05.11.22					
Probable Maximum Demand : 11800 MW					Probable Maximum Generation : 12166 MW							
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 95.12 ft		Today = 94.88 ft		Rule Curve = 108.60 ft			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	04.11.22 (Yesterday)		05.11.22 (Today)		04.11.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		Description/ Remarks
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		Line Overload	
3	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
4	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.	
5	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	73	73	73	73			
6	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage	
7	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		Contract Expired	
8	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	220	227	230	230	133	Gas Shortage	
9	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	180	175	180	180	275	Gas Shortage	
10	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
11	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	370	361	370	370			
12	Siddhirganj 2120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
13	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	Gas Shortage	
14	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	138	120	135	135	215	Gas Shortage	
15	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	40	55	55	55			
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	7	92	60	92			
17	Narshingdi 22 MW PP (Doreen)	Gas (SIIPP, REB)	8x2.90	22	22	8	22	22	22			
18	Summit Power(Madhabdi-Ashulia)	Gas (SIIPP, REB)	6x3.67+7x6.73	80	80	49	48	50	50			
19	Maona 33 MW PP(Summit)	Gas (SIIPP, REB)	4x8.73	33	33	33	33	33	33			
20	Rupganj 33 MW PP(Summit)	Gas (SIIPP, REB)	4x8.73	33	33	29	29	33	33			
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	41	24	49	49			
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	70	88	70	88			
23	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	64	64	115	132			
24	Kamalaghat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54			
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	240	260	240	280			
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	97	135	95	149			
27	Karagang 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	150			
28	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	50			
29	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	50			
30	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	0	35	55			
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55			
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	74	92	74	92			
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	162	35	162			
34	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	32	0	30	0			
35	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17			
36	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	70	77	70	70			
37	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	47	60	70	92			
38	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0			
Dhaka Zone Total					6004	5847	2201	2503	2373	2998	1273	740
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	152	154	154	154		Unit 1 under rehabilitation	
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
41	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
42	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	4	0	5	0	0			
43	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	21	8	25	25			
44	Teknaf 20MW PP (Solarsat)	Solar (IPP)	1x20	20	20	18	0	20	0			
45	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	22	39	24	44			
46	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	51	105	70	105			
47	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
48	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	150	111	150	150	114	STG Under maint.	
49	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	124	245	125	300			
50	Julda 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	50	25	50			
51	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	51	17	51			
52	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	23	22	22			
53	Barabkunda 22 MW PP (Regent)	Gas (SIIPP, PDB)	8x2.90	22	22	0	0	0	0	22	Gas Shortage	
54	* Malancha, Cig EPZ (United)	Gas	5x8.73+3x9.34			27	29	7	15			
55	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0	108	Fuel oil shortage	
56	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	36	36	36	54			
57	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	72	91	70	105			
58	Julda unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	50	25	50			
59	Julda 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	22	76	22	75			
60	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	90	107	107	107			
61	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0		on test	
Chattogram Zone Total					2442	2382	856	1175	904	1307	310	444
62	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage	
63	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	47	51	45	51			
64	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1x75	221	221	204	178	175	190			
65	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	0	0	0	0	360	Under maint.	
66	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	330	280	280	300			
67	Ashuganj 420 MW CCPP(East) GT	Gas (APSCL)	1x284	284	284	0	0	0	0	284	Gas Shortage	
68	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	30	30	30	30			
69	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	160	160	160	160			
70	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	0	0	0	0	51	Gas Shortage	
71	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	45	83	64	100			
72	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	32	32			
73	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	50	49	50	50	57	ST Under maint.	
74	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	51	76	51	180			
75	Feni 22MW PP (Doreen)	Gas (SIIPP, PDB)	8x2.90	22	22	0	0	0	0			
76	Feni 11 MW PP (Doreen)	Gas (SIIPP, REB)	4x2.90	11	11	10	10	10	10			
77	Jangalia 33MW PP (Summit)	Gas (SIIPP, PDB)	4x8.73	33	33	7	25	33	33			
78	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	43	8	43			
79	Cumilla 25 MW PP (Summit)	Gas (SIIPP, REB)	3x3.67+2x6.97	25	25	15	20	15	21			
80	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+40x1.515+15x1.056	200	200	0	0	0	100			
81	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	96	17	114			
82	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	0	0	0	9	113	Fuel Oil Shortage	
83	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	35			
84	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	53	115	53	115			
85	** Impoport (Tripura)	India		160	160	94	114	143	166			
Cumilla Zone Total					3193	3169	1138	1347	1183	1739	582	417
86	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	34	50	34	100	152	Gas Shortage	
87	Tangail 22 MW PP (Doreen)	Gas (SIIPP, PDB)	8x2.90	22	22	15	15	18	18			
88	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	48	99	50	90			
89	Myensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	46	88	48	98	112	Fuel oil shortage	
90	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
91	Sultekhail 50 MW Solar PP	Solar (IPP)	1x50	50	50	49	0	50	0			
92	Tangail 22 MW PP(PGCL)	HFO (IPP)	4x6.7	22	22	0	6	12	12			
Myensingh Zone Total					622	614	194	258	214	318	264	0

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	04.11.22 (Yesterday)		05.11.22 (Today)		04.11.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	GT-1 Under maint.	
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	43	43	43	43		47	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	5	6	6	6				
91	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0	109	54	STG Under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	62	69	66	65				
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 60MW PP (Shahjibazar)	Gas (RPP)	3x2.90	86	86	0	81	0	81				
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	145	90	90	145		141	ST Under maint.	
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	19	19				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	0	0	0	25		Gas Shortage	
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	250	300	300				
101	Bibiyan-II 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	410	365	400	400				
102	Bibiyan South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	394	350	400	400				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	11	11	11	11	39		Gas Shortage	
105	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	5	5	6	6	45		Gas Shortage	
Sylhet Zone Total						2522	2477	1425	1310	1381	1516	218	712
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
107	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	190	190	190	190	220		Gas Shortage	
108	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	2	0	35				
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	78	0	65				
110	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	0				
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	0	50				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	94	60	94				
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0				
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	78	0	100	0				
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	49	0	32	66		Fuel oil shortage	
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	8	40		Fuel oil shortage	
	Rampal 1320 MW	Coal (BIFPCL)				0	0	0	0				
	Khulna 330 MW CCPP	Gas/HSD (BPDB)				0	0	0	0				
**	Bheramara (HVDIC) India			1000	1000	918	918	929	929				
Khulna Zone Total						2388	2384	1186	1331	1279	1403	326	0
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	0	16		110	Line Overload	
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	16	21	16	22				
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	50	49	65	65	145		Gas Shortage	
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	610	690	850	950				
121	Potua Khali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0		150	Line Overload	
	Barisal Electric 307 MW	Coal (IPP)				97	129	0	0				
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	215	220	220	220				
Barisal Zone Total						1958	1958	988	1109	1151	1273	145	260
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	32	0	32				
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	100				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	22		71	Under maint.	
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	0	0	86				
128	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	40	0	32				
129	Katakali 50 MW PP (Northern)	HFO (ORPP)	6x8.9	50	50	0	34	0	42	16		Fuel Oil Shortage	
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	35	0	34				
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	150	164	160	160				
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0		220	Under maint.	
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	271	258	270	270			Gas Shortage	
135	Bogra 22 MW PP (GDB)	Gas (RPP)	6x4.0	22	22	16	17	20	20	5		Gas Shortage	
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	11	5	5	0		Gas Shortage	
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	8	43				
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	40	113	95	113				
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	1	90	35	95				
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0				
Rajshahi Zone Total						2129	2129	487	794	599	1054	412	291
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	79	81	80	80				
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	285	250	250	250			Under maint.	
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	25	100	55	113				
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Majpara, Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	0	0	8	0				
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	54	113	115				
148	Lalmohani 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	27	0	12	0				
Rangpur Zone Total						830	750	416	485	518	558	0	85
Sub-total: Plants in operation						22088	21710	8891.0	10312	9602	12166	3530	2949
(B) Plants under long term maintenance/ contract expired													
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
150	Kaipoti 52 MW PP (Sinhaj)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
151	Bosilia 108MW PP(CICL)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
152	Keranganj 100 MW PP (Powerpac)	HFO (ORPP)	8x13.45	100	0	0	0	0	0				
153	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
154	Arimura 30 MW PP(Sinhaj)	HFO (ORPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired						424	0	0	0	0	0		
Gross Total						22512	21710	8891	10312	9602	12166	3530	2949
(C) Actual data of 04.11.22 (Yesterday) Friday :													
01.	Max. Demand at eve. peak (Generation end)	:	10312 MW, at = 19:00 hrs			12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	10017 MW, at = 19:00 hrs				Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	10312 MW, at = 19:00 hrs				MW	MW	MW		MW	MW	MW
04.	Minimum Generation (Generation end)	:	7698 MW, at = 7:00 hrs				Dhaka	3866	3866	0	Mymensingh	802	802
05.	Day-peak Generation (Generation end)	:	8891 MW, at = 12:00 hrs				Chattogram	1158	1158	0	Sylhet	431	431
06.	Evening-peak Generation (Generation end)	:	10312 MW, at = 19:00 hrs				Khulna	1074	1074	0	Barisal	239	239
07.	Evening Peak Load-shed (Sub-station end)	:	0 MW, at = 19:00 hrs				Rajshahi	967	967	0	Rangpur	575	575
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7474 MW, at = 5:00 hrs				Cumilla	906	906	0			
09.	Generation shortfall at evening peak due to :	:								Total	10017	10017	0
	a) Gas/LF limitation	:	3530 MW			13.	Fuel cost :	(a) Gas = 124059196 Taka	(c) Coal = 198996196 Taka				
	d) Coal supply Limitation	:	0 MW					(b) Oil = 628474882 Taka	Total = 951530274 Taka				
	b) Low water level in Kaptai lake	:	0 MW										
	c) Plants under shut down/ maintenance	:	2949 MW			14.	Maximum Temperature in Dhaka was :	31.4° C					
10.	Total Energy (Generation + India Import)	:	216.07 MKWh			15.	Export through East-West interconnections :						
	By Gas = 111.977 MKWh	By Oil = 47.749 MKWh					At evening peak-hour	:	8891 MW, at 19:00 hrs				
	By Coal = 27.603 MKWh	By Hydro = 3.720 MKWh					Maximum	:	830 MW, at 7:00 hrs				
	By Solar= 1.430 MKWh						Energy	:	0 MKWh				
11.	Total Gas Supplied	:	856.10 MMCFD										
(D) Forecast of 05.11.22 (Today) Saturday :													
01.	Maximum Demand	:	11800 MW (Generation end)			04.	Maximum Load-shed	:	0 MW At evening peak (Sub-station end)				
02.	Maximum Generation	:	12166 MW (Generation end)			05.	Total Generation	:	247.24 MKWh				
03.	Reserve / Shortage	:	366 MW (Generation end)			06.	Probable Max. Temperature in Dhaka :	:	30.3° C				

* Cative Power ** Imported Power
#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00