

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month November, 2022										Day : Sunday				Date : 06.11.22				
Probable Maximum Demand :					12400	MW	Probable Maximum Generation :					12188	MW					
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 94.88		Today = 94.64		Rule Curve = 108.60		ft.							
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Deraled/ Present Capacity (MW)	05.11.22 (Yesterday)		06.11.22 (Today)		05.11.22 (Yesterday)		06.11.22 (Today)		05.11.22 (Yesterday)		06.11.22 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gas/Coal/oil/Water Limitation MW		Machines shut down (MW)		Description/ Remarks		Probable start-up date			
					Day	Evening	Day	Evening										
(A) Plants in operation:																		
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0				260				Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0								Line Overload	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180									
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	140	180	180				225				Under maint.	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	73	73	73	73									
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0				105				Gas Shortage	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0								Contract Expired	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	248	192	200	250				168				Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	200	190	200	200				260				Gas Shortage	
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0				115				Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	397	348	0	0									
11	Siddhirganj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0				210				Gas Shortage	
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0				335				Gas Shortage	
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	135	112	0	0				223				Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55									
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.324	102	102	58	92	60	92									
16	Narshingdi 22 MW PP (Doreen)	Gas (SIIPP, REB)	8x2.90	22	22	22	22	22	22									
17	Summit Power, (Madhabdi-Ashulia)	Gas (SIIPP, REB)	6x3.67+7x6.73	80	80	42	51	52	55									
18	Maona 33 MW PP(Summit)	Gas (SIIPP, REB)	4x8.73	33	33	0	33	33	33									
19	Rupganj 33 MW PP(Summit)	Gas (SIIPP, REB)	4x8.73	33	33	28	29	33	33									
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	49	49	49	49									
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	100	70	100									
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	98	132	115	132									
23	Kamalaghat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54									
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	185	276	275	280									
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	133	134	149									
26	Karagang 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	150									
27	Bramhangon 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	50									
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	50									
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	55	55									
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55									
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	71	93	74	92									
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	144	35	162									
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	30	0	30	0									
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	0	17	17									
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	63	88	70	88									
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	46	92	70	92									
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0									
Dhaka Zone Total					6004	5847	2359	2788	2154	2748	1301	600						
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	118	154	154	154								Unit 1 under rehabilitation	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0				180				Gas Shortage	
40	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0				180				Under maint.	
41	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0									
42	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	6	25	25	25									
43	Teknaf 20MW PP (Solarsat)	Solar (IPP)	1x20	20	20	9	0	20	0									
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	39	44	24	44									
45	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	51	105	70	105									
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0				150				Under maint.	
47	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	151	150	150	150				75				STG Under maint.	
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	123	300	125	300									
49	Julda 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	50	50	25	50									
50	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	51	17	51									
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	23	22	22									
52	Barabkunda 22 MW PP (Regent)	Gas (SIIPP, PDB)	8x2.90	22	22	0	0	0	0				22				Gas Shortage	
53	* Malancha Cig EPZ (United)	Gas	5x8.73+3x9.34			3	12	7	15									
54	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0				108				Fuel oil shortage	
55	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	36	36	36	54									
56	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	71	91	70	105									
57	Julda unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	50	50	25	50									
58	Julda 100 MW Unit-1 (Acom)	HFO (QRPgen)	8x13.45	100	100	100	66	22	75									
59	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107									
60	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0								on test	
Chattogram Zone Total					2442	2382	935	1264	904	1307	310	405						
61	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0				134				Gas Shortage	
62	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	47	50	50	51									
63	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1x75	221	221	169	191	175	190									
64	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	0	0	0	0				360				Under maint.	
65	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	340	310	360	360									
66	Ashuganj 420 MW CCPP(East) GT	Gas (APSCL)	1x284	284	284	0	0	0	0				284				Gas Shortage	
67	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	48	30	30	55									
68	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	168	168	170	180									
69	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	0	0	0	0				51				Gas Shortage	
70	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	40	68	64	100									
71	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	19	43	32	43									
72	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	49	50	50	50				57				ST Under maint.	
73	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	51	200	51	200									
74	Feni 22MW PP (Doreen)	Gas (SIIPP, PDB)	8x2.90	22	22	0	19	16	19									
75	Feni 11 MW PP (Doreen)	Gas (SIIPP, REB)	4x2.90	11	11	10	10	10	10									
76	Jangalia 33MW PP (Summit)	Gas (SIIPP, PDB)	4x8.73	33	33	7	30	33	33									
77	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	29	8	43									
78	Cumilla 25 MW PP (Summit)	Gas (SIIPP, REB)	3x3.67+2x6.97	25	25	12	21	21	21									
79	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+40x1.515+15x1.056	200	200	0	0	0	100									
80	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	96	114	17	114									
81	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	0	0	0	9									

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	05.11.22 (Yesterday)		06.11.22 (Today)		05.11.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	GT-1 Under maint.	
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	43	42	0	43		48	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	53	41	41	53				
91	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0	109	54	STG Under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0				
93	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	62	65	66	65				
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	20	81	0	80				
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	0	90	20	145		141	ST Under maint.	
97	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	18	18	19	19				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	8	10	10	10				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	0	0	0	25		Gas Shortage	
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	270	330	330				
101	Bibiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	408	415	400	400				
102	Bibiana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	380	398	400	400				
103	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	23	16	11	11	34		Gas Shortage	
105	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	44	30	30	44	20		Gas Shortage	
Sylhet Zone Total						2522	2477	1379	1506	1357	1630	188	713
106	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
107	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	180	170	190	190	240		Gas Shortage	
108	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	42	0	42				
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	82	0	82				
110	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	0				
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	0	50				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	54	60	94				
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0				
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	84	0	100	0				
115	Khulna 115 MW PP (KPLC-2)	HFO (NENP)	7x17	115	115	0	49	0	49	66		Fuel oil shortage	
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	8	0	8	32		Fuel oil shortage	
	Rampal 1320 MW	Coal (BIFPCL)				0	0	0	0				
	Khulna 330 MW CCPP	Gas/HSD (PDB)				0	0	0	0				
**	Bheramara (HVDIC) India			1000	1000	912	913	918	918				
Khulna Zone Total						2388	2384	1176	1318	1268	1433	338	0
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	0	16		110	Line Overload	
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	0	0	16	22				
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	62	60	65	65	134		Gas Shortage	
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	630	900	850	950				
121	Potua Khali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0		150	Line Overload	
	Barisal Electric 307 MW	Coal (IPP)				0	0	0	0				
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	64	220	220	220				
Barisal Zone Total						1958	1958	756	1180	1151	1273	134	260
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	32	0	32				
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	100				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	18	0	22		53	Under maint.	
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	86	0	86				
128	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	0	32				
129	Katakali 50 MW PP (Northern)	HFO (ORPP)	6x8.9	50	50	8	34	0	42	16		Fuel Oil Shortage	
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	34	0	34				
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	176	161	160	160				
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0		220	Under maint.	
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	250	231	270	270			Gas Shortage	
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	16	20	20	20				
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	8	11				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	8	43				
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	75	113	95	113				
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	94	35	95				
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0				
Rajshahi Zone Total						2129	2129	541	874	602	1060	407	273
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	10	80	80				
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	250	250	250			Under maint.	
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	113	113	50	70				
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Majpara, Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	0	0	8	0				
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	114	113	115				
148	Lalmohanhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	33	0	12	0				
Rangpur Zone Total						830	750	402	487	513	515	0	85
Sub-total: Plants in operation						22088	21710	8994.0	11297	9531	12188	3519	2753
(B) Plants under long term maintenance/ contract expired													
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
150	Kaipoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
151	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
152	Keraniganj 100 MW PP (Powerpac)	HFO (ORPP)	8x13.45	100	0	0	0	0	0				
153	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
154	Arimura 30 MW PP(Sinha)	HFO (ORPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired						424	0	0	0	0	0		
Gross Total						22512	21710	8994	11297	9531	12188	3519	2753
(C) Actual data of 05.11.22 (Yesterday) Saturday :													
01.	Max. Demand at eve. peak (Generation end)	:	11297	MW,	at =	20:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :					
02.	Max. Demand at eve. peak (Sub-station end)	:	10815	MW,	at =	20:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply
03.	Highest Generation (Generation end)	:	11297	MW,	at =	20:00 hrs	MW	MW	MW	MW	MW	MW	Load Shed
04.	Minimum Generation (Generation end)	:	7474	MW,	at =	5:00 hrs	Dhaka	4272	4272	0	Mymensingh	858	858
05.	Day-peak Generation (Generation end)	:	8994	MW,	at =	12:00 hrs	Chattogram	1189	1189	0	Sylhet	437	437
06.	Evening-peak Generation (Generation end)	:	11297	MW,	at =	20:00 hrs	Khulna	1148	1148	0	Barisal	262	262
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW,	at =	20:00 hrs	Rajshahi	987	987	0	Rangpur	618	618
08.	Minimum Generation Forecast up to 8:00 hrs.	:	8214	MW,	at =	5:00 hrs	Cumilla	1044	1044	0			
09.	Generation shortfall at evening peak due to :	:					Total						
	a) Gas/LF limitation	:	3519	MW			13.	Fuel cost :	(a) Gas = 125314607 Taka	(c) Coal = 199775227 Taka			
	d) Coal supply Limitation	:	0	MW				(b) Oil = 738352780 Taka	Total = 1063442615 Taka				
	b) Low water level in Kaptai lake	:	0	MW									
	c) Plants under shut down/ maintenance	:	2753	MW			14.	Maximum Temperature in Dhaka was : 31.7° C					
10.	Total Energy (Generation + India Import)	:	222.31	MKWh			15.	Export through East-West interconnections :					
	By Gas = 112.907 MKWh			By Oil = 55.480 MKWh				At evening peak-hour	:	8994	MW,	at	20:00 hrs
	By Coal = 25.444 MKWh			By Hydro = 3.391 MKWh				Maximum	:	580	MW,	at	7:00 hrs
	By Solar= 1.442 MKWh							Energy	:	0	MKWh		
11.	Total Gas Supplied	:	836.68	MMCFD									
(D) Forecast of 06.11.22 (Today) Sunday :													
01.	Maximum Demand	:	12400	MW	(Generation end)		04.	Maximum Load-shed					
02.	Maximum Generation	:	12188	MW	(Generation end)		05.	Total Generation					
03.	Reserve / Shortage	:	-212	MW	(Generation end)		06.	Probable Max. Temperature in Dhaka :					
								30.2° C					