

| Date :                |                                         | 6-Nov-22       |                     | Page -2          |                      |                  |                   |
|-----------------------|-----------------------------------------|----------------|---------------------|------------------|----------------------|------------------|-------------------|
| Sl. No.               | Name of the Power Stations              | Producer       | Installed Capacity  | Present Capacity | Peak Hour Generation | Energy Generated | Remarks           |
|                       |                                         |                | Unit No. X Capacity | MW               | MW                   | KWH              |                   |
| 1                     | Ghorasal Repowered CCGP Unit-3 (GT      | PDB            | 1'260               | 260              | 0                    | 0                | Under maint.      |
| 2                     | Ghorasal Repowered CCGP Unit-4          | PDB            | 1'210               | 180              | 0                    | 0                | Machine problem   |
|                       | Ghorasal TPP Unit-5                     | PDB            | 1'210               | 190              | 180                  | 4319500          |                   |
| 3                     | Ghorasal 365 MW CCGP Unit-7             | PDB            | 1'243+1'122         | 365              | 200                  | 4458700          | ST Under maint    |
|                       | Ghorashal 78.5 MW PP(MAX)               | QRPP           | 2'40                | 0                | 0                    | 0                |                   |
| 4                     | Ghorashal 108MW PP (Regent)             | IPP            | 3'4'3 35            | 108              | 32                   | 1148954          | Gas shortage      |
| 5                     | Haripur GTPP                            | SBU, PDB       | 2'32                | 20               | 0                    | 0                | Under maint.      |
| 6                     | Haripur 412 MW CCGP                     | EGCB           | 1'273+1'139         | 412              | 0                    | 292860           | Gas shortage      |
| 7                     | Haripur 360MW CCGP(HPL)                 | IPP            | 1'235+1'125         | 360              | 292                  | 6844000          | Gas shortage      |
| 8                     | Meghnaghat 450 MW CCGP(MPL)             | IPP            | 2'150+1'150         | 450              | 225                  | 5013500          | Gas shortage      |
| 9                     | Meghnaghat 100 MW(IEI)                  | NENP           | 1'2'9               | 100              | 67                   | 1442880          | Engine problem    |
| 10                    | Meghnaghat CCGP(Summit)                 | IPP            | 2'110+1'110         | 335              | 0                    | 0                | Gas shortage      |
| 11                    | Madanganj 102 PPI(Summit)               | NENP           | 6'17                | 102              | 0                    | 0                | Under maint.      |
| 12                    | Madanganj 55 MW PPI(Summit)             | IPP            | 3'17.08+1'11.3      | 55               | 55                   | 1324655          |                   |
| 13                    | Keranganj 100 MW PP (Powerpac)          | QRPP           | 8'13.45             | 0                | 0                    | 0                | Contract Expired  |
| 14                    | Narsingdi 22 MW PP (Doreen)             | SIPP, REB      | 8'2.90              | 22               | 19                   | 440532           |                   |
| 15                    | 210 MW Siddhirgonj TPP                  | PDB            | 1'210               | 115              | 0                    | 0                | Under maint.      |
| 16                    | Siddhirgonj 2'120 MW GTPP               | EGCB           | 2'105               | 210              | 0                    | 0                | Gas shortage      |
| 17                    | Siddhirganj 100 PPI(Dutch Bangla)       | NENP           | 1'2'9               | 100              | 58                   | 1492800          | Engine problem    |
| 18                    | Siddhirganj 335 MW CCGP                 | EGCB           | 1'217+118           | 335              | 0                    | 0                | Gas shortage      |
| 19                    | Gagnagar 102 MW PP (Digital Power)      | IPP            | 12'8.924            | 102              | 92                   | 1610208          | Engine problem    |
| 20                    | Katpotti 52 MW PP (Sinha)               | IPP            | 7'7.9               | 0                | 0                    | 0                | Fuel shortage     |
| 21                    | Kamalaghat 54 MW PP(Banco Energy)       | IPP            | 3'18                | 54               | 54                   | 650160           |                   |
| 22                    | Kodda 150MW PP                          | BPDB-RPCL      | 9'17.06             | 149              | 132                  | 1917120          | Engine problem    |
| 23                    | Manikganj 55 MW PP (Northern)           | IPP            | 3'18.3              | 55               | 35                   | 877653           |                   |
| 24                    | Nababganj 55 MW PP (Southern power )    | IPP            | 3'19.3              | 55               | 35                   | 903764           |                   |
| 25                    | Bossia 108MW PP(CLC)                    | IPP            | 12'8.775+1'3.5      | 0                | 0                    | 0                |                   |
| 26                    | Summit Power (Madhabdi-Ashulia)         | SIPP,REB       | 3'3.67+4'8.73       | 80               | 52                   | 1216590          | Engine problem    |
| 27                    | Maona 33 MW PPI(Summit)                 | SIPP, REB      | 4'8.73              | 33               | 33                   | 817560           |                   |
| 28                    | Rugganj 33 MW PPI(Summit)               | SIPP,REB       | 4'8.73              | 33               | 33                   | 819800           |                   |
| 29                    | Gazipur 52 MW PP                        | RPCL           | 6'8 9               | 52               | 49                   | 891360           | 0.00              |
| 30                    | Tongi 80 MW GTPP                        | PDB            | 1' 105              | 105              | 0                    | 0                | Under maint.      |
| 31                    | Kodda 300 MW PP Unit-2 (Summit)         | IPP            | 18'17.076           | 300              | 275                  | 6631             | Engine problem    |
| 32                    | Keranganj 300 MW PP (APF)               | IPP            | 256'1.4             | 300              | 108                  | 1916112          | Fuel conservation |
| 33                    | Bramhangaoan 100 MW PP (Aggreko)        | IPP            | 11'40.969           | 100              | 85                   | 792949           | Fuel conservation |
| 34                    | Aurahati 100MW PP (Aggreko)             | IPP            | 0.85'23+0.95'91     | 100              | 90                   | 847236           | Fuel conservation |
| 35                    | Kodda 149 MW PP Unit-1 (Summit)         | IPP            | 8'18.45+8.97        | 149              | 135                  | 3059860          | Engine problem    |
| 36                    | Gazipur 100 MW PP                       | RPCL           | 6'17.5              | 105              | 105                  | 2029188          |                   |
| 37                    | Meghnaghat 104 MW PP (OPCL)             | IPP            | 18.5'6              | 104              | 74                   | 1626240          | Fuel shortage     |
| 38                    | Manikgonj 162MW PPI(MPL)                | IPP            | 9'18                | 162              | 162                  | 2122560          | Engine problem    |
| 39                    | Spectra Solar Plant Ltd.                | IPP            | 35                  | 35               | 0                    | 187732           |                   |
| 40                    | Kanchan Purbachal Power Generation Ltd. | IPP            | 18.4'3              | 55               | 17                   | 424440           | Fuel shortage     |
| Dhaka area Total      |                                         |                |                     | 5847             | 2694                 | 49491454         |                   |
| 41                    | Chattogram TPP-1                        | PDB            | 1'210               | 180              | 0                    | 0                | Machine problem   |
|                       | Chattogram TPP-2                        | PDB            | 1'210               | 180              | 0                    | 0                | Gas shortage      |
| 42                    | Raozan 25 MW PP                         | RPCL           | 3'8.9               | 25               | 25                   | 483084           |                   |
| 43                    | Teknaf 20MW PP (Solaritech)             | IPP            | 20                  | 20               | 0                    | 125145           |                   |
| 44                    | Patenga 50MW PP (Baraka)                | IPP            | 8'6.98              | 50               | 44                   | 901920           | Engine problem    |
| 45                    | Kaptai Hydro: Unit-1,2,3,4, 5           | PDB            | 2'40+3'50           | 230              | 152                  | 3676080          | Low water level   |
| 46                    | Sikalbaha 225MW                         | PDB            | 1'150+1'175         | 225              | 150                  | 3646392          | ST Under maint    |
| 47                    | Sikalbaha Peaking GT                    | PDB            | 1'150               | 150              | 0                    | 0                | Under maint.      |
| 48                    | Sikalbaha 105 MW PP (Baraka Sikalbaha)  | IPP            | 6'17.5              | 105              | 105                  | 1834145          |                   |
| 49                    | Hafizazari 100 MW peaking PP            | PDB            | 11'5.9              | 98               | 38                   | 481976           | Fuel shortage     |
| 50                    | Dohazari -Kalaish 100 MW Peaking        | PDB            | 8'17                | 102              | 51                   | 620473           | Fuel shortage     |
| 51                    | Juidah 100 MW Unit-1 (Acorn)            | NENP           | 8'13.45             | 100              | 77                   | 1202400          | Fuel shortage     |
| 52                    | Juidah 100 MW PP Unit-3 (Acorn)         | IPP            | 8'13.5              | 100              | 63                   | 1085760          | Fuel shortage     |
| 53                    | Barabkunda 22 MW PP (Regent)            | SIPP, PDB      | 8'2.90              | 22               | 0                    | 0                | Engine problem    |
| *                     | Malancha, Clg. EP2 (United)             |                | 5'8.73+3'9.34       | 0                | 7                    | 383430           |                   |
| 54                    | Chattogram 108 MW PP (ECPV)             | IPP            | 16'7                | 108              | 0                    | 0                | Fuel shortage     |
| 55                    | Kaptai 7 MW Solar PP                    | PDB            | 7.4 MW              | 7                | 0                    | 24336            |                   |
| 56                    | Anwara 300 MW PP (United)               | IPP            | 17'17+24            | 300              | 300                  | 3289418          |                   |
| 57                    | Jodai Power                             | IPP            | 3'18.55+1'3.6       | 54               | 36                   | 981435           | Engine problem    |
| 58                    | Karnaphuli Power Ltd.                   | IPP            | 18.415'6+6.5        | 110              | 72                   | 1703665          | Fuel shortage     |
| 59                    | Juidah unit-2 (Acorn)                   | IPP            | 8'13.6              | 100              | 100                  | 1496640          |                   |
| 60                    | Anilma Energy Ltd.                      | IPP            | 6'21.2              | 116              | 107                  | 2578091          | Engine problem    |
|                       | Mirshara 150 MW                         | BPDB-RPCL      | 18.5'9              | 0                | 0                    | 45163            | On test.          |
| Chattogram area Total |                                         |                |                     | 2382             | 1327                 | 24595553         |                   |
| 61                    | Ashuganj TPP Unit-3                     | APSCL          | 1'150               | 0                | 0                    | 0                | Contract Expired  |
|                       | Ashuganj TPP Unit-4                     | APSCL          | 1'150               | 0                | 0                    | 0                | Contract Expired  |
|                       | Ashuganj TPP Unit-5                     | APSCL          | 1'150               | 134              | 0                    | 0                | Gas shortage      |
| 62                    | Ashuganj 225 MW CCGP                    | APSCL          | 1'142+1'175         | 221              | 170                  | 4144000          | Gas shortage      |
| 63                    | Ashuganj 450 MW CCGP(North)             | APSCL          | 1'360               | 360              | 305                  | 7974500          |                   |
| 64                    | Ashuganj 450 MW CCGP(South)             | APSCL          | 1'360               | 360              | 80                   | 590000           | ST Under S/D      |
|                       | Ashuganj 420 MW CCGP(East)              | APSCL          | 284'1+136'1         | 284              | 0                    | 0                | On test.          |
| 65                    | Ashuganj 50 MW PP                       | APSCL          | 14'3.968            | 45               | 30                   | 1022904          | Gas shortage      |
| 66                    | Ashuganj 55 MW PP (Precision)           | QRPP           | 15'4                | 55               | 10                   | 510720           | Gas shortage      |
| 67                    | Ashuganj 195MW PP (APSCL-United)        | IPP            | 20'9.73+1'16        | 195              | 65                   | 3245090          | Gas shortage      |
| 68                    | Ashuganj 51 MW PP (Midland)             | IPP            | 6'9.34              | 51               | 0                    | 0                | Gas shortage      |
| 69                    | Ashuganj 150MW PP (Midland)             | IPP            | 23'7.015            | 150              | 73                   | 1537236          | Fuel shortage     |
| 70                    | Titas 50 MW Peaking PP                  | PDB            | 6'8.92              | 52               | 36                   | 526016           | Engine problem    |
| 71                    | Chandpur 150 MW CCGP                    | PDB            | 1'106+1'57          | 163              | 49                   | 1183950          | Machine problem   |
| 72                    | Chandpur 200MW (Desh energy)            | IPP            | 12'18.4             | 200              | 180                  | 1568640          | Engine problem    |
| 73                    | Feni 22MW PP (Doreen)                   | SIPP, PDB      | 8'2.90              | 22               | 19                   | 422604           | Engine problem    |
| 74                    | Feni 11 MW PP (Doreen)                  | SIPP, REB      | 4'2.90              | 11               | 10                   | 248760           |                   |
| **                    | Import (Tripura)                        | Imported power | 0                   | 160              | 140                  | 3091200          |                   |
| 75                    | Jangalia 33MW PP (Summit)               | SIPP, PDB      | 4'8.73              | 33               | 33                   | 583000           |                   |
| 76                    | Jangalia 52 MW PP (Lakdoreen)           | IPP            | 6'8.92              | 52               | 43                   | 433315           | Engine problem    |
| 77                    | Cumilla 25 MW PP (Summit)               | SIPP, REB      | 3'3.67+2'6.97       | 25               | 21                   | 483470           | Engine problem    |
| 78                    | Daudkandi 200 MW PP (B.Trac)            | IPP            | 154'1.4             | 200              | 50                   | 493632           | Fuel conservation |
| 79                    | Feni Lanka Power                        | IPP            | 7'18.415+1'9.78     | 114              | 114                  | 721620           |                   |
| 80                    | Chowmuhani 113 MW                       | IPP            | 12'9.78+2'3.1       | 113              | 0                    | 0                | Fuel shortage     |
| 81                    | Bhairab 54.5 MW                         | IPP            | 3'18.2              | 54               | 35                   | 745200           | Engine problem    |
| 82                    | Chandpur 115(Doreen)                    | IPP            | 4'18.5+2'22.5       | 115              | 115                  | 1703040          |                   |
| Cumilla Area Total    |                                         |                |                     | 3169             | 1578                 | 31228897         |                   |
| 83                    | RPCL 210MW CCGP                         | IPP            | 4'35+1'70           | 202              | 72                   | 2100480          | Gas shortage      |
| 84                    | Tangail 22 MW PP (Doreen)               | SIPP, PDB      | 8'2.90              | 22               | 10                   | 279108           | Gas shortage      |
| 85                    | Jamalpur 95 MW PP(Powerpac)             | IPP            | 12'8.924            | 0                | 0                    | 0                | Under maint.      |
| 86                    | Sarishabari 3 MW Solar Plant            | IPP            | 1'3                 | 3                | 0                    | 12150            |                   |
| 87                    | Mymensingh 200 MW PP (United)           | IPP            | 9'78'21             | 200              | 58                   | 1368000          | Fuel shortage     |
| 88                    | Jamalpur 115 MW PP (United)             | IPP            | 9'78'12             | 115              | 58                   | 1318800          | Engine problem    |
| 89                    | Sutakhal 50 MW Solar PP                 | IPP            | 50                  | 50               | 0                    | 289980           |                   |
| 90                    | Tangail Pali Power Gen 22 MW            | IPP            | 4'6.7               | 22               | 6                    | 142800           | Engine problem    |
| Mymensingh Area Total |                                         |                |                     | 614              | 204                  | 5511318          |                   |
| 91                    | Fenchugonj CCGP Phase-1                 | PDB            | 2'32+1'33           | 70               | 30                   | 716000           | Machine problem   |
| 92                    | Fenchugonj CCGP Phase-2                 | PDB            | 2'35+1'35           | 90               | 30                   | 540360           | Machine problem   |
| 93                    | Kushnara 163 MW CCGP (KP)               | IPP            | 1'109+1'54          | 163              | 0                    | 0                | Gas shortage      |
| 94                    | Shajibazar 330 MW CCGP                  | PDB            | 3'110               | 330              | 0                    | 0                | Under maint.      |
| 95                    | Fenchugonj 51 MW PP (Barakatullah)      | RPP            | 19'2.90             | 51               | 11                   | 271000           | Gas shortage      |
|                       | Fenchuganj 44MW (Energyprima)           | NENP           | 12'3.3+5'2          | 50               | 10                   | 266688           | Gas shortage      |
| 96                    | Hobiganj 11MW PP Confidene-E            | SIPP, REB      | 4'2.90              | 11               | 0                    | 0                | Gas shortage      |
| 97                    | Shahjibazar GTPP Unit- 8 & 9            | PDB            | 2'35                | 66               | 61                   | 1461792          |                   |
| 98                    | Shahjibazar 56MW PP (Shahjibazar)       | RPP            | 3'22.90             | 86               | 81                   | 717120           |                   |
| 99                    | Shahjibazar 100 MW GTPP                 | PDB            | 1'100               | 100              | 0                    | 0                | Under maint.      |
| 100                   | Sylhet 225 MW CCGP                      | PDB            | 1'142+1'99          | 231              | 133                  | 2531190          | ST Under maint    |
| 101                   | Sylhet 20 MW GTPP                       | PDB            | 1'20                | 20               | 18                   | 433000           | Gas shortage      |
|                       | Sylhet 50MW PP (EPL)                    | NENP           | 27'2                | 50               | 30                   | 384420           | Gas shortage      |
| 102                   | Shahjahanulla 25 MW PP                  | SIPP, REB      | 3'9.34              | 25               | 0                    | 0                | Gas shortage      |
| 103                   | Bibiana-II 341 MW CCGP (Summit)         | IPP            | 1'222+1'119         | 341              | 300                  | 7139500          | FGMO              |
| 104                   | Bibiyana-III 400 MW CCGP                | PDB            | 400 MW              | 400              | 403                  | 9674000          |                   |
| 105                   | Sylhet 10MW PP (Desh)                   | RPP            | 6'1.95              | 10               | 10                   | 240660           |                   |
| 106                   | Bibiyana South 400 MW                   | PDB            | 400 MW              | 383              | 400                  | 9442000          |                   |
| Sylhet Area Total     |                                         |                |                     | 2477             | 1517                 | 33817730         |                   |
| 107                   | Bheramara GTPP Unit-3                   | PDB            | 1'20                | 16               | 0                    | 0                | Fuel shortage     |
| **                    | Bheramara (HVDC )                       | Imported power | 2'500               | 1000             | 905                  | 2085909          |                   |
| 108                   | Khulna 115 PP MW (KPCL-2)               | NENP           | 7'17.54             | 115              | 66                   | 389800           | Fuel shortage     |
| 109                   | Fardpur 50 MW Peaking PP                | PDB            | 8'6.98              | 54               | 33                   | 144960           | Engine problem    |
| 110                   | Khulna 225 MW CCGP                      | NWPGCL         | 1'150+1'175         | 230              | 0                    | 0                | Fuel shortage     |
| 111                   | Gopalganj 100 MW Peaking PP             | PDB            | 16'6.98             | 109              | 80                   | 363008           | Engine problem    |
| 112                   | Bheramara 410 MW CCGP                   | NWPGCL         | 1'278+1'132         | 410              | 140                  | 4180896          | Gas shortage      |
|                       | Noapara 40 MW PP (Khanjahan Ali)        | NENP           | 5'8 5               | 40               | 8                    | 32625            | Fuel shortage     |
| 113                   | Noapara 100 MW PP (Bangla Trac)         | IPP            | 70'1.4              | 100              | 20                   | 65280            | Fuel conservation |
| 114                   | Rupsha 105 MW PP (Orion rupsha)         | IPP            | 6'18.445            | 105              | 75                   | 975840           | Fuel shortage     |
| 115                   | Madhumati 100 MW PP                     | NWPGCL         |                     |                  |                      |                  |                   |