

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month November, 2022				Day : Wednesday				Date : 09.11.22				
Probable Maximum Demand : 11500 MW				Probable Maximum Generation : 11731 MW				Rule Curve = 108.20 ft.				
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 94.16 ft Today = 93.72 ft								
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	08.11.22 (Yesterday)		09.11.22 (Today)		08.11.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	Probable start-up date
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW			
					Day	Evening	Day	Evening	Machines shut down (MW)	Description/ Remarks		
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0			Line Overload
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	110	180	180	180			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	200	0	0	0			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	3x43.35	108	108	31	72	72	72			
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			Contract Expired
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	326	313	320	320			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225		Gas Shortage
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412		Gas Shortage
11	Siddhirganj 2120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335		Gas Shortage
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0	335		Gas Shortage
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	30	15	15	15			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	84	92	84	92			
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	0	22	22			
17	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	47	52	50	51			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	33	33			
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	49	49	49	49			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	105	105	105			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	82	133	80	133			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	35	17	54			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	195	293	280	285			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	99	117	135	135			
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	88	103	200	150			
27	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	50	50	100	50			
28	Auraihat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	88	50	100	50			
29	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	55	35	35	55			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	35	55			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	72	73	54	80			
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	140	162	140	162			
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	30	0	30	0			
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	35	17	34			
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	80	88	80	88			
36	Meghnaghat 100 MW(HEL)	HFO (NENP)	12x8.9	100	100	81	75	75	75			
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0			
Dhaka Zone Total					6004	5847	2417	2465	2566	2603	1622	375
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	154	152	152	154			Unit 1 under rehabilitation
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	1	0	5	0			
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	17	17	17			
42	Teknaf 20MW PP (SolarTech)	Solar (IPP)	1x20	20	20	19	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	18	44	30	44			
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	78	105	80	105			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.
46	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	149	151	150	150	74		STG Under maint.
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x6.04	300	300	300	300	150	300			
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	50	25	50			
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	17	51			
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	29	21	22	22			
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0	22		Gas Shortage
*	Malancha, Cig.EP2 (United)	Gas	5x8.73+3x9.34			2	2	5	10			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0	108		Fuel oil shortage
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	36	36	36			
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	91	91	91	91			
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	50	50	50			
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	33	55	33	55			
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107			
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0			on test
Chattogram Zone Total					2442	2382	1102	1232	990	1242	310	404
58	Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	8	20	8	48			
60	Ashuganj 225 MW CAPP	Gas (APSCCL)	1x142+1175	221	221	177	178	180	180			
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	300	300	320	360			
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	320	315	300	300			
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCCL)	1x284	284	284	0	0	0	0	284		Gas Shortage
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	5	20	5	20	35		Gas Shortage
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+11'16	195	195	8	8	8	8	187		Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	0	0	0	0	51		Gas Shortage
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	67	77	65	77			
68	Titaz 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	43	43	0	43			
69	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	50	50	50	50	57		ST Under maint.
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	51	200	51	200			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	10	10			
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	14	25	33	33			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	34	8	33			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	13	21	21	21			
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	9x14+6x1.515+15x1.098	200	200	30	100	100	100			
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	0	114	15	114			
78	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	9	9	9	9	104		Fuel Oil Shortage
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	25	35	35	35			
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	115	115	115	115			
**	Import (Tripura)	India		160	160	102	130	143	166			
Cumilla Zone Total					3193	3169	1377	1826	1498	1944	795	57
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	67	101	70	101	101		Gas Shortage
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	8	8	8	8			
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	77	79	50	80			
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	76	107	48	75	93		Fuel oil shortage
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
86	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	52	0	50	0			
87	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	12	12	12	12			
Mymensingh Zone Total					622	614	294	307	240	276	194	0

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	08.11.22 (Yesterday)		09.11.22 (Today)		08.11.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gas/Coal/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening				
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	GT-1 Under maint.	
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	20	42	42	42		48	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	0	0	0	0				
91	Kushiara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0	109	54	STG Under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	56	61	60	63				
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	81	0	81				
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	220	219	200	220		12	ST Under maint.	
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	8	8	8	17		Gas Shortage	
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	280	265	280	280				
101	Bibiyan-II 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	411	408	400	400				
102	Bibiyan South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	384	400	400	400				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	0	0	0	0	50		Gas Shortage	
105	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12x3.3+5*2	50	50	0	0	0	0	50		Gas Shortage	
Sylhet Zone Total						2522	2477	1444	1542	1448	1552	226	584
106	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
107	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	160	160	160	160	250		Gas Shortage	
108	Fairdipor 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	43	0	43				
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	48	0	48				
110	Khulna 225 MW CCPP	HSD (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0				
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	0	50				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	56	67	76				
113	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	0	0				
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	65	0	100	0				
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	16	99	32	99	16		Fuel oil shortage	
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	8	40		Fuel oil shortage	
	Rampal 1320 MW	Coal (BIFPCL)				0	0	0	0				
	Khulna 330 MW CCPP	Gas/HSD (BPDB)				0	0	0	0				
**	Bheramara (HVDC)	India		1000	1000	890	890	906	906				
Khulna Zone Total						2388	2384	1148	1296	1265	1390	306	0
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	0	0		110	Line Overload	
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	17	23	16	22				
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	65	62	65	65	132		Gas Shortage	
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	700	880	850	850				
121	Potukhalhi 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0		150	Line Overload	
	Barisal Electric 307 MW	Coal (IPP)				0	0	0	0				
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	222	221	220	220				
Barisal Zone Total						1958	1958	1004	1186	1151	1157	132	260
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	32	0	32				
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	100				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	25	0	22		46	Under maint.	
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	86	0	86				
128	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	41	0	40				
129	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	8	34	34	34				
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	35	0	35				
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	152	154	150	150	56		Gas Shortage	
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	0	0	0	0		220	Under maint.	
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	207	199	270	270	215		Gas Shortage	
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	15	22	18	22				
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	11	8	11				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	43	8	43				
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	95	113	100	113				
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	50	94	35	94				
140	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	4	0	6	0				
Rajshahi Zone Total						2129	2129	547	889	629	1052	662	266
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	82	80	80	80				
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	160	250	250			Under maint.	
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	56	71	50	70				
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0				
147	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	115	115	35	115	113	115				
148	Lalmohithai 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	31	0	12	0				
Rangpur Zone Total						830	750	461	426	513	515	0	85
Sub-total: Plants in operation						22088	21710	9794.0	11169	10300	11731	4247	2031
(B) Plants under long term maintenance/ contract expired													
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
150	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
151	Bosila 108MW PP(PLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
153	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
154	Ammura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired						424	0	0	0	0	0	0	0
Gross Total						22512	21710	9794	11169	10300	11731	4247	2031
(C) Actual data of 08.11.22 (Yesterday) Tuesday :													
01.	Max. Demand at eve. peak (Generation end)	:	11169	MW, at =	19:30 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	10638	MW, at =	19:30 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	11169	MW, at =	19:30 hrs	Dhaka	4176	4176	0	Mymensingh	836	836	0
04.	Minimum Generation (Generation end)	:	7802	MW, at =	4:00 hrs	Chattogram	1221	1221	0	Sylhet	437	437	0
05.	Day-peak Generation (Generation end)	:	9794	MW, at =	12:00 hrs	Khulna	1150	1150	0	Barisal	271	271	0
06.	Evening-peak Generation (Generation end)	:	11169	MW, at =	19:30 hrs	Rajshahi	1001	1001	0	Rangpur	603	603	0
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at =	19:30 hrs	Cumilla	944	944	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7795	MW, at =	5:00 hrs					Total	10638	10638	0
09.	Generation shortfall at evening peak due to :	:				13.	Fuel cost :	(a) Gas = 119389851 Taka (b) Oil = 837417473 Taka		(c) Coal = 218935265 Taka Total = 1175742590 Taka		Taka	Taka
	a) Gas/LF limitation	:	4247	MW						31.7° C			
	d) Coal supply Limitation	:	0	MW									
	b) Low water level in Kaptai lake	:	0	MW									
	c) Plants under shut down/ maintenance	:	2031	MW		14.	Maximum Temperature in Dhaka was :						
10.	Total Energy (Generation + India Import)	:	225.82	MKWh		15.	Export through East-West interconnections :						
	By Gas = 109.294 MKWh			By Oil = 61.487 MKWh			At evening peak-hour : 9794 MW, at 19:30 hrs						
	By Coal = 27.108 MKWh			By Hydro = 3.250 MKWh			Maximum : 640 MW, at 7:00 hrs						
	By Solar= 1.409 MKWh						Energy : 0 MKWh						
11.	Total Gas Supplied	:	826.50	MMCFD									
(D) Forecast of 09.11.22 (Today) Wednesday :													
01.	Maximum Demand	:	11500	MW (Generation end)		04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)						
02.	Maximum Generation	:	11731	MW (Generation end)		05.	Total Generation : 232.51 MKWh						
03.	Reserve / Shortage	:	231	MW (Generation end)		06.	Probable Max. Temperature in Dhaka : 29.2° C						