

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month November, 2022					Day : Thursday				Date : 10.11.22			
Probable Maximum Demand : 11300 MW					Probable Maximum Generation : 11562 MW				Rule Curve = 108.10 ft.			
Water Level of Kaptai Lake at 06:00 AM					Today = 93.50 ft.							
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	09.11.22 (Yesterday)		10.11.22 (Today)		09.11.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	Probable start-up date
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW			
					Day	Evening	Day	Evening	Machines shut down (MW)	Description/ Remarks		
(A) Plants in operation:												
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work
2	a) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0			Line Overload
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	3x43.35	108	108	70	72	67	67			
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0			Contract Expired
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	322	261	300	300			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225		Gas Shortage
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412		Gas Shortage
11	Siddhirganj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335		Gas Shortage
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0	335		Gas Shortage
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	15			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	84	92	84	92			
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	22	22	22			
17	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	44	45	52	52			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25			
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	26	33	33	33			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	41	47	50	50			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	105	105	105	105			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	64	133	64	133			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	35	17	35			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	225	291	280	291			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	134	135	135	135			
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	207	153	200	150			
27	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	91	50	100	50			
28	Auraihat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	60	26	100	50			
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	35	55			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	55	73	55	80			
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	144	140	162			
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	28	0	30	0			
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	35	17	34			
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	88	88	88	88			
36	Meghnaghat 100 MW(HEL)	HFO (NENP)	12x8.9	100	100	68	75	84	84			
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0			
Dhaka Zone Total					6004	5847	2297	2470	2538	2568	1622	375
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	105	150	152	152			Unit 1 under rehabilitation
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	4	0	5	0				
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	17	17	17			
42	Teknaf 20MW PP (SolarTech)	Solar (IPP)	1x20	20	20	19	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	39	44	25	44			
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	85	105	80	105			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.
46	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	149	151	150	150	74		STG Under maint.
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x6.04	300	300	123	300	150	300			
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	50	25	50			
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	17	51			
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	33	21	20	20			
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0	22		Gas Shortage
*	Malancha, Cig.EP2 (United)	Gas	5x8.73+3x9.34			2	3	5	10			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0	108		Fuel oil shortage
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	36	36	36	36			
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	73	73	91	91			
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	21	50	25	50			
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	33	55	33	55			
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107			
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			10	0	0	0			on test
Chattogram Zone Total					2442	2382	864	1213	958	1238	310	404
58	Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	47	44	5	44			
60	Ashuganj 225 MW CAPP	Gas (APSCCL)	1x142+17x5	221	221	149	152	130	180			
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	320	300	380	330			
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	335	280	270	280			
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCCL)	1x284	284	284	0	0	0	0	284		Gas Shortage
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	5	5	5	5	50		Gas Shortage
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+1'16	195	195	8	8	8	8	187		Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	0	0	0	0	51		Gas Shortage
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	55	50	33	64			
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	42	43	0	43			
69	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	49	50	50	50	57		ST Under maint.
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	51	200	51	200			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	21	21	21			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	10	10	10			
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	16	25	25	25			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	16	8	16			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	21	21	21			
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	96x1.4+6x1.515+15x1.098	200	200	70	30	100	100			
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	17	114	17	114			
78	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	9	9	9	9	104		Fuel Oil Shortage
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	26	35	17	35			
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	31	115	115	115			
**	Import (Tripura)	India		160	160	108	134	143	166			
Cumilla Zone Total					3193	3169	1393	1662	1418	1836	810	57
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	65	56	90	100	146		Gas Shortage
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	8	8	8	8			
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	49	79	50	80			
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	48	106	48	100	94		Fuel oil shortage
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
86	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	52	0	50	0			
87	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	12	12	12	12			
Mymensingh Zone Total					622	614	236	261	260	300	240	0

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	09.11.22 (Yesterday)		10.11.22 (Today)		09.11.22 (Yesterday)		Status of Machines under shut-down/ Maintenance			
						Actual Peak Generation (MW)	Probable Peak Generation (MW)	Gen. shortfall for :		Description/ Remarks	Probable start-up date				
								Gas/Coal/Water Limitation MW	Machines shut down (MW)						
						Day	Evening	Day	Evening						
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	GT-1 Under maint.			
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42		48	GT-4 Under maint.			
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	0	11	0	0						
91	Kushiara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0	109	54	STG Under maint.			
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	2	2	2						
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	56	59	64	60						
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.			
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	3x2x90	86	86	0	81	0	81						
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	219	219	220	220		12	ST Under maint.			
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	19	19						
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10						
99	Shahjahanula 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	0	0	0	25		Gas Shortage			
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	300	270	280						
101	Bibiyan-II 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	411	406	400	400						
102	Bibiyan South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	390	397	400	400						
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work			
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	0	0	0	0	50		Gas Shortage			
105	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12x3.3+5x2	50	50	0	0	0	0	50		Gas Shortage			
Sylhet Zone Total						2522	2477	1476	1575	1457	1544	234	584		
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0						
107	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	155	150	185	185	260		Gas Shortage			
108	Fairdipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	43	0	43						
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	72	0	72						
110	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	0						
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	50	0	50						
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	53	53	53						
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0						
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	76	0	100	0						
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	66	32	99	49		Fuel oil shortage			
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5x8.5	40	40	0	0	0	8	40		Fuel oil shortage			
	Rampal 1320 MW	Coal (BIFPCL)				0	0	0	0						
	Khulna 330 MW CCPP	Gas/HSD (BPDB)				160	0	0	0						
**	Bheramara (HVDC)	India		1000	1000	888	903	921	921						
Khulna Zone Total						2388	2384	1279	1337	1291	1431	349	0		
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	0	0		110	Line Overload			
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	17	22	16	22						
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	65	65	65	65	129		Gas Shortage			
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	620	870	850	870						
121	Potukhalhi 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0		150	Line Overload			
	Barisal Electric 307 MW	Coal (IPP)				0	0	0	0						
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	203	222	220	220						
Barisal Zone Total						1958	1958	905	1179	1151	1177	129	260		
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage			
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage			
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	32	0	32						
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	30	0	100						
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	15	0	22		56	Under maint.			
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	87	0	86						
128	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	40	0	40						
129	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	34	34	34						
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	28	0	35						
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	156	155	150	150		55	Gas Shortage			
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage			
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0		220	Under maint.			
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	197	199	220	220	215		Gas Shortage			
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	15	20	17	20						
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11						
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	43	43	8	43						
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6x18.55	113	113	35	113	90	113						
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	94	94	94						
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	6	0	6	0						
Rajshahi Zone Total						2129	2129	463	901	630	1000	661	276		
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	82	83	80	80						
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling			
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	160	160	160	160			Under maint.			
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	716x 2"3	113	113	56	113	113	113						
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
146	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0						
147	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6x20	115	115	95	115	113	115						
148	Lalmohini 30 MW Solar (Intraco)	Solar (IPP)	1x30	30	30	31	0	12	0						
Rangpur Zone Total						830	750	430	471	486	468	0	85		
Sub-total: Plants in operation						22088	21710	9343.0	11069	10189	11562	4355	2041		
(B) Plants under long term maintenance/ contract expired															
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0						
150	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0						
151	Bosila 108MW PP(PLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0						
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0						
153	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020			
154	Ammura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022			
Sub-Total: Plants under long term maintenance/ contract expired						424	0	0	0	0	0				
Gross Total						22512	21710	9343	11069	10189	11562	4355	2041		
(C) Actual data of 09.11.22 (Yesterday) Wednesday :															
01.	Max. Demand at eve. peak (Generation end)	:	11069	MW, at =	19:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand at eve. peak (Sub-station end)	:	10608	MW, at =	19:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW		
03.	Highest Generation (Generation end)	:	11069	MW, at =	19:00 hrs	Dhaka	4139	4139	0	Mymensingh	814	814	0		
04.	Minimum Generation (Generation end)	:	7795	MW, at =	5:00 hrs	Chattogram	1263	1263	0	Sylhet	414	414	0		
05.	Day-peak Generation (Generation end)	:	9343	MW, at =	12:00 hrs	Khulna	1134	1134	0	Barisal	271	271	0		
06.	Evening-peak Generation (Generation end)	:	11069	MW, at =	19:00 hrs	Rajshahi	1006	1006	0	Rangpur	620	620	0		
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at =	19:00 hrs	Cumilla	947	947	0						
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7720	MW, at =	5:00 hrs	Total							10608	10608	0
09.	Generation shortfall at evening peak due to :	:				13.	Fuel cost :	(a) Gas = 116840612 Taka	(c) Coal = 211693638 Taka						
a) Gas/LF limitation	:	4355	MW					(b) Oil = 833089036 Taka	Total = 1161623285 Taka						
d) Coal supply Limitation	:	0	MW												
b) Low water level in Kaptai lake	:	0	MW												
c) Plants under shut down/ maintenance	:	2041	MW			14. Maximum Temperature in Dhaka was : 31.5° C									
10.	Total Energy (Generation + India Import)	:	223.15	MKWh		15. Export through East-West interconnections :									
	By Gas =	106.623	MKWh	By Oil =	62.342	At evening peak-hour : 9343 MW, at 19:00 hrs									
	By Coal =	25.832	MKWh	By Hydro =	3.083	Maximum : 640 MW, at 7:00 hrs									
	By Solar =	1.405	MKWh			Energy : 0 MKWh									
11.	Total Gas Supplied	:	814.10	MMCFD											
(D) Forecast of 10.11.22 (Today) Thursday :															
01.	Maximum Demand	:	11300	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)				
02.	Maximum Generation	:	11562	MW	(Generation end)	05.	Total Generation	:	227.80	MKWh					
03.	Reserve / Shortage	:	262	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	29.3° C						