

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 10-Nov-22

Page -2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CCPP-Unit-3 (GT	PDB	1'260	260	0	0	Under maint.
2	Ghorasal Repowered CCPP-Unit-4	PDB	1'210	180	0	0	Line O/L
3	Ghorasal TPP Unit-5	PDB	1'210	190	180	4378500	
4	Ghorasal 365 MW CCPP Unit-7	PDB	1'243+1'122	365	0	0	Under maint.
5	Ghorashal 78.5 MW PP(MAX)	QRPP	2'40	0	0	0	
6	Ghorashal 108MW PP (Regent)	IPP	34'3.35	108	70	1639272	Gas shortage
7	Haripur GTPP	SBU, PDB	2'32	20	0	0	Under maint.
8	Haripur 412 MW CCPP	EGCB	1'273+1'139	412	0	0	Gas line maintenance
9	Haripur 360MW CCPP(HPL)	IPP	1'235+1'125	360	241	7248000	Gas shortage
10	Meghnaghat 450 MW CCPP(MPL)	IPP	2'150+1'150	450	225	5181500	Gas shortage
11	Meghnaghat 100 MW(IEI)	NENP	12'8.9	100	84	1443840	Engine problem
12	Meghnaghat CCPP(Summit)	IPP	2'110+1'110	335	0	0	Gas shortage
13	Madanganj 102 PP(Summit)	NENP	6'17	102	0	2692	Under maint.
14	Madanganj-25 MW PP(Summit)	IPP	3'17.08+1'11.3	55	15	380080	Fuel shortage
15	Keraniganj 100 MW PP (Powerpac)	QRPP	8'13.45	0	0	0	Contract Expired
16	Narsingdi 22 MW PP (Doreen)	SIPP, REB	8'2.90	22	22	474156	
17	210 MW Siddhirgonj TPP	PDB	1'210	115	0	0	Under maint.
18	Siddhirgonj 2'120 MW GTTP	EGCB	2'105	210	0	0	Gas shortage
19	Siddhirgonj 100 PP(Dutch Bangla)	NENP	12'8.9	100	87	1717440	Engine problem
20	Siddhirgonj 335 MW CCPP	EGCB	1'217+118	335	0	0	Gas shortage
21	Gagnagar 102 MW PP (Digital Power)	IPP	12'8.924	102	83	1536048	Engine problem
22	Kaipoti 52 MW PP (Sirsha)	IPP	7'7.9	0	0	0	Fuel shortage
23	Kamalaghat 54 MW PP(Banco Energy)	IPP	3'18	54	54	533160	
24	Kodda 150MW PP	BPDB-RRCL	9'17.08	149	133	1880160	Fuel shortage
25	Manikganj 55 MW PP (Northern)	IPP	3'19.3	55	35	890217	Fuel shortage
26	Nabaganj 55 MW PP (Southern power)	IPP	3'19.3	55	35	873553	Fuel shortage
27	Bosila 108MW PP(CLC)	IPP	12'8.775+1'3.5	0	0	0	
28	Summit Power (Madhabdi-Ashulia)	SIPP REB	3'3.67+4'8.73	80	52	1209300	Engine problem
29	Madana 33 MW PP(Summit)	SIPP, REB	4'8.73	33	25	625400	Engine problem
30	Rugan 33 MW PP(Summit)	SIPP, REB	4'8.73	31	778400		
31	Gazipur 52 MW PP	RPCL	6'8.9	52	49	968160	0.00
32	Tongi 80 MW GTTP	PDB	1' 105	105	0	0	Under maint.
33	Kodda 300 MW PP Unit-2 (Summit)	IPP	18'17.076	300	283	4486255	Engine problem
34	Keraniganj 300 MW PP (APR)	IPP	256'1.4	300	11	959806	Fuel conservation
35	Bramhanaga 100 MW PP (Aggreko)	IPP	114'9.959	100	50	474521	Fuel conservation
36	Aurahati 100MW PP (Aggreko)	IPP	0.85'23+0.95'91	100	50	461089	Fuel conservation
37	Kodda 149 MW PP Unit-1 (Summit)	IPP	8'18.45+8.97	149	135	2378740	Engine problem
38	Gazipur 100 MW PP	RPCL	6'17.5	105	105	2334732	
39	Meghnaghat 104 MW PP (OPCL)	IPP	18.5'6	104	73	1438080	Fuel shortage
40	Manikganj 162MW PP(MPGL)	IPP	9'18	162	162	1743840	
41	Spectro Solar Plant Ltd.	IPP	35	35	0	185122	
42	Kanchan Purbachal Power Generation Ltd.	IPP	18.4'3	55	25	475560	Fuel shortage
Dhaka area Total				5847	2315	46706323	
43	Chattogram TPP-1	PDB	1'210	180	0	0	Machine problem
44	Chattogram TPP-2	PDB	1'210	180	0	0	Gas shortage
45	Racoon 25 MW PP	RPCL	3'8.9	25	17	318000	Engine problem
46	Takraf 20MW PP (Solaritech)	IPP	20	20	0	136755	
47	Palenga 50MW PP (Baraka)	IPP	8'6.98	50	38	722400	Engine problem
48	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2'40+3'50	230	151	3272671	Low water level
49	Sikalbaha 225MW	PDB	1'150+1'175	225	151	3532072	ST Under maint.
50	Sikalbaha Peaking GT	PDB	1'150	150	0	0	Under maint.
51	Sikalbaha 105 MW PP (Baraka Sikabaha)	IPP	6'17.5	105	105	1681083	
52	Hazibnagar 100 MW peaking PP	PDB	11'8.9	98	31	515520	Fuel shortage
53	Dohazari -Kalaish 100 MW Peaking	PDB	6'17	102	51	351433	Fuel shortage
54	Juldah 100 MW Unit-1 (Accorn)	NENP	8'13.45	100	55	883320	Fuel shortage
55	Juldah 100 MW PP Unit-3 (Accorn)	IPP	8'13.5	100	50	741120	Fuel shortage
56	Barakkunda 22 MW PP (Regent)	SIPP, PDB	8'2.90	22	0	0	Engine problem
57	Malancha, Ctr. EPZ Unit-1	IPP	5'8.73+9.34	0	3	388900	
58	Chattogram 108 MW PP (ECPV)	IPP	16'7	108	0	0	Fuel shortage
59	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	25441	
60	Anwara 300 MW PP (United)	IPP	17'17+24	300	300	3196091	
61	Jodiac Power	IPP	3'18.55+1'3.6	54	36	964477	Engine problem
62	Karnaphuli Power Ltd.	IPP	18.415'6+8.5	110	84	1855883	Engine problem
63	Juldah unit-2 (Accorn)	IPP	8'13.6	100	34	752640	
64	Anilima Energy Ltd.	IPP	8'21.2	116	107	2494036	Engine problem
65	Minshahi 150 MW	BPDB-RPCL	18.5'9	0	0	40145	On test.
Chattogram area Total				2382	1213	21674887	
66	Ashuganj TPP Unit- 3	APSCL	1'150	0	0	0	Contract Expired
67	Ashuganj TPP Unit- 4	APSCL	1'150	0	0	0	Contract Expired
68	Ashuganj TPP Unit- 5	APSCL	1'150	0	0	0	Gas shortage
69	Ashuganj 225 MW CCPP	APSCL	1'142+1'175	221	207	4127000	Gas shortage
70	Ashuganj 450 MW CCPP(North)	APSCL	1'360	360	290	7501300	Gas shortage
71	Ashuganj 450 MW CCPP(South)	APSCL	1'360	360	360	8099000	
72	Ashuganj 420 MW CCPP(East)	APSCL	284'1+136'1	284	0	0	On test.
73	Ashuganj 50 MW PP	APSCL	14'3.968	45	20	554328	Gas shortage
74	Ashuganj 55 MW PP (Precision)	QRPP	55	0	0	38880	Gas shortage
75	Ashuganj 195MW PP (APSCL-United)	IPP	20'9.73+1'16	195	8	167272	Gas shortage
76	Ashuganj 51 MW PP (Midland)	IPP	6'9.34	51	0	0	Gas shortage
77	Ashuganj 150MW PP (Midland)	IPP	23'7.015	150	53	963490	Fuel shortage
78	Titas 50 MW Peaking PP	PDB	6'8.92	52	43	559936	Engine problem
79	Chandpur 150 MW CCPP	PDB	1'106+1'57	163	50	1191010	Machine problem
80	Chandpur 200MW (Desh energy)	IPP	12'14.4	200	180	1623840	Engine problem
81	Feni 22MW PP (Doreen)	SIPP, PDB	8'2.90	22	22	48808	
82	Feni 11 MW PP (Doreen)	SIPP, REB	4'2.90	11	8	211500	
83	Import (Tripura)	Imported power	0	160	126	2680320	
84	Jangalia 33MW PP (Summit)	SIPP, PDB	4'8.73	33	22	627200	Engine problem
85	Jangalia 52 MW PP (Lakshmi)	IPP	8'9.92	36	36	345805	Fuel shortage
86	Qumilla 25 MW PP (Summit)	SIPP, REB	3'3.67+2'6.97	25	21	424480	Engine problem
87	Daudkandi 200 MW PP (B.Trac)	IPP	154'1.4	200	0	318912	Fuel conservation
88	Feni Lanka Power	IPP	7'18.415+1'9.78	114	114	738720	
89	Chowmuhani 113 MW	IPP	12'9.78+2'3.1	113	9	218400	Fuel shortage
90	Bharob 54.5 MW	IPP	3'18.2	54	35	608940	Engine problem
91	Chandpur 115 (Doreen)	IPP	4'18.5+2'22.5	115	104	865520	Engine problem
Qumilla Area Total				3169	1708	32482841	
92	RPCL 210MW CCPP	IPP	4'35+1'70	202	96	1865280	Gas shortage
93	Tangail 22 MW PP (Doreen)	SIPP, PDB	8'2.90	22	8	186516	Gas shortage
94	Jamalpur 95 MW PP(Powerpac)	IPP	12'8.924	0	0	0	Under maint.
95	Sarishabadi 3 MW Solar Plant	IPP	1'3	3	0	14000	
96	Mymensingh 200 MW PP (United)	IPP	9'78'21	200	96	1500000	Fuel shortage
97	Jamalpur 115 MW PP (United)	IPP	9'78'12	115	89	1483200	Engine problem
98	Sutiakhali 50 MW Solar PP	IPP	50	50	0	352770	
99	Tangail Pali Power Gen 22 MW	IPP	4'6.7	22	12	298560	Engine problem
Mymensingh Area Total				614	261	5700326	
100	Fenchugonj CCPP Phase-1	PDB	2'32+1'33	70	30	715000	Machine problem
101	Fenchugonj CCPP Phase-2	PDB	2'35+1'35	90	42	964920	Machine problem
102	Kushibara 163 MW CCPP (KP)	IPP	1'109+1'54	163	0	0	Gas shortage
103	Shajibazar 330 MW CCPP	PDB	3'110	330	0	0	Under maint.
104	Fenchugonj 51 MW PP (Barakattullah)	RPP	19'2.90	51	0	0	Gas shortage
105	Fenchugonj 44MW (Energyprima)	NENP	12'3.3+5'2	50	0	0	Gas shortage
106	Hidiganj 11MW PP Confidence-E	SIPP, REB	4'2.90	11	2	61056	Gas shortage
107	Shajibazar GTTP Unit- 3 & 9	PDB	2'35	66	63	1443840	
108	Shajibazar 86MW PP (Shajibazar)	RPP	32'2.90	86	81	654720	
109	Shajibazar 100 MW GTTP	PDB	1'100	100	0	0	Under maint.
110	Sylhet 225 MW CCPP	PDB	1'142+1'89	231	220	5265830	
111	Sylhet 20 MW GTTP	PDB	1'20	20	18	440000	
112	Sylhet 50MW PP (EPL)	NENP	2'72	50	0	0	Gas shortage
113	Shahjahanulla 25 MW PP	SIPP, REB	3'9.34	25	8	50544	Gas shortage
114	Bibiana-II 341 MW CCPP (Summit)	IPP	1'222+1'119	341	270	7070000	FGMO
115	Bibiyana-III 400 MW CCPP	PDB	400 MW	400	407	9617000	
116	Sylhet 10MW PP (Desh)	RPP	6'1.95	10	10	241920	
117	Bibiyana South 400 MW	PDB	400 MW	383	400	9274300	
Sylhet Area Total				2477	1551	35799130	
118	Bheramara GTTP Unit-3	PDB	1'20	16	0	0	Fuel shortage
119	Bheramara (HVDC)	Imported power	2'500	1000	904	20961454	
120	Khulna 115 PP MW (KPCL-2)	NENP	7'17	115	66	762240	Fuel shortage
121	Fandpur 50 MW Peaking PP	PDB	8'6.89	54	44	75360	Engine problem
122	Khulna 225 MW CCPP	NWPGCL	1'150+1'175	230	0	0	Fuel shortage
123	Gosairganj 100 MW Peaking PP	PDB	16'8.98	109	76	248960	Engine problem
124	Bheramara 410 MW CCPP	NWPGCL	1'278+1'132	410	160	4317120	Engine problem
125	Noapara 40 MW PP (Khanjahan Ali)	NENP	5'8.5	40	0	0	Fuel shortage
126	Noapara 100 MW PP (Bangla Trac)	IPP	70'1.4	100	0	78720	Fuel conservation
127	Rupsha 105 MW PP (Orion rupsha)	IPP	6'18.445	105	95	1244160	Engine problem
128	Madhumati 105 MW PP	NWPGCL	6'18	105	0	0	Fuel shortage
129	Mongia Orion 100 MW Solar PP	IPP	100	100	0	514080	
130	Khulna 330 MW CCPP (OIL)	BPDB	1'220+1'110	0	0	1387898	On test.
Rampal 1320 MW (BIFPCL)				0	0	0	On test.
Khulna Area Total				2384	1345	29599992	
131	Barisal 110 MW PP (Summit)	IPP	7'17.076	110	0	0	Line O/L
132	Bhola 33 MW PP (Venture)	NENP	1'34.50	40	18	387100	Engine problem
133	Bhola 225 MW CCPP	PDB	2'63+1'88	194	86	1827620	Gas shortage
134	Bhola 95 MW PP (Aggreko)	QRPP	96'1.10	0	0	0	Contract Expired
135	Payra 1320 MW	BCPCL	2'622	1244	880	19392200	Line O/L
136	Bhola Nutan Biddut BD LTD	IPP	220	220	221	4649973	
137	United Payra Power Ltd.	IPP	8'18.5+1'9.5	150	0	0	Line O/L
Barisal 307 MW				0	0	0	On test.
Barisal Area Total				1958	1055	28238893	
138	Baghabari 71 MW GTTP	PDB	1'71	71	0	0	Gas shortage
139	Baghabari 100 MW GTTP	PDB	1'100	100	0	0	Gas shortage
140	Baghabari 50 MW Peaking PP	PDB	6'8.9	52	32	123814	Engine problem
141	Bera 70 MW Peaking PP	PDB	9'8.29	71	20	87768	Engine problem
142	Amnara 50 MW PP(Sirsha)	QRPP	7'7.9	0	0	0	Contract Expired
143	Katakhali 50 MW PP (Northern)	IPP	6'8.9	50	25	451712	Engine problem
144	Katakhali 50 MW Peaking PP	PDB	6'8.7	50	40	155143	Engine problem
145	Sirajgonj Unit-1 225MW	NWPGCL	1'150+1'175	210	155	3907127	Gas shortage
146	Sirajgonj Unit-2 225MW	NWPGCL	1'150+1'175	220	0	0	
147	Sirajgonj Unit-3 225MW	NWPGCL	1'141	220	0	0	Gas shortage
148	Sirajgonj 400 MW CCPP Unit-4	NWPGCL	1'282+1'132	414	224	5581818	Gas shortage
149	Santalar 50 MW Peaking PP	PDB	6'8.7	50	34	131448	Engine problem