

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month November, 2022				Day : Sunday				Date : 13.11.22						
Probable Maximum Demand : 11400 MW				Probable Maximum Generation : 11530 MW				Rule Curve = 107.80 ft.						
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 92.98 ft Today = 92.60 ft										
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	12.11.22 (Yesterday)		13.11.22 (Today)		12.11.22 (Yesterday)		13.11.22 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Machines shut down (MW)		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW					
(A) Plants in operation:														
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0			260	Under project work	
2	a) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0				Line Overload	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180					
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0			365	Under maint.	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	3x3.35	108	108	68	72	71	72					
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105			Gas Shortage	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0				Contract Expired	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	279	226	220	230	134			Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225			Gas Shortage	
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0			115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412			Gas Shortage	
11	Siddhirganj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210			Gas Shortage	
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335			Gas Shortage	
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0	335			Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	4	10	10					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	66	75	70	75					
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	22	22	22					
17	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	50	53	52	53					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25					
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	0	33	33	33					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	41	49	50	50					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	105	105	105	105					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	133	132	80	132					
23	Karnalaghat 54 MW PP (Baraka Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	245	275	150	275					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	134	133	130	133					
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	156	0	100	150					
27	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	90	0	50	50					
28	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	90	0	50	50					
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	19	35	35					
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	55	55					
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	55	55	55	55					
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	144	140	144					
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	26	0	30	0					
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17					
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	80	88	88	88					
36	Meghnaghat 100 MW(IEL)	HFO (NENP)	12x8.9	100	100	58	83	80	83					
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0					
Dhaka Zone Total				6004	5847	2247	2124	2140	2401	1756	740			
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	152	150	150	150				Unit 1 under rehabilitation	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180			Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0			180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0					
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	10	10	10					
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	13	0	20	0					
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	26	39	26	40					
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	66	105	80	105					
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0			150	Under maint.	
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	150	151	150	150			74	STG Under maint.	
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	122	300	150	300					
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	50	25	50					
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	51	17	51					
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	30	20	30					
51	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0	22			Gas Shortage	
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	14	5	10					
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0	108			Fuel oil shortage	
53	Sikalbaha 54 MW PP(Jodiach Power)	HFO (IPP)	3x18.55+1x3.6	54	54	36	36	36	36					
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	53	72	70	72					
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	50	25	50					
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	33	55	33	55					
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	89	107	107	107					
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			17	0	0	0				on test	
Chattogram Zone Total				2442	2382	838	1220	929	1216	310	404			
58	Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134			Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	44	20	20	20					
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1x75	221	221	145	208	177	210					
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	315	270	265	270					
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	370	285	0	0					
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCCL)	1x284	284	284	0	0	0	0	284			Gas Shortage	
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	5	5	5	5	50			Gas Shortage	
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+1'16	195	195	8	8	150	195	187			Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	0	0	0	0	51			Gas Shortage	
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	35	55	33	50					
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	4	29	0	30					
69	Chandpur 150 MW CCPP	Gas (PDB)	1x106+1x57	163	163	50	49	50	50			57	ST Under maint.	
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	51	192	51	200					
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	22	22	22					
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	10	10	10					
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	16	33	33	33					
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	42	8	42					
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	19	21	21	21					
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+60x1.915+15x1.098	200	200	123	0	100	100					
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	17	114	17	114					
78	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	57	107	80	100					
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	17	17	17					
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	17	35	35	35					
**	Import (Tripura)	India		160	160	108	114	143	166					
Cumilla Zone Total				3193	3169	1419	1636	1237	1690	706	57			
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	72	74	70	75	128			Gas Shortage	
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	5	5	5	5					
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	49	99	50	100					
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	48	87	48	87	113			Fuel oil shortage	
85	Sarishab													

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	12.11.22 (Yesterday)		13.11.22 (Today)		12.11.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)		
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	G1- Under maint.	
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42		48	G1-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	42	53	30	51				
91	Kushiara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0	109	54	STG Under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	2	2	2	2				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	65	69	66	66				
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 66MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	81	0	80				
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	178	165	160	165		66	ST Under maint.	
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	19	19	19				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	8	8	8	17		Gas Shortage	
100	Bibi-ana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	275	270	275				
101	Bibi-ana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	416	414	400	400				
102	Bibi-ana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	300	300	300	300				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	28	29	21	29	21		Gas Shortage	
105	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12x3.4+5x2	50	50	41	47	40	47				
Sylhet Zone Total						2522	2477	1462	1544	1398	1524	147	638
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
107	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	170	220	210	220	190		Gas Shortage	
108	Fariapur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	40				
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	80	0	80				
110	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	0				
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	0	50				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	70	53	70				
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0				
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	63	0	100	0				
115	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	0	49	32	99				
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5x8.5	40	40	0	0	0	0	40		Fuel oil shortage	
	Rampal 1320 MW	Coal (BHPCL)				0	0	0	0				
	Khulna 330 MW CCPP	Gas/HSD (BPD)				235	235	180	235				
**	Bheramara (HVDC) India		1000	1000	905	905	916	922					
Khulna Zone Total						2388	2384	1373	1559	1491	1716	230	0
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	0	0		110	Line Overload	
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	15	18	12	18				
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	75	75	75	75	119		Gas Shortage	
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	500	680	800	800				
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0		150	Line Overload	
	Barisal Electric 307 MW	Coal (IPP)				0	0	0	0				
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	164	220	220	220				
Barishal Zone Total						1958	1958	754	993	1107	1113	119	260
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	24	0	25				
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	100				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	5	0	20		66	Under maint.	
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	0	0	85				
128	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	40				
129	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	34	34				
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	33	0	33				
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	145	141	150	150		69	Gas Shortage	
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0	0	220		Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0		220	Under maint.	
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	170	372	300	350	42		Gas Shortage	
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	0	22	22	22				
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	43	8	43				
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6x18.55	113	113	0	50	90	113				
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	50	94	95				
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0				
Rajshahi Zone Total						2129	2129	330	751	715	1121	502	286
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	80	82	80	82				
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	160	160	160	160			Under maint.	
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7x16x 2x3	113	113	0	113	113	113				
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Majpara, Talulia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0				
147	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6x20	115	115	0	55	113	115				
148	Lalmohana 30 MW Solar (Intraco)	Solar (IPP)	1x30	30	30	25	0	12	0				
Rangpur Zone Total						830	750	270	410	486	470	0	85
Sub-total: Plants in operation						22088	21710	8930.0	10514	9740	11530	4011	2470
(B) Plants under long term maintenance/ contract expired													
149	Jamulpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
150	Katpodi 52 MW PP (Sinha)	HFO (IPP)	7x7.50	51	0	0	0	0	0				
151	Bosila 108MW PPI (CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
153	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0				Contract Expired on 12/11/2020
154	Moulvibazar 30 MW PP (Sinnal)	HFO (QRPP)	7x7.79	50	0	0	0	0	0				Contract Expired on 11/01/2022
Sub-Total: Plants under long term maintenance/ contract expired						424	0	0	0	0	0		
Gross Total						22512	21710	8930	10514	9740	11530	4011	2470
(C) Actual data of 12.11.22 (Yesterday) Saturday :													
01.	Max. Demand at eve. peak (Generation end)	:	10514	MW, at =	19:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	10141	MW, at =	19:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	10514	MW, at =	19:00 hrs	Dhaka	4095	4095	0	Mymensingh	791	791	0
04.	Minimum Generation (Generation end)	:	7074	MW, at =	6:00 hrs	Chattogram	1065	1065	0	Sylhet	389	389	0
05.	Day-peak Generation (Generation end)	:	8930	MW, at =	12:00 hrs	Khulna	1129	1129	0	Barishal	260	260	0
06.	Evening-peak Generation (Generation end)	:	10514	MW, at =	19:00 hrs	Rajshahi	951	951	0	Rangpur	591	591	0
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at =	19:00 hrs	Cumilla	870	870	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7286	MW, at =	5:00 hrs								
09.	Generation shortfall at evening peak due to :	:											
	a) Gas/LF limitation	:	4011	MW		13.	Fuel cost :	a) Gas = 119347044 Taka		(c) Coal = 177629634 Taka			
	d) Coal supply Limitation	:	0	MW			b) Oil = 663004321 Taka			Total = 959809098 Taka			
	b) Low water level in Kaptai lake	:	0	MW									
	c) Plants under shut down/ maintenance	:	2470	MW		14.	Maximum Temperature in Dhaka was :	30.7° C					
10.	Total Energy (Generation + India Import)	:	209.56	MKWh		15.	Export through East-West interconnections :						
	By Gas =	106.975	MKWh	By Oil =	53.210	MKWh	At evening peak-hour	:	8930	MW, at	19:00 hrs		
	By Coal =	22.017	MKWh	By Hydro =	3.282	MKWh	Maximum	:	700	MW, at	7:00 hrs		
	By Solar =	1.282	MKWh				Energy	:	0	MKWh			
11.	Total Gas Supplied	:	818.55	MMCFD									
(D) Forecast of 13.11.22 (Today) Sunday :													
01.	Maximum Demand	:	11400	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	11530	MW	(Generation end)	05.	Total Generation	:	227.22	MKWh			
03.	Reserve / Shortage	:	130	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	28.8° C				

* Captive Power ** Imported Power
#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation