

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month November, 2022				Day : Tuesday				Date : 15.11.22				
Probable Maximum Demand : 10800 MW				Probable Maximum Generation : 11340 MW								
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 92.21 ft	Today = 91.82 ft	Rule Curve = 107.60 ft						
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	14.11.22 (Yesterday)		15.11.22 (Today)		14.11.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)		Description/ Remarks
(A) Plants in operation:												
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		Line Overload	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	3x3.35	108	108	12	67	40	70			
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0		Contract Expired	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	348	353	320	350			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	85	170	225	225	280	Gas Shortage	
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412	Gas Shortage	
11	Siddhirganj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	199	155	135	135	55	Gas Shortage	
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	Gas Shortage	
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0	335	Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	55	15	55			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	33	92	33	92			
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	0	22	22			
17	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	50	44	42	50			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25			
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	29	28	33	33			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	50	49	50	50			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	88	105	105			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	98	133	100	132			
23	Karnalaghat 54 MW PP (Baraka Energy)	HFO (IPP)	3x18.69	54	54	17	35	17	35			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	198	240	175	230			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	117	134	117	133			
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	204	37	200	150			
27	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	97	40	100	50			
28	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	91	30	100	50			
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	35	35	55			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	54	56	55	55			
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	162	140	162			
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	32	0	30	0			
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	0	17	17			
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	65	50	65	87			
36	Meghnaghat 100 MW(HEL)	HFO (NENP)	12x8.9	100	100	59	75	60	75			
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0			
Dhaka Zone Total			6004	5847	2235	2388	2471	2678	1522	740		
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	150	148	150	150		Unit 1 under rehabilitation	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	4	0	5	0				
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	17	17	17			
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	20	0	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	26	44	26	44			
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	68	86	68	86			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	152	151	150	150	74	STG Under maint.	
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	123	272	130	275			
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	40	25	50			
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	68	17	51			
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	29	23	20	30			
51	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0	22	Gas Shortage	
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	2	2	2			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0			
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	36	36	36	36			
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	63	92	70	91			
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	36	25	50			
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	33	55	33	55			
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	89	107	107	107			
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	6	0	0		on test	
Chattogram Zone Total			2442	2382	879	1183	901	1194	202	404		
58	Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	40	47	44	47			
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1x75	221	221	180	159	177	180			
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	335	325	320	320			
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	0	0	0	0			
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCCL)	1x284	284	284	0	0	0	0	284	Gas Shortage	
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	55	55	55	55			
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+1'16	195	195	187	189	150	150	6	Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	5	5	5	5	46	Gas Shortage	
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	68	99	65	99			
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	44	0	40			
69	Chandpur 150 MW CCPP	Gas (PDB)	1x106+1x57	163	163	50	49	50	50	57	ST Under maint.	
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	51	76	51	90			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	21	22	22			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	10	10	10			
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	8	15	33	33			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	19	8	35			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	15	21	21	21			
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+60x1.915+15x1.098	200	200	100	30	100	100			
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	17	17	17	17			
78	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	94	107	80	100			
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17			
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	18	104	35	104			
**	Import (Tripura)	India		160	160	104	126	143	166			
Cumilla Zone Total			3193	3169	1379	1535	1403	1661	470	57		
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	70	72	70	75	130	Gas Shortage	
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	5	5	5	5			
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	49	96	50	100			
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	48	86	48	87			
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
86	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	49	0	50	0				
87	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	6	24	6	24			
Mymensingh Zone Total			622	614	229	283	231	291	130	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	14.11.22 (Yesterday)		15.11.22 (Today)		14.11.22 (Yesterday)		Status of Machines under shut-down/ Maintenance			
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date		
						Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)				
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30			40	G1-1 Under maint.		
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42			48	G1-4 Under maint.		
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	27	27	27	27						
91	Kushiara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0	109		54	STG Under maint.		
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	2	2	2	2						
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	61	67	66	66						
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0			330	Under maint.		
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	81	0	80						
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	0	0	0	0						
97	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	18	19	19	19						
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10						
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	8	8	8	17			Gas Shortage		
100	Bibi-ana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	305	300	305						
101	Bibi-ana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	403	409	400	400						
102	Bibi-ana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	398	400	300	400						
103	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0			100	Under project work		
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	28	28	21	30	22			Gas Shortage		
105	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12x3.3+5x2	50	50	45	47	45	45						
Sylhet Zone Total						2522	2477	1371	1475	1270	1464	148	572		
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0						
107	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	180	165	170	180	245			Gas Shortage		
108	Fariapur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	51	0	51						
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	80	0	80						
110	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	0						
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	0	0	50					
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	48	0	70						
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0						
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	76	0	100	0						
115	Khulna 115 MW PP (KPC-2)	HFO (NENP)	7x17	115	115	0	32	0	49						
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5x8.5	40	40	0	0	0	0						
	Rampal 1320 MW	Coal (BIFPCL)				0	0	0	0						
	Khulna 330 MW CCPP	Gas/HSD (BPD)				200	237	180	235						
**	Bheramara (HVDC) India			1000	1000	898	898	915	917						
Khulna Zone Total						2388	2384	1354	1511	1365	1632	245	0		
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	0	0			110	Line Overload		
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	13	16	12	18						
119	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	88	87	88	88	107			Gas Shortage		
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	530	700	800	800						
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0			150	Line Overload		
	Barisal Electric 307 MW	Coal (IPP)				0	0	0	0						
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	222	220	220						
Barishal Zone Total						1958	1958	851	1025	1120	1126	107	260		
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71			Gas Shortage		
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100			Gas Shortage		
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	32	0	32						
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	100						
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	4	0	20			67	Under maint.		
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	70	0	70						
128	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	40	0	40						
129	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	8	34	34						
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	0	33						
131	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	148	164	150	150	46			Gas Shortage		
132	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0	0	220			Gas Shortage		
133	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220			Under maint.		
134	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	295	238	250	250	176			Gas Shortage		
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	8	18	22	22						
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8						
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	0	8						
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6x18.55	113	113	15	95	90	113						
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	3	76	35	76						
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0						
Rajshahi Zone Total						2129	2129	482	793	595	956	613	287		
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	84	0	0	0	85			Coal Shortage		
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85			Under Overhauling		
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	160	160	160	160						
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7x16x 2x3	113	113	13	113	113	113						
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
146	Majpara, Talulia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0						
147	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6x20	115	115	0	65	40	65						
148	Lalmohitha 30 MW Solar (Intraco)	Solar (IPP)	1x30	30	30	31	0	30	0						
Rangpur Zone Total						830	750	293	338	351	338	85	85		
Sub-total: Plants in operation						22088	21710	9073.0	10531	9707	11340	3522	2405		
(B) Plants under long term maintenance/ contract expired															
149	Jamulpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0						
150	Katpodi 52 MW PP (Sinha)	HFO (IPP)	7x7.50	51	0	0	0	0	0						
151	Bosila 108MW PPI (CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0						
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0						
153	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0					Contract Expired on 12/11/2020	
154	Amritnara 30 MW PP (Sinnal)	HFO (QRPP)	7x7.79	50	0	0	0	0	0					Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired						424	0	0	0	0	0				
Gross Total						22512	21710	9073	10531	9707	11340	3522	2405		
(C) Actual data of 14.11.22 (Yesterday) Monday :															
01.	Max. Demand at eve. peak (Generation end)	:	10531	MW, at =	18:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand at eve. peak (Sub-station end)	:	10256	MW, at =	18:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW		
03.	Highest Generation (Generation end)	:	10531	MW, at =	18:00 hrs	Dhaka	4004	4004	0	Mymensingh	790	790	0		
04.	Minimum Generation (Generation end)	:	6923	MW, at =	5:00 hrs	Chattogram	1245	1245	0	Sylhet	399	399	0		
05.	Day-peak Generation (Generation end)	:	9073	MW, at =	12:00 hrs	Khulna	1130	1130	0	Barishal	246	246	0		
06.	Evening-peak Generation (Generation end)	:	10531	MW, at =	18:00 hrs	Rajshahi	927	927	0	Rangpur	665	665	0		
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at =	18:00 hrs	Cumilla	851	851	0						
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7019	MW, at =	5:00 hrs										
09.	Generation shortfall at evening peak due to :	:				Total				10256	10256	0			
	a) Gas/LF limitation	:	3437	MW		13. Fuel cost : a) Gas = 122054348 Taka				(c) Coal = 183572313 Taka					
	d) Coal supply Limitation	:	85	MW		(b) Oil = 623485991 Taka				Total = 929112652 Taka					
	b) Low water level in Kaptai lake	:	0	MW		14. Maximum Temperature in Dhaka was : 30.3° C									
	c) Plants under shut down/ maintenance	:	2405	MW		15. Export through East-West interconnections :									
	Total Energy (Generation + India Import)	:	209.34	MWWh		At evening peak-hour : 9073 MW, at 18:00 hrs									
	By Gas = 108.043 MKWh	By Oil =	51.262	MKWh		Maximum : 970 MW, at 21:00 hrs									
	By Coal = 22.460 MKWh	By Hydro =	3.268	MKWh		Energy : 0 MKWh									
	By Solar= 1.469 MKWh														
11. Total Gas Supplied : 855.92 MMCFD															
(D) Forecast of 15.11.22 (															