

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 15-Nov-22

Page -2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CCPP-Unit-3 (GT	PDB	1'260	260	0	0	Under maint.
2	Ghorasal Repowered CCPP Unit-4	PDB	1'210	180	0	0	Line O/L
3	Ghorasal 365 MW CCPP Unit-7	PDB	1'243+1'122	365	0	0	Under maint.
	Ghorashal 78.5 MW PP(MAX)	QRPP	2'40	0	0	0	
4	Ghorashal 108MW PP (Regent)	IPP	34'3.35	108	72	1684227	Gas shortage
5	Haripur GTPP	SBU, PDB	2'32	20	0	0	Under maint.
6	Haripur 412 MW CCPP	EGCB	1'273+1'139	412	69	2304000	Synchronized at 14:58.
7	Haripur 360MW CCPP(HPL)	IPP	1'235+1'125	360	353	7966000	
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2'150+1'150	450	225	5157000	Gas shortage
9	Meghnaghat 100 MW(IEI)	NENP	12'8.9	100	75	1072320	Engine problem
10	Meghnaghat CCPP(Summit)	IPP	2'110+1'110	335	0	0	Gas shortage
11	Madanganj 102 PP(Summit)	NENP	6'17	102	0	0	Under maint.
12	Madanganj-55 MW PP(Summit)	IPP	3'17.08+1'11.3	55	55	1332995	
13	Keraniganj 100 MW PP (Powerpac)	QRPP	8'13.45	0	0	0	Contract Expired
14	Narsingdi 22 MW PP (Doreen)	SIPP, REB	8'2.90	22	22	459540	
15	210 MW Siddhirgonj TPP	PDB	1'210	115	0	0	Under maint.
16	Siddhirgonj 2'120 MW GTTP	EGCB	2'105	210	36	2111000	Gas shortage
17	Siddhirgonj 100 PP(Dutch Bangla)	NENP	12'8.9	100	82	1326720	Engine problem
18	Siddhirgonj 335 MW CCPP	EGCB	1'217+118	335	0	0	Gas shortage
19	Gagnagar 102 MW PP (Digital Power)	IPP	12'8.924	102	74	1070208	Engine problem
20	Katpotti 52 MW PP (Sirsha)	IPP	7'7.9	0	0	0	Fuel shortage
21	Kamalaghat 54 MW PP(Banco Energy)	IPP	3'18	54	35	591480	Fuel shortage
22	Kodda 150MW PP	BPDB-RPCL	9'17.08	149	133	1629120	Engine problem
23	Manikganj 55 MW PP (Northern)	IPP	3'19.3	55	35	811471	Engine problem
24	Nababganj 55 MW PP (Southern power)	IPP	3'19.3	55	35	925469	Engine problem
25	Bosila 108MW PP(CLC)	IPP	12'8.775+1'3.5	0	0	0	
26	Summit Power (Madhabdi+Ashulia)	SIPP, REB	3'3.67+4'8.73	80	51	1202820	Engine problem
27	Madona 33 MW PP(Summit)	SIPP, REB	4'8.73	33	25	638000	Engine problem
28	Rusganj 33 MW PP(Summit)	SIPP, REB	4'8.73	33	24	582700	Engine problem
29	Gazipur 52 MW PP	RPCL	6'8.9	52	49	647520	
30	Tongi 80 MW GTTP	PDB	1' 105	105	0	0	Under maint.
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18'17.076	300	233	3836400	Fuel shortage
32	Keraniganj 300 MW PP (APR)	IPP	256'1.4	300	99	826389	Fuel conservation
33	Bramhanagar 100 MW PP (Aggreko)	IPP	114'9.959	100	50	396767	Fuel conservation
34	Aurshat 100MW PP (Aggreko)	IPP	0.85'23+0.95'91	100	50	362763	Fuel conservation
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	8'18.45+8.97	149	135	2126016	Engine problem
36	Gazipur 100 MW PP	RPCL	6'17.5	105	88	1737852	Engine problem
37	Meghnaghat 104 MW PP (OPCL)	IPP	18.5'6	104	56	1307520	Fuel shortage
38	Manikgonj 162MW PP(MPGL)	IPP	9'18	162	162	1733760	
39	Spectro Solar Plant Ltd.	IPP	35	35	0	197969	
40	Kanchan Purbachal Power Generation Ltd.	IPP	18.4'3	55	17	302760	Fuel shortage
Dhaka area Total				5847	2520	48681506	
41	Chattoagram TPP-1	PDB	1'210	180	0	0	Machine problem
42	Chattoagram TPP-2	PDB	1'210	180	0	0	Gas shortage
43	Racozan 25 MW PP	RPCL	3'8.9	25	17	272278	Engine problem
44	Teknaf 20MW PP (Solaritech)	IPP	0	20	0	139860	
45	Palenga 50MW PP (Baraka)	IPP	8'6.98	50	30	549120	Engine problem
46	Kapita Hydro: Unit-1,2,3,4, 5	PDB	2'40+3'50	230	154	3340465	Low water level
47	Sikalbaha 225MW	PDB	1'150+1'175	225	151	3586705	ST Under maint
48	Sikalbaha Peaking GT	PDB	1'150	150	0	0	Under maint.
49	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	6'17.5	105	85	1397563	Engine problem
50	Hazibnagar 100 MW peaking PP	PDB	11'8.9	98	98	187038	Fuel shortage
51	Dohazari -Kalaish 100 MW Peaking	PDB	6'17	102	47	501148	Fuel shortage
52	Juldah 100 MW Unit-1 (Accorn)	NENP	8'13.45	100	55	867600	Fuel shortage
53	Juldah 100 MW PP Unit-3 (Accorn)	IPP	8'13.5	100	40	756480	Fuel shortage
54	Barabkundia 22 MW PP (Regent)	SIPP, PDB	8'2.90	22	0	0	Engine problem
55	Malancha, Ctr. EPZ Unit-1	IPP	5'8.73+9.34	0	2	88880	
56	Chattoagram 108 MW PP (ECVP)	PDB	16'7	108	0	0	Fuel shortage
57	Kapita 7 MW Solar PP	PDB	7.4 MW	7	0	25441	
58	Anwara 300 MW PP (United)	IPP	17'17+24	300	270	2908036	Engine problem
59	Jodiach Power	IPP	3'18.55+1'3.6	54	36	903527	Engine problem
60	Kanapathuli Power Ltd.	IPP	18.415'6+8.5	110	69	1482029	Fuel shortage
61	Juldah unit-2 (Accorn)	IPP	8'13.6	100	39	750720	
62	Anilima Energy Ltd.	IPP	8'21.2	116	107	2354782	Engine problem
63	Minshahi 150 MW	BPDB-RPCL	18.5'9	0	0	6500	On test.
Chattoagram area Total				2382	1127	20128142	
64	Ashuganj TPP Unit- 3	APSCL	1'150	0	0	0	Contract Expired
65	Ashuganj TPP Unit- 4	APSCL	1'150	0	0	0	Contract Expired
66	Ashuganj TPP Unit- 5	APSCL	1'150	134	0	0	Gas shortage
67	Ashuganj 225 MW CCPP	APSCL	1'142+1'175	221	200	4653000	FGMO
68	Ashuganj 450 MW CCPP(North)	APSCL	1'360	360	0	0	FGMO
69	Ashuganj 450 MW CCPP(South)	APSCL	1'360	360	295	6912000	FGMO
70	Ashuganj 420 MW CCPP(East)	APSCL	284'1+136'1	284	159	2496000	On test.
71	Ashuganj 50 MW PP	APSCL	14'3.968	45	47	879768	
72	Ashuganj 55 MW PP (Precision)	QRPP	15'1.4	55	5	360640	Gas shortage
73	Ashuganj 165MW PP (APSCL-United)	IPP	20'9.73+1'16	195	55	1689454	Gas shortage
74	Ashuganj 51 MW PP (Midland)	IPP	6'9.34	51	5	213048	Gas shortage
75	Ashuganj 150MW PP (Midland)	IPP	23'7.015	150	100	1711200	Fuel shortage
76	Titas 50 MW Peaking PP	PDB	6'8.92	52	36	298688	Engine problem
77	Chandpur 150 MW CCPP	PDB	1'106+1'57	163	40	1120430	Machine problem
78	Chandpur 200MW (Desh energy)	IPP	12'18.4	200	79	1528320	Engine problem
79	Feni 22MW PP (Doreen)	SIPP, PDB	8'2.90	22	20	487368	
80	Feni 11 MW PP (Doreen)	SIPP, REB	4'2.90	11	10	227520	
81	Import (Tripura)	Imported power	0	160	124	2780160	
82	Jangalia 33MW PP (Summit)	SIPP, PDB	4'8.73	33	15	513000	Engine problem
83	Jangalia 52 MW PP (Lakshmi)	IPP	8'9.92	52	26	332390	Fuel shortage
84	Qumilla 25 MW PP (Summit)	SIPP, REB	3'3.67+2'6.97	25	9	302900	Engine problem
85	Daudkandi 200 MW PP (B.Trac)	IPP	154'1.4	200	100	468480	Fuel conservation
86	Feni Lanka Power	IPP	7'18.415+1'9.78	114	17	429780	Fuel shortage
87	Chowmuhani 113 MW	IPP	12'9.78+2'3.1	113	107	1766520	Engine problem
88	Bharob 54.5 MW	IPP	3'18.2	54	17	444240	Engine problem
89	Chandpur 115 (Doreen)	IPP	4'18.5+2'22.5	115	87	1289280	Engine problem
Cumilla Area Total				3169	1563	30924186	
90	RPCL 210MW CCPP	IPP	4'35+1'70	202	42	1789440	Gas shortage
91	Tangail 22 MW PP (Doreen)	SIPP, PDB	8'2.90	22	0	149292	Gas shortage
92	Jamalpur 95 MW PP(Powerpac)	IPP	12'8.924	0	0	0	Under maint.
93	Sarishabadi 3 MW Solar Plant	IPP	1'3	3	0	13600	
94	Mymensingh 200 MW PP (United)	IPP	9'78'21	76	200	1327200	Fuel shortage
95	Jamalpur 115 MW PP (United)	IPP	9'78'12	115	98	1532400	Engine problem
96	Sutiakhali 50 MW Solar PP	IPP	50	50	0	299550	
97	Tangail Pali Power Gen 22 MW	IPP	4'6.7	22	12	217680	Engine problem
Mymensingh Area Total				614	228	5329162	
98	Fenchugonj CCPP Phase-1	PDB	2'32+1'33	70	30	715000	Machine problem
99	Fenchugonj CCPP Phase-2	PDB	2'35+1'35	90	42	953230	Machine problem
100	Kushibara 163 MW CCPP (KP)	IPP	1'109+1'54	163	0	0	Gas shortage
101	Shajibazar 330 MW CCPP	PDB	3'110	330	0	0	Under maint.
102	Fenchugonj 51 MW PP (Barakatullah)	RPP	19'2.90	51	11	429600	Gas shortage
103	Fenchugonj 44MW (Energyprima)	NENP	12'3.3+5'2	50	20	745128	Gas shortage
104	Hobiganj 11MW PP Confidence-E	SIPP, REB	4'2.90	11	2	61056	Gas shortage
105	Shajibazar GTTP Unit- 3 & 9	PDB	2'35	66	70	1556064	
106	Shajibazar 86MW PP (Shajibazar)	RPP	32'2.90	86	81	489600	
107	Shajibazar 100 MW GTTP	PDB	1'100	100	0	0	Under maint.
108	Sylhet 225 MW CCPP	PDB	1'142+1'89	231	140	999420	Machine problem
109	Sylhet 20 MW GTTP	PDB	1'20	20	18	437000	
110	Sylhet 50MW PP (EPL)	NENP	2'7.2	50	28	554120	Gas shortage
111	Shahjahanulla 25 MW PP	SIPP, REB	3'9.34	25	8	132104	Gas shortage
112	Bibiana-II 341 MW CCPP (Summit)	IPP	1'222+1'119	341	290	7083000	FGMO
113	Bibiyana-III 400 MW CCPP	PDB	400 MW	400	414	9500000	
114	Sylhet 10MW PP (Desh)	RPP	6'1.95	10	10	244260	
115	Bibiyana South 400 MW	PDB	400 MW	383	383	9121500	
Sylhet Area Total				2477	1547	33029172	
116	Bheramara GTTP Unit-3	PDB	1'20	16	0	0	Fuel shortage
117	Bheramara (HVDC)	Imported power	2'500	1000	905	20775272	
118	Khulna 115 PP MW (KPCL-2)	NENP	7'17	115	55	552000	Engine problem
119	Fandpur 50 MW Peaking PP	PDB	8'6.89	54	43	43200	Line O/L
120	Khulna 225 MW CCPP	NWPGCL	1'150+1'175	230	0	0	Fuel shortage
121	Gopalganj 100 MW Peaking PP	PDB	16'8.98	109	70	387968	Engine problem
122	Bheramara 410 MW CCPP	NWPGCL	1'278+1'132	410	145	4251456	Gas shortage
123	Noapara 40 MW PP (Khanjahan Ali)	NENP	5'8.5	40	0	0	Fuel shortage
124	Noapara 100 MW PP (Bangla Trac)	IPP	70'1.4	100	50	113280	Fuel conservation
125	Rupsha 105 MW PP (Orion rupsha)	IPP	6'18.445	105	80	682560	Engine problem
126	Madhumati 105 MW PP	NWPGCL	6'18	105	0	0	Fuel shortage
127	Mongia Orion 100 MW Solar PP	IPP	100	100	0	504720	
128	Khulna 330 MW CCPP (OIL)	BPDB	1'220+1'110	0	0	3131262	On test.
Rampal 1320 MW (BIFPCL)				0	0	0	On test.
Khulna Area Total				2384	134		