

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month November, 2022					Day : Friday				Date : 18.11.22					
Probable Maximum Demand : 10200 MW					Probable Maximum Generation : 11340 MW					Rule Curve = 107.30 ft.				
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 91.24 ft.					Today = 91.07 ft.				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	17.11.22 (Yesterday)		18.11.22 (Today)		17.11.22 (Yesterday)		18.11.22 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Machines shut down (MW)			
					Day	Evening	Day	Evening						
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	0	0	0	0				260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0					Line Overload	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180						
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0				365	Under maint.	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	3x43.35	108	108	70	71	70	71					
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0			105	Gas Shortage	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0				Contract Expired	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	322	307	300	307					
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225			225	Gas Shortage	
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0				115	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	371	372	350	372					
11	Siddhirganj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0			210	Gas Shortage	
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0			335	Gas Shortage	
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0			335	Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	41	66	33	66					
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	22	22	22					
17	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	52	47	42	47					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33					
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	24	24	20	24					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	41	49	50	50					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	105	105	105	105					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	98	133	100	133					
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	35	17	54					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	95	262	175	260					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	86	136	125	136					
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	40	20	100	150					
27	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	50	50	50	50					
28	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	50	50	50	50					
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	55	35	35	35					
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	35	35	35					
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	55	66	55	55					
32	Manikganj 162MW PP(MPL)	HFO (IPP)	9x18	162	162	162	162	162	162					
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	28	0	30	0					
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17					
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	71	78	75	78					
36	Meghnaghat 100 MW(HEL)	HFO (NENP)	12x8.9	100	100	78	83	70	83					
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0					
Dhaka Zone Total					6004	5847	2498	2718	2581	2855	1210	740		
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	46	80	80	80				Unit 1 under rehabilitation	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0			180	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0				180	
40	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0					
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	17	17	17					
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0					
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	14	44	26	44					
44	Sikalbaha 105 MW PP (Baraka Sikabaha)	HFO (IPP)	6x18.415	105	105	69	105	68	105					
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0			150	Under maint.	
46	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	152	150	150	150			75	STG Under maint.	
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	244	290	260	290					
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	40	25	40					
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	51	17	51					
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	23	50	20	40					
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0			22	Gas Shortage	
*	Malancha, Cig.EP2 (United)	Gas	5x8.73+3x9.34			0	2	10	20					
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0					
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	36	36	36					
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	73	91	70	91					
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	50	25	50					
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	22	44	33	44					
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107					
	Minshara 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0				on test	
Chattogram Zone Total					2442	2382	912	1157	969	1165	202	405		
58	Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0			134	Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	0	0	40	45			45	Gas Shortage	
60	Ashuganj 225 MW CAPP	Gas (APSCCL)	1x142+117.5	221	221	184	199	0	0					
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	310	295	300	300					
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	0	0	0	0			360	Minor Inspection	
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCCL)	1x284	284	284	288	268	288	288					
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	0	0	30	30			55	Gas Shortage	
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+11'16	195	195	0	0	8	8			195	Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	0	0	0	0			51	Gas Shortage	
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	62	87	65	87					
68	Titaz 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	36	37	0	37					
69	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	39	40	40	40			57	ST Under maint.	
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	51	79	51	200					
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22					
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8					
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	15	17	33	33					
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	28	8	28					
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	9	14	15	19					
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+6x1.515+15x1.098	200	200	10	40	100	100					
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	17	17	17	17					
78	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	80	107	80	107					
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17					
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	109	109	35	115					
**	Imphoct (Tripura)	India		160	160	110	124	143	165					
Cumilla Zone Total					3193	3169	1375	1508	1300	1666	480	417		
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	37	38	70	70			164	Gas Shortage	
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	10	9	9	9					
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	78	97	50	97					
84	Myemensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	81	85	75	85					
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0					
86	Sutiakehali 50 MW Solar PP	Solar (IPP)	1x50	50	50	47	0	50	0					
87	Tangail 22 MW PP(PPLGL)	HFO (IPP)	4x6.7	22	22	12	12	12	12					
Myemensingh Zone Total					622	614	267	241	288	273	164	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	17.11.22 (Yesterday)		18.11.22 (Today)		17.11.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gas/Coal/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening				
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	GT-1 Under maint.	
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	0	30		48	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	31	25	0	0				
91	Kushiara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0	109	54	STG Under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	2	2	2	2				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	62	68	66	66				
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	78	0	80				
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	20	65	80	80				
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	0	0	0	25		Gas Shortage	
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	280	280	300	300				
101	Bibiyan-II 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	423	422	400	400				
102	Bibiyan South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	21	28	0	0	22		Gas Shortage	
105	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12x3.3+5x2	50	50	47	47	0	0				
Sylhet Zone Total													
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0		156	572	
107	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	125	125	130	150	285		Gas Shortage	
108	Fairdipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	35	0	35				
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	52	0	70				
110	Khulna 225 MW CCPP	HSD (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0				
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	20	0	50				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	95	95	0	95				
113	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	0	0				
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	76	0	100	0				
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	49	16	115				
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5x8.5	40	40	0	18	0	8				
	Rampal 1320 MW	Coal (BIFPCL)				0	0	0	0				
	Khulna 330 MW CCPP	Gas/HSD (BPDB)				0	0	230	230				
**	Bheramara (HSDC)	India		1000	1000	904	904	922	922				
Khulna Zone Total				2388	2384	1200	1298	1398	1675	285	0		
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	0	0		110	Line Overload	
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	17	20	12	20				
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	87	152	120	150	42		Gas Shortage	
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	490	580	800	800				
121	Potukhalhi 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0		150	Line Overload	
	Barisal Electric 307 MW	Coal (IPP)				125	243	0	0				
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	167	108	100	108				
Barisal Zone Total				1958	1958	886	1103	1032	1078	42	260		
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	30	0	30				
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	10				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	4	0	20		67	Under maint.	
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	57	0	57				
128	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	40	0	40				
129	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	16	34	34	34				
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	34	0	34				
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	143	139	140	140	71		Gas Shortage	
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	0	0	0	0		220	Under maint.	
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	134	150	150	200	264		Gas Shortage	
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	15	14	17	18				
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	43	8	43				
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6x18.55	113	113	38	95	90	95				
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	75	94	85	94				
140	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	4	0	6	0				
Rajshahi Zone Total				2129	2129	436	745	541	826	726	287		
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	160	160	160	160				
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7x16x 2"3	113	113	106	113	90	113				
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0				
147	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6x20	115	115	37	113	67	113				
148	Lalmohini 30 MW Solar (Intraco)	Solar (IPP)	1x30	30	30	27	0	30	0				
Rangpur Zone Total				830	750	335	386	355	386	85	85		
Sub-total: Plants in operation				22088	21710	9295.0	10671	9750	11340	3350	2766		
(B) Plants under long term maintenance/ contract expired													
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
150	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
151	Bosila 108MW PP(PLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
153	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
154	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired				424	0	0	0	0	0				
Gross Total				22512	21710	9295	10671	9750	11340	3350	2766		
(C) Actual data of 17.11.22 (Yesterday) Thursday :													
01.	Max. Demand at eve. peak (Generation end)	:	10671	MW, at =	18:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	10337	MW, at =	18:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	10671	MW, at =	18:00 hrs		Dhaka	4131	4131		0	Mymensingh	774
04.	Minimum Generation (Generation end)	:	7056	MW, at =	5:00 hrs	Chattogram	1232	1232	0	Sylhet	386	386	0
05.	Day-peak Generation (Generation end)	:	9295	MW, at =	12:00 hrs	Khulna	1129	1129	0	Barisal	247	247	0
06.	Evening-peak Generation (Generation end)	:	10671	MW, at =	18:00 hrs	Rajshahi	949	949	0	Rangpur	640	640	0
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at =	18:00 hrs	Cumilla	849	849	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6877	MW, at =	5:00 hrs								
09.	Generation shortfall at evening peak due to :	:											
	a) Gas/LF limitation	:	3265	MW									
	d) Coal supply Limitation	:	85	MW									
	b) Low water level in Kaptai lake	:	0	MW									
	c) Plants under shut down/ maintenance	:	2766	MW									
10.	Total Energy (Generation + India Import)	:	211.76	MKWh									
	By Gas =	108.818	MKWh	By Oil =	54.657	14. Maximum Temperature in Dhaka was : 30.7° C							
	By Coal =	22.442	MKWh	By Hydro =	1.276	15. Export through East-West interconnections :							
	By Solar=	1.356	MKWh										
11.	Total Gas Supplied	:	840.29	MMCFD									
(D) Forecast of 18.11.22 (Today) Friday :													
01.	Maximum Demand	:	10200	MW (Generation end)	04. Maximum Load-shed : 0 MW At evening peak (Sub-station end)								
02.	Maximum Generation	:	11340	MW (Generation end)	05. Total Generation : 202.41 MKWh								
03.	Reserve / Shortage	:	1140	MW (Generation end)	06. Probable Max. Temperature in Dhaka : 28.2° C								