

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 19-Nov-22

Page -2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks	
			Unit No. X Capacity	MW	MW	KWH		
1	Ghorasal Repowered CAPP-Unit-3 (GT)	PDB	1*260	260	0	0	Under maint.	
2	Ghorasal Repowered CAPP-Unit-4	PDB	1*210	180	0	0	Line O/L	
3	Ghorasal 365 MW CAPP-Unit-7	PDB	1*243+1*122	365	0	0	Under maint.	
4	Ghorasal 78.5 MW PP(MAX)	QRPP	2*40	0	0	0		
5	Ghorasal 108MW PP (Regent)	IPP	34*3.35	108	72	1639272	Gas shortage	
6	Haripur GTPP	SBU, PDB	2*32	20	0	0	Under maint.	
7	Haripur 412 MW CAPP	EGCB	1*273+1*139	412	371	880640	Gas shortage	
8	Haripur 360MW CAPP(HPL)	IPP	1*235+1*125	360	281	729600	Gas shortage	
9	Meghnaghat 450 MW CAPP(MPL)	IPP	2*150+1*150	450	225	5250500	GT-2 S/D due to Gas shortage	
10	Meghnaghat 100 MW(IEEL)	NENP	12*8.9	100	69	672960	Fuel shortage	
11	Meghnaghat CAPP(Summit)	IPP	2*110+1*110	330	0	0	Gas shortage	
12	Madanagar 102 MW(Summit)	NENP	6*17	102	0	0	Under maint.	
13	Madanagar-55 MW PPS(Summit)	IPP	3*17.08+1*11.3	55	55	1169058		
14	Keraniganj 100 MW PP (Powerpac)	QRPP	8*13.45	0	0	0	Contract Expired	
15	Narsingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	19	398		
16	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Under maint.	
17	Siddhirgonj 2*120 MW GTPP	EGCB	2*105	210	0	0	Gas shortage	
18	Siddhirgonj 100 PP(Dutch) Bangla	NENP	12*8.9	100	70	765984	Fuel shortage	
19	Siddhirgonj 335 MW CAPP	EGCB	1*217+1*118	335	0	0	Gas shortage	
20	Gagnagar 102 MW PP (Digital Power)	IPP	12*8.924	102	50	811728	Fuel shortage	
21	Katipoti 52 MW PP (Sinha)	IPP	7*7.9	0	0	0	Fuel shortage	
22	Kamalaghat 54 MW PP(Banco Energy)	IPP	3*18	54	54	526320		
23	Kodda 150MW PP	BPDB-RPCL	9*17.08	150	133	886560	Engine problem	
24	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	488155		
25	Nabaganj 55 MW PP (Southern power)	IPP	3*19.3	55	35	804129	Engine problem	
26	Bosila 108MW PP(CLC)	IPP	12*8.775+1*3.5	0	0	0		
27	Summit Power (Madhabdi+Ashulia)	SIPP, REB	3*3.67+4*8.73	80	41	1150080	Engine problem	
28	Madhabdi 33 MW PP(Summit)	SIPP, REB	4*8.73	33	0	453200	Engine problem	
29	Ruaganj 30 MW PP(Summit)	SIPP, REB	4*8.73	30	24	675400	Engine problem	
30	Gazipur 52 MW PP	RPCL	6*8.9	52	49	562560	0.00	
31	Tongi 80 MW GTPP	PDB	1* 105	0	0	0	Under maint.	
32	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	171	3081164	Fuel shortage	
33	Keraniganj 300 MW PP (APR)	IPP	256*1.4	300	0	0	Fuel conservation	
34	Bramhanaga 100 MW PP (Aggreko)	IPP	11*9.959	100	0	0	Fuel conservation	
35	Auraha 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	0	Fuel conservation	
36	Kodda 149 MW PP Unit-1 (Summit)	IPP	8*18.45+8.97	149	128	1971936	Engine problem	
37	Gazipur 100 MW PP	RPCL	6*17.5	105	105	1602516		
38	Meghnaghat 104 MW PP (OPCL)	IPP	18.5*6	104	54	847680	Fuel shortage	
39	Manikganj 162MW PP(MPGL)	IPP	9*18	162	162	1765440		
40	Spectro Solar Plant Ltd.	IPP	35	35	0	174755		
41	Kanchan Flatbatal Power Generation Ltd.	IPP	18.4*3	55	17	430200	Fuel shortage	
Dhaka area Total				5847	2418	46280885		
41	Chattoagram TPP-1	PDB	1*210	180	0	0	Machine problem	
42	Chattoagram TPP-2	PDB	1*210	180	0	0	Gas shortage	
43	Raozan 25 MW PP	RPCL	3*8.9	25	17	196551	Engine problem	
44	Takraf 20MW PP (Solartech)	IPP	20	20	0	1066520		
45	Palenga 50MW PP (Baraka)	IPP	6*8.96	50	42	289920	Engine problem	
46	Kapali Hydro Unit-1,2,3,4, 5	PDB	2*40+3*50	230	46	888380	Low water level	
47	Sikalbaha 225MW	PDB	1*150+1*175	225	151	3558509	ST Under maint.	
48	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Under maint.	
49	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	6*17.5	105	105	1502109		
50	Hathazari -Kalaish 100 MW Peaking	PDB	11*9.9	102	34	467232	Fuel shortage	
51	Juldah 100 MW Unit-1 (Accorn)	NENP	6*17	102	51	464589	Fuel shortage	
52	Juldah 100 MW PP Unit-3 (Accorn)	IPP	8*13.5	100	33	602040	Fuel shortage	
53	Barabkunda 22 MW PP (Regent)	SIPP, PDB	6*2.90	22	0	0	Fuel shortage	
54	Chattoagram 108 MW PP (ECPV)	IPP	5*8.73+9.34	108	2	337920		
55	Kapali 7 MW Solar PP	PDB	7.4 MW	7	0	24723		
56	Anwara 300 MW PP (United)	IPP	17*17+24	300	289	3111273		
57	Jodiak Power	IPP	3*18.55+1*3.6	54	36	655985	Engine problem	
58	Kanapathu Power Ltd.	IPP	18.15*6+8.5	110	85	1841665	Fuel shortage	
59	Juldah unit-3 (Accorn)	IPP	8*13.5	100	36	730560		
60	Anlima Energy Ltd.	IPP	6*21.2	116	107	1891855	Engine problem	
Mirsharai 150 MW				BPDB-RPCL	18.5*9	0	0	On test.
Chattoagram area Total				2382	1074	17369231		
61	Ashuganj TPP Unit-3	APSCL	1*150	0	0	0	Contract Expired	
62	Ashuganj TPP Unit-4	APSCL	1*150	0	0	0	Contract Expired	
63	Ashuganj TPP Unit-5	APSCL	1*150	134	0	0	Gas shortage	
64	Ashuganj 225 MW CAPP	APSCL	1*142+1*75	221	0	0	Gas shortage	
65	Ashuganj 450 MW CAPP(North)	APSCL	1*360	360	0	0	Gas shortage	
66	Ashuganj 450 MW CAPP(South)	APSCL	1*360	360	260	6734000	Gas shortage	
67	Ashuganj 420 MW CAPP(East)	APSCL	284*1+136*1	284	377	9390909	On test.	
68	Ashuganj 50 MW PP	APSCL	14*3.968	45	47	602760		
69	Ashuganj 50 MW PP (Precision)	QRPP	15*14	55	20	303840	Gas shortage	
70	Ashuganj 195MW PP (APSCL-United)	IPP	20*9.73+1*16	195	0	0	Gas shortage	
71	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	0	0	Gas shortage	
72	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	67	1077236	Fuel shortage	
73	Titas 50 MW Peaking PP	PDB	6*8.92	52	37	233200	Engine problem	
74	Chandpur 150 MW CAPP	PDB	1*106+1*57	163	30	999990	Machine problem	
75	Chandpur 200MW (Desh energy)	IPP	1*214.4	200	200	1535040	High voltage	
76	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	21	476784		
77	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	8	183240	Engine problem	
78	Impoport (Tripura)	Imported power	0	160	126	2355840		
79	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	16	623100	Engine problem	
80	Jangalia 50 MW PP (Lakshmi)	IPP	6*8.92	52	42	271349	Engine problem	
81	Cumilla 25 MW PP (Summit)	SIPP, REB	3*3.67+2*6.97	25	21	445150	Engine problem	
82	Daudkandi 200 MW PP (B. Trac)	IPP	15*4.14	200	0	0	Fuel conservation	
83	Feni Lanka Power	IPP	7*18.415+1*9.78	114	0	145920	Fuel shortage	
84	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	106	950880	Engine problem	
85	Bharadwaj 54.5 MW	IPP	3*18.2	54	17	443520	Engine problem	
86	Chandpur 115 (Doreen)	IPP	4*18.5+2*22.5	115	115	1284320		
Cumilla Area Total				3169	1410	26157078		
87	RPCL 210MW CAPP	IPP	4*55+1*70	202	44	1735680	Gas shortage	
88	Tangal 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	11	280584	Gas shortage	
89	Jamalpur 95 MW PP (Powerpac)	IPP	12*8.924	0	0	0	Under maint.	
90	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	14000		
91	Mymensingh 200 MW PP (United)	IPP	9*78*21	85	200	800000	Engine problem	
92	Jamalpur 115 MW PP (United)	IPP	9*78*12	115	94	1321200	Engine problem	
93	Suliakhali 50 MW Solar PP	IPP	50	50	0	312020		
94	Tangal Pali Power Gen 22 MW	IPP	4*6.7	22	6	147120	Engine problem	
Mymensingh Area Total				614	240	4710604		
95	Fenchuganj CAPP Phase-1	PDB	2*32+1*33	70	0	436000	Machine problem	
96	Fenchuganj CAPP Phase-2	PDB	2*35+1*35	90	20	240600	Machine problem	
97	Kushara 163 MW CAPP (KP)	IPP	1*109+1*54	163	0	0	Gas shortage	
98	Shahjibazar 330 MW CAPP	PDB	3*110	330	0	0	Under maint.	
99	Fenchuganj 51 MW PP (Barakatullah)	RPP	19*2.90	51	0	0	Gas shortage	
100	Fenchuganj 44MW (Energyprima)	NENP	12*3.3+5.2	50	0	0	Gas shortage	
101	Haldiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	3	72576	Gas shortage	
102	Shahjibazar GTTP Unit-3 & 9	PDB	2*35	86	86	1439136		
103	Shahjibazar 86MW PP (Shahjibazar)	RPP	32*2.90	86	78	639360		
104	Shahjibazar 100 MW GTTP	PDB	1*100	100	0	0	Under maint.	
105	Sylhet 225 MW CAPP	PDB	1*142+1*89	231	127	2689820	Gas shortage	
106	Sylhet 20 MW GTTP	PDB	1*20	20	0	0	Gas shortage	
107	Sylhet 50MW PP (EPL)	NENP	2*25	50	10	375400	Gas shortage	
108	Shahjibazar 25 MW PP	SIPP, REB	3*9.34	25	0	0	Gas shortage	
109	Bitiana-II 341 MW CAPP (Summit)	IPP	1*222+1*119	341	270	7025500	FGMO	
110	Bitiana-III 400 MW CAPP	PDB	400 MW	400	420	9072000		
111	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	0	0		
112	Bitiana South 400 MW	PDB	400 MW	383	398	8895500		
Sylhet Area Total				2477	1392	38868892		
113	Bheramara GTTP Unit-3	PDB	1*20	16	0	0	Fuel shortage	
114	Bheramara (HVDC)	Imported power	2*500	1000	903	16529454		
115	Khulna 115 PP MW (KPCL-2)	NENP	7*17	115	49	480000	Line O/L	
116	Fariapur 50 MW Peaking PP	PDB	6*8.89	54	45	32160	Line O/L	
117	Khulna 225 MW CAPP	NWPGCL	1*150+1*75	225	0	0	Fuel shortage	
118	Casapara 100 MW Peaking PP	PDB	1*6.98	100	50	189056	High voltage	
119	Bheramara 410 MW CAPP	NWPGCL	1*278+1*132	410	150	4301280	Gas shortage	
120	Noapara 40 MW PP (Khanjahan Ali)	NENP	5*8.5	40	8	10125	Fuel shortage	
121	Noapara 100 MW PP (Bangla Trac)	IPP	70*1.4	100	0	0	Fuel conservation	
122	Rupsha 105 MW PP (Orion rupsha)	IPP	6*18.445	105	69	1177440	Engine problem	
123	Madhumati 100 MW PP	NWPGCL	6*16	100	0	0	Fuel shortage	
124	Mongia Orion 100 MW Solar PP	IPP	100	100	0	521280		
125	Khulna 330 MW CAPP (DIL)	BPDB	1*220+1*110	0	0	0	On test.	
126	Rampal 1320 MW (BIFPCL)	NTPC&BPDB	0	0	0	0	On test.	
Khulna Area Total				2384	1274	23240795		
127	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	0	0	Line O/L	
128	Bhola 53 MW PP (Venture)	NENP	1*34.50	40	18	338100	Engine problem	
129	Bhola 225 MW CAPP	PDB	2*63+1*68	114	119	3081672	Contract Expired	
130	Bhola 95 MW PP (Aggreko)	QRPP	96*1.10	0	0	0	Contract Expired	
131	Payra 1320 MW	BCPCL	2*622	1244	670	19268500	Line O/L	
132	Bhola Nutan Biddut BD LTD	IPP	220	220	108	2616355		
133	United Payra Power Ltd.	IPP	6*18.5+1*9.5	150	0	0	Line O/L	
Barisal 307 MW				0	229	1549700	On test.	
Barisal Area Total				1958	1144	26854327		
134	Baghabari 71 MW GTTP	PDB	1*71	71	0	0	Gas shortage	
135	Baghabari 100 MW GTTP	PDB	1*100	100	0	0	Gas shortage	
136	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	30	40752	Engine problem	
137	Bera 70 MW Peaking PP	PDB	9*8.29	71	0	6902		
138	Amnara 50 MW PP (Sinha)	QRPP	7*7.9	0	0	0	Contract Expired	
139	Katakhali 50 MW PP (Northern)	QRPP	6*8.9	50	42	275170	Engine problem	
140	Katakhali 50 MW Peaking PP	PDB	6*8.7	50	32	26255	Engine problem	
141	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	161	4035509	Gas shortage	
142	Sirajgonj Unit-2 225MW	NWPGCL	1*150+1*75	220	0	0		
143	Sirajgonj Unit-3 225MW	NWPGCL	1*141	220	0	0	Gas shortage	
144	Sirajgonj 450 MW CAPP Unit-4	NWPGCL	1*262+1*132	204	414	5612000	Gas shortage	
145	Santaliar 50 MW Peaking PP	PDB	6*8.7	50	33	33655		
146	Bogra 22 MW PP (GBB)	RPP	6*4	22	16	443280	Engine problem	
147	Bogra 20 MW PP (Energyprima)	NENP	5*3.3+5*2	0	0	0		
148	Ullapara 11 MW PP (Summit)	SIPP, REB	4*2.90	11	11	230346		
149	Natore 53 MW PP (Rajajika)	IPP	6*8.92	52	24	25090	Line O/L	
1								