

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month November, 2022					Day : Tuesday				Date : 22.11.22			
Probable Maximum Demand : 10800 MW					Probable Maximum Generation : 11313 MW				Rule Curve = 107.10 ft.			
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 90.91 ft				Today = 90.89 ft			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	21.11.22 (Yesterday)		22.11.22 (Today)		21.11.22 (Yesterday)		22.11.22 (Today)	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Machines shut down (MW)	
					Day	Evening	Day	Evening			Description/ Remarks	Probable start-up date
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0			Line Overload
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	Under maint.
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	3x43.35	108	108	65	71	71	71			
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	Gas Shortage
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0			Contract Expired
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	274	252	255	255	108		Gas Shortage
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225		Gas Shortage
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	309	278	300	280	134		Gas Shortage
11	Siddhirganj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335		Gas Shortage
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0	335		Gas Shortage
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	45	45	45	45			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	24	50	24	50			
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	22	22	22			
17	Summit Power,(Madhabadi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	43	42	49	49			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	16	17	31	33			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	42	48	42	50			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	105	105	105	105			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	98	133	98	133			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	35	17	35			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	113	240	97	285			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	142	149	125	149			
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	103	109	100	150			
27	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	98	50	50	50			
28	Auraihat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	72	50	0	50			
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	35	35	55			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	17	17	17			
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	145	162	90	162			
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	30	0	30	0			
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17			
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	76	84	75	84			
36	Meghnaghat 100 MW(HEL)	HFO (NENP)	12x8.9	100	100	84	90	80	90			
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0			
Dhaka Zone Total			6004	5847	2463	2594	2248	2730	1452	740		
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	46	46	46	46	184		Low water level
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	4	0	5	0				
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	17	17	17			
42	Teknaf 20MW PP (SolarTech)	Solar (IPP)	1x20	20	20	19	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	18	37	26	44			
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	51	95	51	105			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.
46	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	151	152	150	150	73		STG Under maint.
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	255	283	260	300			
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	40	25	50			
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	17	51			
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	24	16	20	34			
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0	22		Gas Shortage
*	Malancha, Cig.EP2 (United)	Gas	5x8.73+3x9.34			2	2	2	2			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0			
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	36	36	36	36			
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	73	91	70	91			
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	43	25	50			
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	22	44	22	44			
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107			
	Minsharai 150 MW	HFO (BRPgen)	9x18.5			7	0	0	0			on test
Chattogram Zone Total			2442	2382	882	1060	899	1127	386	403		
58	Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	40	48	40	40			
60	Ashuganj 225 MW CAPP	Gas (APSCCL)	1x142+117.5	221	221	0	0	0	0			
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	250	240	300	300			
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	0	0	0	0		360	Minor Inspection
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCCL)	1x284	284	284	406	402	400	400			
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	5	15	15	15	40		Gas Shortage
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+11'16	195	195	0	0	0	0	195		Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	0	0	0	0	51		Gas Shortage
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	65	117	75	115			
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	22	30	0	35			
69	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	30	30	68	68	57		ST Under maint.
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	65	51	100			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8			
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	14	15	33	33			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	8	8	8			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	15	15	15	15			
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+6x1.515+15x1.098	200	200	0	70	100	100			
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	17	17	0	0			
78	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	108	107	108	108			
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	32	17	35			
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	115	115	115	115			
**	Import (Tirupura)	India		160	160	116	122	143	165			
Cumilla Zone Total			3193	3169	1275	1478	1518	1682	420	417		
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	38	35	70	100	167		Gas Shortage
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	11	11	11	11			
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	68	96	50	99			
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	76	86	70	95			
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
86	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	45	0	50	0			
87	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	6	12	12	12			
Mymensingh Zone Total			622	614	246	240	265	317	167	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	21.11.22 (Yesterday)		22.11.22 (Today)		21.11.22 (Yesterday)		Status of Machines under shut-down/ Maintenance									
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Water Limitation MW		Machines shut down (MW)	Description/ Remarks	Probable start-up date							
						Day	Evening	Day	Evening												
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	0	0	0	0		70	GT-1 Under maint.									
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	43	43	43	43		47	GT-4 Under maint.									
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	0	0	50	50												
91	Kushiara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0	109	54	STG Under maint.									
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	3	3	3	3												
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	56	66	70	70												
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.									
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	81	0	78												
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	164	164	177	177												
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	19	19												
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	0	10	10												
99	Shahjahanula 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	0	22	22	25		Gas Shortage									
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	280	280	0	0												
101	Bibiyan-II 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	420	408	400	400												
102	Bibiyan South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400												
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work									
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	0	0	20	20	50		Gas Shortage									
105	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12'3.3x5'2	50	50	0	0	33	33												
Sylhet Zone Total						2522	2477	1366	1445	1247	1325	184	601								
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0												
107	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	155	145	175	175	265		Gas Shortage									
108	Fairdipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	31	0	45												
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	75	0	75												
110	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	0												
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	0	50												
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	80	64	94												
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0												
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	77	0	100	0												
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	107	16	115												
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	16	0	16												
	Rampal 1320 MW	Coal (BIFPCL)				0	0	0	0												
	Khulna 330 MW CCPP	Gas/HSD (BPDB)				0	0	0	0												
**	Bheramara (HVDC)	India		1000	1000	896	897	913	913												
Khulna Zone Total						2388	2384	1145	1351	1268	1483	265	0								
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	0	0		110	Line Overload									
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	16	27	15	25												
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	135	130	130	130	64		Gas Shortage									
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	540	640	800	800												
121	Potukhalhi 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0		150	Line Overload									
	Barisal Electric 307 MW	Coal (IPP)				174	242	190	200												
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	109	109	110	110												
Barisal Zone Total						1958	1958	974	1148	1245	1265	64	260								
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage									
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage									
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	31	0	30												
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	10												
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	4	0	20		67	Under maint.									
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	80	0	90												
128	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	0	40												
129	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	50	25	25	50												
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	0	35												
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	144	152	170	175	58		Gas Shortage									
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage									
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0		220	Under maint.									
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	220	205	255	255	209		Gas Shortage									
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	15	16	18	18												
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11												
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	43	8	43												
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6'18.55	113	113	37	113	90	113												
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	85	85	113												
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0												
Rajshahi Zone Total						2129	2129	517	829	668	1003	658	287								
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage									
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling									
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	160	160	160	160												
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0												
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	34	113	90	113												
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0												
146	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0												
147	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6'20	115	115	35	108	70	108												
148	Lalmohini 30 MW Solar (Intraco)	Solar (IPP)	1'30	30	30	32	0	30	0												
Rangpur Zone Total						830	750	267	381	358	381	85	85								
Sub-total: Plants in operation						22088	21710	9135.0	10526	9716	11313	3681	2793								
(B) Plants under long term maintenance/ contract expired																					
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0												
150	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0												
151	Bosila 108MW PP(PLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0												
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0												
153	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020									
154	Ammura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022									
Sub-Total: Plants under long term maintenance/ contract expired						424	0	0	0	0	0	0	0								
Gross Total						22512	21710	9135	10526	9716	11313	3681	2793								
(C) Actual data of 21.11.22 (Yesterday) Monday :																					
01.	Max. Demand at eve. peak (Generation end)	:	10526	MW, at =	18:00 hrs																
02.	Max. Demand at eve. peak (Sub-station end)	:	10280	MW, at =	18:00 hrs																
03.	Highest Generation (Generation end)	:	10526	MW, at =	18:00 hrs																
04.	Minimum Generation (Generation end)	:	7024	MW, at =	5:00 hrs																
05.	Day-peak Generation (Generation end)	:	9135	MW, at =	12:00 hrs																
06.	Evening-peak Generation (Generation end)	:	10526	MW, at =	18:00 hrs																
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at =	18:00 hrs																
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6884	MW, at =	5:00 hrs																
09.	Generation shortfall at evening peak due to :	:																			
	a) Gas/LF limitation	:	3412	MW																	
	d) Coal supply Limitation	:	85	MW																	
	b) Low water level in Kaptai lake	:	184	MW																	
	c) Plants under shut down/ maintenance	:	2793	MW																	
10.	Total Energy (Generation + India Import)	:	209.07	MKWh																	
	By Gas =	105.968	MKWh	By Oil =	54.225	MKWh															
	By Coal =	24.411	MKWh	By Hydro =	1.070	MKWh															
	By Solar =	1.411	MKWh																		
11.	Total Gas Supplied	:	804.93	MMCFD																	
Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :																					
						Demand MW	Supply MW	Load Shed MW		Zone	Demand MW	Supply MW	Load Shed MW								
						Dhaka	3986	3986	0	Mymensingh	776	776	0								
						Chattogram	1286	1286	0	Sylhet	389	389	0								
						Khulna	1139	1139	0	Barisal	252	252	0								
						Rajshahi	933	933	0	Rangpur	677	677	0								
						Cumilia	843	843	0												
										Total	10280	10280	0								
						13.	Fuel cost :	(a) Gas = 103909369 Taka (b) Oil = 728574901 Taka		(c) Coal = 164888141 Taka Total = 997372411 Taka		Taka	Taka								
						14.	Maximum Temperature in Dhaka was : 30.9° C														
						15.	Export through East-West interconnections :														
							At evening peak-hour		:	9135	MW, at	18:00 hrs									
							Maximum		:	566	MW, at	7:00 hrs									
							Energy		:	0	MKWh										
(D) Forecast of 22.11.22 (Today) Tuesday :																					
01.	Maximum Demand	:	10800	MW (Generation end)			04.	Maximum Load-shed		:	0	MW	At evening peak (Sub-station end)								
02.	Maximum Generation	:	11313	MW (Generation end)			05.	Total Generation		:	214.51	MKWh									
03.	Reserve / Shortage	:	513	MW (Generation end)			06.	Probable Max. Temperature in Dhaka :		:	28.1° C										