

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month November, 2022			Day : Thursday				Date : 24.11.22					
Probable Maximum Demand : 10500 MW			Yesterday = 90.85 ft				Today = 90.83 ft				Rule Curve = 106.70 ft	
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	23.11.22 (Yesterday)		24.11.22 (Today)		23.11.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)		Description/ Remarks
(A) Plants in operation:												
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work
2	a) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0			Line Overload
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
3	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	Under maint.
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	3x3.35	108	108	65	71	71	71			
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	Gas Shortage
6	Harijpur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			Contract Expired
7	Harijpur 360MW CAPP(HPL)	Gas (IPP)	1x235+1x125	360	360	288	289	270	280	71		Gas Shortage
8	Meghnaghat 450 MW CAPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225		
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
10	Harijpur 412 MW CAPP	Gas (EGCB)	1x273+1x139	412	412	337	325	320	310	87		Gas Shortage
11	Siddhirganj 2' 120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage
12	Siddhirganj 335 MW CAPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335		Gas Shortage
13	Meghnaghat CAPP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0	335		Gas Shortage
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	45	45	45	45			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	33	24	50			
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	16	19	22	22	22		
17	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x3.73	80	80	50	44	45	49			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	30	30	33	33			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	34	50	50	50			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	105	105	105	105			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	116	133	115	133			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	97	145	97	275			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	126	125	135	149			
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	104	102	100	150			
27	Bramhanaganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	90	50	50	50			
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	87	50	50	50			
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	55	17	55			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	17	17	17			
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	139	17	162			
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	29	0	30	0			
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17			
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	67	85	80	90			
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	80	81	50	92			
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0			
Dhaka Zone Total			6004	5847	2315	2557	2250	2802	1368	740		
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	46	46	46	46	184		Low water level
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0			
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	0	17	17			
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	38	0	19	43			
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	68	105	68	105			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.
46	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	151	151	150	150	74		STG Under maint.
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x6.04	300	300	70	271	300	300			
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	12	12	12			
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	51	17	51			
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	28	46	48	55			
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0	22		Gas Shortage
*	Malancha, Cig.EP2 (United)	Gas	5x8.73+3x9.34			2	2	2	2			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0			
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	36	36	36	36			
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	53	91	53	91			
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	10	12	12			
56	Juldah 100 MW Unit-1 (Acom)	HFO (ORPP)	8x13.45	100	100	22	10	10	10			
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	79	89	89			
**	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			5	0	0	0			on test
Chattogram Zone Total			2442	2382	733	910	904	1019	386	404		
58	Ashuganj TPP Unit- 5	Gas (APSCl)	1 x 150	150	134	0	0	0	0	134		Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCl)	14x3.968	53	45	45	44	44	44			
60	Ashuganj 225 MW CAPP	Gas (APSCl)	1x142+1*75	221	221	0	0	0	0	221		Minor Inspection
61	Ashuganj 450 MW CAPP(South)	Gas (APSCl)	1x360	360	360	250	240	280	280			
62	Ashuganj 450 MW CAPP(North)	Gas (APSCl)	1x361	360	360	0	0	0	0	360		Minor Inspection
63	Ashuganj 420 MW CAPP(East) GT	Gas (APSCl)	1x284	284	284	407	432	400	400			
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	30	30	30	30	25		Gas Shortage
65	Ashuganj 195MW PP (APSCl-United)	Gas (IPP)	20*9.73+1*116	195	195	0	0	0	0	195		Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	5	5	5	5	46		Gas Shortage
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	87	105	85	115			
68	Tilas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	38	30	0	30			
69	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	76	70	78	78	57		ST Under maint.
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	51	134	51	200			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	20	22	22			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	10	10	10			
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	16	21	33	33			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	12	14	8	8			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	15	15	15	15			
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	86x1.4+6x1.515+15x1.098	200	200	50	100	100	100			
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	17	0			
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	94	109	104	104			
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	33	17	34			
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	18	98	115	115			
**	Impoport (Tripura)	India		160	160	100	116	143	165			
Cumilla Zone Total			3193	3169	1341	1626	1557	1788	400	638		
81	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	37	35	40	40	167		Gas Shortage
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	8	8	10	10			
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	47	59	49	59			
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	48	57	48	58			
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
86	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	49	0	50	0			
87	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	12	12	12	12			
Mymensingh Zone Total			622	614	203	171	211	179	167	0		

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	23.11.22 (Yesterday)		24.11.22 (Today)		23.11.22 (Yesterday)	24.11.22 (Yesterday)	Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)				Gas/Coal/Water Limitation MW	Machines shut down (MW)	Description/ Remarks
					Day	Evening	Day	Evening					
88	Fenchugonj CCGP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	GT-1 Under maint.	
89	Fenchugonj CCGP Phase-2	Gas (PDB)	2x35+1x35	104	90	43	43	43	43		47	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	34	53	50	50				
91	Kushiara 163 MW CCGP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0	109	54	STG Under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	3	3	3	3				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	61	66	66	66				
94	Shahjibazar 330 MW CCGP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	84	0	84				
96	Sylhet 225 MW CCGP	Gas (PDB)	1x142+1x89	231	231	178	90	90	90				
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	19	19				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
99	Shahjahanula 25 MW PP	Gas (CIPP, REB)	3x3.34	25	25	21	16	21	24				
100	Bibiana-II 341 MW CCGP (Summit)	Gas (IPP)	1x222+1x119	341	341	0	0	0	0		341	Major Inspection 31/12/2022	
101	Bibiyana-III 400 MW CCGP	Gas (PDB)	1x285+1x115	400	400	418	419	400	400				
102	Bibiyana South 383 MW CCGP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	26	26	25	25				
105	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12x3.34x52	50	50	25	35	35	35				
Sylhet Zone Total					2522	2477	1267	1293	1192	1279	109	912	
106	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
107	Bheramara 410 MW CCGP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	150	155	160	150	255		Gas Shortage	
108	Fairdipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	45	0	50				
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	46	0	75				
110	Khulna 225 MW CCGP	HSD (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0				
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	10	0	50				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	35	74	54	94				
113	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	0	0				
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	77	0	100	0				
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	83	66	115				
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	32	0	32				
	Rampal 1320 MW	Coal (BIFPCL)				0	0	0	0				
	Khulna 330 MW CCGP	Gas/HSD (PBDB)				0	0	0	0				
**	Bheramara (HVDC)	India		1000	1000	894	895	912	912				
Khulna Zone Total					2388	2384	1156	1340	1292	1478	255	0	
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	0	0		110	Line Overload	
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	14	18	15	20				
119	Bhola 225 MW CCGP	Gas (PDB)	2x63+1x68	194	194	130	127	130	130	67		Gas Shortage	
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	650	740	850	850				
121	Potukhali 150MW PP (LUPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0		150	Line Overload	
	Barisal Electric 307 MW	Coal (IPP)				141	170	190	300				
122	Bhola 220MW CCGP (Nutan Bidvut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	0	0	0	0				
Barishal Zone Total					1958	1958	935	1055	1185	1300	67	260	
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	31	0	34				
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	1	0	0				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	4	0	20				
127	Chapanawabaganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	88	0	80				
128	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	40	0	40				
129	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	25	50	34	34				
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	35	0	34				
131	Sirajgonj 225MW CCGP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	164	160	165	160	50		Gas Shortage	
132	Sirajgonj 225MW CCGP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
133	Sirajgonj 225MW CCGP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	0	0	0	0		220	Under maint.	
134	Sirajgonj 400 MW CCGP Unit-4	Gas (IPP)	1x282+1x132	414	414	200	200	190	190	214		Gas Shortage	
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	15	17	19	19				
136	Lillapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	43	35	43				
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	37	95	35	95				
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	36	94	70	113				
140	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	5	0	6	0				
Ratahahi Zone Total					2129	2129	493	869	565	873	655	220	
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Storage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	160	160	160	160				
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2'3	113	113	33	81	34	113				
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Majpara, Tazula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0				
147	Thekugaon 115MW PP (Energypac)	HFO (IPP)	6'20	115	115	35	94	50	115				
148	Lalmohar 30 MW Solar (Intraco)	Solar (IPP)	1'30	30	30	7	0	30	0				
Rangpur Zone Total					830	750	241	335	282	388	85	85	
Sub-total: Plants in operation					22088	21710	8684.0	10156	9438	11106	3492	3259	
(B) Plants under long term maintenance/ contract expired													
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
150	Katpohi 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
151	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
153	Boogra 20 MW PP (Energyprima)	Gas (NENP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
154	Ammura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired					424	0	0	0	0	0	0	0	
Gross Total					22512	21710	8684.0	10156	9438	11106	3492	3259	
(C) Actual data of 23.11.22 (Yesterday) Wednesday :													
01.	Max. Demand at eve. peak (Generation end)	:	10245	MW, at =	18:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	9996	MW, at =	18:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	10156	MW, at =	18:00 hrs	Dhaka	3884	3872	12	Mymensingh	759	689	70
04.	Minimum Generation (Generation end)	:	6735	MW, at =	5:00 hrs	Chattogram	1126	1126	0	Sylhet	376	376	0
05.	Day-peak Generation (Generation end)	:	8684	MW, at =	12:00 hrs	Khulna	1121	1121	0	Barishal	236	236	0
06.	Evening-peak Generation (Generation end)	:	10156	MW, at =	18:00 hrs	Rajshahi	976	976	0	Rangpur	681	681	0
07.	Evening Peak Load-shed (Sub-station end)	:	82	MW, at =	18:00 hrs	Cumilla	837	837	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6604	MW, at =	5:00 hrs	Total 9996 9914 82							
09.	Generation shortfall at evening peak due to :	:				(a) Gas = 103358634 Taka (c) Coal = 181055913 Taka							
	a) Gas/LF limitation	:	3223	MW		(b) Oil = 670728566 Taka Total = 955143113 Taka							
	c) Coal supply Limitation	:	85	MW									
	b) Low water level in Kaptai lake	:	184	MW									
	c) Plants under shut down maintenance	:	3259	MW									
10.	Total Energy (Generation + India Import)	:	201.79	MKWh		14. Maximum Temperature in Dhaka was : 29.5° C							
	By Gas = 102.737 MKWh	By Oil =	49.044	MKWh		15. Export through East-West interconnections :							
	By Coal = 25.945 MKWh	By Hydro =	1.059	MKWh		At evening peak-hour : 8684 MW, at 18:00 hrs							
	By Solar= 1.249 MKWh					Maximum : 500 MW, at 7:00 hrs							
11.	Total Gas Supplied	:	800.15	MMCFD		Energy : 0 MKWh							
(D) Forecast of 24.11.22 (Today) Thursday :													
01.	Maximum Demand	:	10500	MW	(Generation end)	04. Maximum Load-shed : 0 MW At evening peak (Sub-station end)							
02.	Maximum Generation	:	11106	MW	(Generation end)	05. Total Generation : 208.63 MKWh							
03.	Reserve / Shortage	:	606	MW	(Generation end)	06. Probable Max. Temperature in Dhaka : 27.8° C							