

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month November, 2022				Day : Friday				Date : 25.11.22						
Probable Maximum Demand : 10200 MW				Probable Maximum Generation : 10688 MW				Rule Curve = 10670 ft.						
Water Level of Kaptai Lake at 06:00 AM				Today = 90.68 ft.										
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	24.11.22 (Yesterday)		25.11.22 (Today)		24.11.22 (Yesterday)		25.11.22 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Machines shut down (MW)			
					Day	Evening	Day	Evening						
(A) Plants in operation:														
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0			260	Under project work	
2	a) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0				Line Overload	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180					
3	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	200	200			365	Under maint.	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	3x43.35	108	108	66	71	22	22					
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0			105	Gas Shortage	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0				Contract Expired	
7	Haripur 360MW CAPP(HPL)	Gas (IPP)	1x235+1x125	360	360	275	267	0	0			93	Gas Shortage	
8	Meghnaghat 450 MW CAPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	150	225			225	Gas Shortage	
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0			115	Under Overhauling	
10	Haripur 412 MW CAPP	Gas (EGCB)	1x273+1x139	412	412	328	313	320	310			99	Gas Shortage	
11	Siddhirganj 2°120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	210	100			210	Gas Shortage	
12	Siddhirganj 335 MW CAPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0			335	Gas Shortage	
13	Meghnaghat CAPP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0			335	Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	30	45	30	45					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	16	40	16	50					
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	22	22	22					
17	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	48	51	48	48					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	33	33					
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	30	28	33	33					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	33	49	50	50					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	105	105	105	105					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	48	48	48	133					
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	97	289	97	275					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	135	143	135	149					
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	191	224	100	150					
27	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	97	95	50	50					
28	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	94	96	50	50					
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	35	17	55					
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	35	35	55					
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	17	17	17					
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	62	162	17	162					
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	28	0	30	0					
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17					
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	71	80	80	90					
36	Meghnaghat 100 MW(HEL)	HFO (NENP)	12x8.9	100	100	68	83	50	92					
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0					
Dhaka Zone Total			6004	5847	2394	2807	2179	2772	1402	740				
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	76	76	46	46			154	Low water level	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0			180	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0			180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	4	4	5	0	0					
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	17	17	17					
42	Teknaf 20MW PP (SolarTech)	Solar (IPP)	1x20	20	20	20	0	20	0					
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	13	26	19	43					
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	68	68	68	105					
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0			150	Under maint.	
46	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	151	151	150	150			74	STG Under maint.	
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	250	286	300	300					
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	12	12	12	12					
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	51	17	51					
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	48	38	22	33					
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0			22	Gas Shortage	
*	Malancha, Cig.EP2 (United)	Gas	5x8.73+3x9.34			2	3	15	25					
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0					
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	36	36	36					
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	53	57	53	91					
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	12	12	12	12					
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	10	10	10	10					
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	89	89	89	89					
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0				on test	
Chattogram Zone Total			2442	2382	896	932	891	1020	356	404				
58	Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0			134	Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	44	41	44	44					
60	Ashuganj 225 MW CAPP	Gas (APSCCL)	1x142+1°175	221	221	0	0	0	0			221	Minor Inspection	
61	Ashuganj 450 MW CAPP(South)	Gas (APSCCL)	1x360	360	360	230	210	280	280					
62	Ashuganj 450 MW CAPP(North)	Gas (APSCCL)	1x361	360	360	0	0	0	0				Minor Inspection	
63	Ashuganj 420 MW CAPP(East) GT	Gas (APSCCL)	1x284	284	284	432	430	400	400					
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15°4	55	55	25	25	25	25			30	Gas Shortage	
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20°9.73+1°116	195	195	0	0	0	0			195	Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	5	5	5	5			46	Gas Shortage	
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	75	120	85	115					
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	24	31	0	30					
69	Chandpur 150 MW CAPP	Gas (PDB)	1x106+1x57	163	163	79	70	78	78			57	ST Under maint.	
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	51	92	51	200					
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22					
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	10	10					
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	16	22	33	33					
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	16	8	8					
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	15	15	15	15					
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+6x1.515+1x1.098	200	200	70	50	100	100					
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7°18.415+1°9.78	114	114	17	17	17	17					
78	Chowmuhani 113 MW	HFO (IPP)	12°9.78+2°3.1	113	113	98	89	104	104					
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	34					
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	97	109	115	115					
**	Imphoct (Tripura)	India		160	160	112	114	143	166					
Cumilla Zone Total			3193	3169	1447	1505	1552	1801	405	638				
81	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	34	34	75	105			168	Gas Shortage	
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	8	8	8	8					
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	58	59	49	59					
84	Myemensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	58	58	58	58					
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0					
86	Sutiakehari 50 MW Solar PP	Solar (IPP)	1x50	50	50	39	0	50	0					
87	Tangail 22 MW PP(PPLGL)	HFO (IPP)	4x6.7	22	22	12	12	12	12					
Myemensingh Zone Total			622	614	211	171	254	242	168	0				

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	24.11.22 (Yesterday)		25.11.22 (Today)		24.11.22 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Water Limitation MW		Machines shut down (MW)	Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening					
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	GT-1 Under maint.		
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	43	43	43	43		47	GT-4 Under maint.		
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	50	50	50	50					
91	Kushiara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0	109	54	STG Under maint.		
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	3	3	3	3					
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	57	68	66	66					
94	Shajibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.		
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	84	0	84					
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	90	90	90	90					
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	19	19					
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10					
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	24	22	24					
100	Bibiya-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	0	0	0	0		341	Major Inspection	31/12/2022	
101	Bibiya-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	415	420	400	400					
102	Bibiya South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400					
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work		
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	26	27	25	25					
105	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12'3.3x5'2	50	50	37	37	37	37					
Sylhet Zone Total						2522	2477	1195	1304	1195	1281	109	912	
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
107	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	155	155	160	165	255		Gas Shortage		
108	Fairdipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	50					
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	60	0	75					
110	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	0					
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	0	50					
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	60	54	94					
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0					
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	75	0	100	0					
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	10	97	66	115					
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	32	0	32					
	Rampal 1320 MW	Coal (BIFPCL)				0	0	0	0					
	Khulna 330 MW CCPP	Gas/HSD (BPDB)				0	0	0	0					
**	Bheramara (HSDC)	India		1000	1000	895	893	480	720					
Khulna Zone Total						2388	2384	1152	1297	860	1301	255	0	
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	0	0		110	Line Overload		
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	13	17	15	20					
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	130	130	130	130	64		Gas Shortage		
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	660	890	850	850					
121	Potukhalhi 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0		150	Line Overload		
	Barisal Electric 307 MW	Coal (IPP)				251	0	0	0					
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	0	0	0	0					
Barisal Zone Total						1958	1958	1054	1037	995	1000	64	260	
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage		
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Gas Shortage		
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	34					
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	1	0	0					
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	20					
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	88	0	80					
128	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	31	0	40					
129	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	16	34	34	34					
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	33	0	34					
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	167	165	165	160		45	Gas Shortage		
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage		
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0		220	Under maint.		
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	201	202	200	200	212		Gas Shortage		
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	15	16	19	19					
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11					
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	16	43	35	43					
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6'18.55	113	113	37	95	35	95					
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	36	94	70	113					
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0					
Rajshahi Zone Total						2129	2129	501	810	575	883	648	220	
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage		
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0			Under Overhauling		
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	160	160	160	160	114		Coal Shortage		
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	34	84	34	113					
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
146	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0					
147	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6'20	115	115	0	0	50	115					
148	Lalmohar 30 MW Solar (Intraco)	Solar (IPP)	1'30	30	30	31	0	30	0					
Rangpur Zone Total						830	750	231	244	282	388	199	85	
Sub-total: Plants in operation						22088	21710	9081.0	10107	8783	10688	3606	3259	
(B) Plants under long term maintenance/ contract expired														
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0					
150	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0					
151	Bosila 108MW PP(PLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0					
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0					
153	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020		
154	Ammura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022		
Sub-Total: Plants under long term maintenance/ contract expired						424	0	0	0	0	0			
Gross Total						22512	21710	9081	10107	8783	10688	3606	3259	
(C) Actual data of 24.11.22 (Yesterday) Thursday :														
01.	Max. Demand at eve. peak (Generation end)	:	10107	MW,	at =	18:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	9738	MW,	at =	18:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	10107	MW,	at =	18:00 hrs		MW	MW	MW		MW	MW	MW
04.	Minimum Generation (Generation end)	:	6604	MW,	at =	5:00 hrs	Dhaka	3953	3953	0	Mymensingh	703	703	0
05.	Day-peak Generation (Generation end)	:	9081	MW,	at =	12:00 hrs	Chattogram	1133	1133	0	Sylhet	373	373	0
06.	Evening-peak Generation (Generation end)	:	10107	MW,	at =	18:00 hrs	Khulna	1049	1049	0	Barisal	227	227	0
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW,	at =	18:00 hrs	Rajshahi	856	856	0	Rangpur	653	653	0
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6674	MW,	at =	5:00 hrs	Cumilla	792	792	0				
09.	Generation shortfall at evening peak due to :	:					Total							
	a) Gas/LF limitation	:	3253	MW			13.	Fuel cost :	(a) Gas =	103891005	Taka	(c) Coal =	207103370	Taka
	d) Coal supply Limitation	:	199	MW		(b) Oil =			673345945	Taka	Total =	984340320	Taka	
	b) Low water level in Kaptai lake	:	154	MW										
	c) Plants under shut down/ maintenance	:	3259	MW			14.	Maximum Temperature in Dhaka was : 30.2° C						
10.	Total Energy (Generation + India Import)	:	204.42	MKWh			15.	Export through East-West interconnections :						
	By Gas = 103.561 MKWh			By Oil =	49.549 MKWh		At evening peak-hour							
	By Coal = 26.629 MKWh			By Hydro =	1.538 MKWh		: 9081 MW, at 18:00 hrs							
	By Solar= 1.357 MKWh						Maximum : 684 MW, at 7:00 hrs							
							Energy : 0 MKWh							
11.	Total Gas Supplied	:	817.46	MMCFD			06. Probable Max. Temperature in Dhaka : 29.1° C							
(D) Forecast of 25.11.22 (Today) Friday :														
01.	Maximum Demand	:	10200	MW	(Generation end)		04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)						
02.	Maximum Generation	:	10688	MW	(Generation end)		05.	Total Generation : 206.30 MKWh						
03.	Reserve / Shortage	:	488	MW	(Generation end)		06.	Probable Max. Temperature in Dhaka : 29.1° C						