

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month November, 2022				Day : Saturday				Date : 26.11.22				
Probable Maximum Demand : 10000 MW				Probable Maximum Generation : 10923 MW				Rule Curve = 106.50 ft.				
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 90.68 ft Today = 90.44 ft								
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	25.11.22 (Yesterday)		26.11.22 (Today)		25.11.22 (Yesterday)		26.11.22 (Today)	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Status of Machines under shut-down/ Maintenance	
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0			Line Overload
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	200	200	200	200		165	Under maint.
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	22	22	22	22			
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			Contract Expired
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	0	0	0	0	360		Gas Shortage
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	175	225	225	225	225		Gas Shortage
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	302	377	400	400	35		Gas Shortage
11	Siddhirganj 2°120 MW GTTP	Gas (EGCB)	2 x 105	210	210	206	38	100	100	172		Gas Shortage
12	Siddhirganj 335 MW MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335		Gas Shortage
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	10	150	150	325		Gas Shortage
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	45	45	45	45			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	25	50	25	50			
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	7	22	22			
17	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	40	39	48	48			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25			
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	28	33	33			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	49	37	50	50			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	105	105	105			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	48	48	48	48			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	97	264	82	275			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	135	130	135	149			
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	102	0	100	150			
27	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	50	0	50	50			
28	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	50	0	50	50			
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	35	35	55			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	35	55			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	17	17	17			
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	108	144	108	162			
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	30	0	30	0			
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17			
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	80	55	80	80			
36	Meghnaghat 100 MW(HEL)	HFO (NENP)	12x8.9	100	100	67	47	50	92			
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0			
Dhaka Zone Total					6004	5847	2289	2234	2484	2909	1557	540
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	76	76	76	76	154		Low water level
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	4	0	5	0	0			
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	17	17	17			
42	Teknaf 20MW PP (SolarTech)	Solar (IPP)	1x20	20	20	0	20	0	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	19	26	19	43			
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	105	68	105			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	101	151	150	150		74	STG Under maint.
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	100	270	100	300			
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	12	12	12			
49	Dohazari -Kalash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	17	51			
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	29	25	22	33			
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0	22		Gas Shortage
*	Malancha, Cig.EP2 (United)	Gas	5x8.73+3x9.34			23	25	7	15			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0			
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	36	36	36	36			
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	53	73	53	91			
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	12	12	12	12			
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	10	10	10	10			
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107			
	Minsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0			on test
Chattogram Zone Total					2442	2382	632	996	731	1058	356	404
58	Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	44	44	41	41			
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1°175	221	221	0	0	0	0	221		Minor Inspection
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	250	270	230	270			
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	0	0	0	0		360	Minor Inspection
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCCL)	1x284	284	284	429	432	400	400			
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15°4	55	55	51	30	30	30	25		Gas Shortage
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20°9.73+1°116	195	195	0	0	0	0	195		Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	5	5	5	5	46		Gas Shortage
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	72	83	85	115			
68	Titaz 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	22	22	0	30			
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	77	78	78	78		57	ST Under maint.
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	41	51	200			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11			
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	24	33	33	33			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	8	8	8			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	15	15	15	15			
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	8x14+8x1.515+15x1.098	200	200	50	0	100	100			
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7°18.415+1°9.78	114	114	35	17	17	17			
78	Chowmuhani 113 MW	HFO (IPP)	12°9.78+2°3.1	113	113	6	108	26	108			
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	34			
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	36	115	35	115			
**	Import (Tribuna)	India		160	160	88	106	143	166			
Cumilla Zone Total					3193	3169	1279	1457	1347	1798	400	638
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	34	44	75	105		158	Gas Shortage
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	8	8	11	11			
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	47	58	49	59			
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	57	56	58	58			
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
86	Sutiaakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	0	0	50	0			
87	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	12	12	12	12			
Mymensingh Zone Total					622	614	210	178	257	245	158	0

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	25.11.22 (Yesterday)		26.11.22 (Today)		25.11.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Water Limitation		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	MW	Machines shut down (MW)		
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	28	30	30	30		40	GT-1 Under maint.	
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	43	43	43	43		47	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakattullah)	Gas (RPP)	19x2.90	51	51	47	50	50	50				
91	Kushiara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0	109	54	STG Under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	2	3	3				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	66	68	66	66				
94	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	84	84	0	84				
96	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	90	90	90	90				
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	19	19	19				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	22	24	22	24				
100	Bibiya-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	0	0	0	0		341	Major Inspection	31/12/2022
101	Bibiya-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	419	402	400	400				
102	Bibiya South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	104	400	400	400				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	26	30	30	30				
105	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12'3.3x5'2	50	50	37	37	37	37				
Sylhet Zone Total						2522	2477	999	1289	1200	1286	109	912
106	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
107	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	160	165	160	165	245		Gas Shortage	
108	Fairdipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	34	0	50				
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	40	0	75				
110	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	0				
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	0	50				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	42	50	54	94				
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0				
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	79	0	100	0				
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	61	82	66	115				
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	16	32	0	32				
	Rampal 1320 MW	Coal (BIFPCL)				298	274	0	0				
	Khulna 330 MW CAPP	Gas/HSD (BPDB)				0	0	0	0				
**	Bheramara (HVDG)	India		1000	1000	472	691	900	1000				
Khulna Zone Total						2388	2384	1128	1368	1280	1581	245	0
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	0	0		110	Line Overload	
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	13	16	15	20				
119	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	128	111	130	130	83		Gas Shortage	
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	520	370	622	622				
121	Potukhalhi 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0		150	Line Overload	
	Barisal Electric 307 MW	Coal (IPP)				0	0	0	0				
122	Bhola 220MW CAPP (Nutan Bidrut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	0	0	0	0				
Barisal Zone Total						1958	1958	661	497	767	772	83	260
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	30	0	34				
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	4	0	20				
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	50	83	0	80				
128	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	40	22	0	40				
129	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	25	25	34	34				
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	35	0	34				
131	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	167	163	165	160			Gas Shortage	
132	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
133	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0		220	Under maint.	
134	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	205	210	200	200	204		Gas Shortage	
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	17	20	20	22				
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	43	10	35	43				
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6'18.55	113	113	37	95	35	95				
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	70	113	70	113				
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0				
Rajshahi Zone Total						2129	2129	669	821	576	886	642	220
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	160	159	160	160	115		Coal Shortage	
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	34	80	34	113				
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0				
147	Teakurgaon 119MW PP (Energypac)	HFO (IPP)	6'20	115	115	115	108	50	115				
148	Lalmohanhat 30 MW Solar (Intraco)	Solar (IPP)	1'30	30	30	32	0	30	0				
Rangpur Zone Total						830	750	347	347	282	388	200	85
Sub-total: Plants in operation						22088	21710	8214.0	9187	8924	10923	3750	3059
(B) Plants under long term maintenance/ contract expired													
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
150	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
151	Bosila 108MW PP(PLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
153	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
154	Ammura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired						424	0	0	0	0	0		
Gross Total						22512	21710	8214	9187	8924	10923	3750	3059
(C) Actual data of 25.11.22 (Yesterday) Friday :													
01.	Max. Demand at eve. peak (Generation end)	:	9187	MW,	at =	18:00 hrs							
02.	Max. Demand at eve. peak (Sub-station end)	:	8952	MW,	at =	18:00 hrs							
03.	Highest Generation (Generation end)	:	9187	MW,	at =	18:00 hrs							
04.	Minimum Generation (Generation end)	:	6674	MW,	at =	7:00 hrs							
05.	Day-peak Generation (Generation end)	:	8214	MW,	at =	12:00 hrs							
06.	Evening-peak Generation (Generation end)	:	9187	MW,	at =	18:00 hrs							
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW,	at =	18:00 hrs							
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6286	MW,	at =	5:00 hrs							
09.	Generation shortfall at evening peak due to :	:											
	a) Gas/LF limitation	:	3396	MW									
	d) Coal supply Limitation	:	200	MW									
	b) Low water level in Kaptai lake	:	154	MW									
	c) Plants under shut down maintenance	:	3059	MW									
10.	Total Energy (Generation + India Import)	:	189.02	MKWh									
	By Gas =	103.259	MKWh	By Oil =	44.934	MKWh							
	By Coal =	21.949	MKWh	By Hydro =	1.819	MKWh							
	By Solar =	1.447	MKWh										
11.	Total Gas Supplied	:	833.10	MMCFD									
(D) Forecast of 26.11.22 (Today) Saturday :													
01.	Maximum Demand	:	10000	MW	(Generation end)								
02.	Maximum Generation	:	10923	MW	(Generation end)								
03.	Reserve / Shortage	:	923	MW	(Generation end)								
04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)								
05.	Total Generation	:	205.75	MKWh									
06.	Probable Max. Temperature in Dhaka :	:	28.6° C										

* Captive Power ** Imported Power