

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month December, 2022				Day : Thursday				Date : 01.12.22					
Probable Maximum Demand : 10500 MW				Probable Maximum Generation : 11784 MW									
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 89.79 ft		Today = 89.75 ft		Rule Curve = 106.00 ft					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	30.11.22 (Yesterday)		01.12.22 (Today)		30.11.22 (Yesterday) Gen. shortfall for : Gas/Coal/Oil/Water Limitation MW	01.12.22 (Yesterday) Gen. shortfall for : Machines shut down (MW)	Status of Machines under shut-down/ Maintenance	Description/ Remarks	Probable start-up date
					Actual Peak Generation (MW)		Actual Peak Generation (MW)						
					Day	Evening	Day	Evening					
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0			Line Overload	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180				
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	200	200	200	200		165	Under maint.	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	3x3.35	108	108	22	22	22	22		86	Gas Shortage	
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			Contract Expired	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	0	0	0	0		360	Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225		225	Gas Shortage	
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	316	284	300	280		128	Gas Shortage	
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0		210	Gas Shortage	
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0		335	Gas Shortage	
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	235	215	250	215		120	Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	45	45	45	45				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	33	33	50				
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	16	19	16	16				
17	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	48	47	46	46				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	0	33	33	33				
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	27	25	25	25				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	49	49	44	50				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	105	88	105				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	32	32	32				
23	Karnataghat 54 MW PP (Baro Energy)	HFO (IPP)	3x18.69	54	54	17	35	17	54				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	95	245	95	285				
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	43	62	45	64				
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	241	32	300	150				
27	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	100	50	100	50				
28	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	50	0	50				
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	35	35	55				
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55				
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	82	55	82				
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	90	162	90	162				
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	29	0	30	0				
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	30				
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	65	75	80	80				
36	Meghnaghat 100 MW(HEL)	HFO (NENP)	12x8.9	100	100	48	72	73	73				
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0				
Dhaka Zone Total				6004	5847	2323	2486	2511	2714		1569	540	
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	46	46	46	46		184		Low water level
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0			180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	1	0	5	0				
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	17	17	17				
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	3	0	20	0				
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	19	44	26	44				
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	105	17	105				
45	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.	
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	151	151	151	151		74	STG Under maint.	
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	69	154	200	290				
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	12	12	12	12				
49	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	17	51				
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	24	32	22	32				
51	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0		22	Gas Shortage	
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	8	2	10				
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0				
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	36	36	36	36				
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	55	73	53	74				
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	12	12	12	12				
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	10	10	10	10				
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	89	107	89	107				
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			15	0	0	0			on test	
Chattogram Zone Total				2442	2382	578	858	735	997		386	404	
58	Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0		134		Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	41	44	43	43				
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1x75	221	221	160	132	150	225				
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	265	270	270	360				
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	55	320	0	0				
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCCL)	1x284	284	284	0	0	200	300				
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	10	5	0	55		50		Gas Shortage
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+1'16	195	195	65	8	8	100		187		Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	5	5	5	50		46		Gas Shortage
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	66	20	150	149				
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	32	21	32				
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	78	64	70	70			57	ST Under maint.
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	200	17	200				
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	22	19	22				
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	16	23	25	25				
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	16	8	16				
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	15	15	15	15				
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+4x1.515+15x1.598	200	200	162	20	100	100				
77	Feni 11.4 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	17	99	17	99				
78	Chowmuhani 11.3 MW	HFO (IPP)	12'9.78+2'3.1	113	113	105	115	104	113				
79	Bhairob 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	36				
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	36	115	34	115				
**	Impoget (Tripura)	India		160	160	122	132	143	166				
Cumilla Zone Total				3193	3169	1290	1685	1427	2302		417	57	
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	33	48	72	72		154		Gas Shortage
82	Tangali 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	8	7	7	7				
83	Jamailpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	47	59	49	58				
84	Myemensing 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	50	57	48	57				
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
86	Sutiaikhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	43	0	50	0				
87	Tangali 22 MW PP(PDGL)	HFO (IPP)	4x6.7	22	22	12	12	12	12				
Myemensing Zone Total				622	614	195	183	240	206		154	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	30.11.22 (Yesterday)		01.12.22 (Today)		30.11.22 (Yesterday)		Status of Machines under shut-down/ Maintenance				
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)					
						Day	Evening	Day	Evening			Description/ Remarks	Probable start-up date			
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	GT-1 Under maint.				
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	21	21	21		69	GT-4 Under maint.				
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	48	53	51	51							
91	Kushlara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	110	110		54	STG Under maint.				
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8							
93	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	64	67	66	66							
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.				
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	86	0	86							
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	0	0	0	0							
97	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	18	18	18	18							
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10							
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	22	24	21	24							
100	Bibi-ana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	0	0	0	0		341	Major Inspection	31/12/2022			
101	Bibi-ana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	415	423	400	400							
102	Bibi-ana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	395	395	400	400							
103	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work				
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	32	32	32	32							
105	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12x3.4+5x2	50	50	43	47	40	47							
Sylhet Zone Total						2522	2477	1197	1326	1207	1303	0	934			
106	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0							
107	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	160	165	180	180	245		Gas Shortage				
108	Fariapur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	32	0	40							
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	60	0	75							
110	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	0							
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	10	0	50							
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	75	56	75							
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0							
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	74	0	100	0							
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	16	49	16	49							
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5x8.5	40	40	0	0	0	8							
	Rampal 1320 MW	Coal (BHPCL)				486	426	540	540							
	Khulna 330 MW CCPP	Gas/HSD (BPD)				0	0	0	0							
**	Bheramara (HVDC) India			1000	1000	892	892	907	907							
Khulna Zone Total						2388	2384	1645	1709	1799	1924	245	0			
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	0	0		110	Line Overload				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	12	19	15	19							
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	86	145	145	145	49		Gas Shortage				
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	330	480	622	622							
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0		150	Line Overload				
	Barisal Electric 307 MW	Coal (IPP)				0	0	0	0							
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	222	220	200	220							
Barishal Zone Total						1958	1958	650	864	962	1006	49	260			
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage				
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage				
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	34	0	34							
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0							
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	29	0	29							
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	50	0	100							
128	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	40	0	40							
129	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	25	50	34	50							
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	26	0	35							
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	169	155	190	190	55		Gas Shortage				
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0	0	220		Gas Shortage				
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0		220	Under maint.				
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	247	240	265	265	174		Gas Shortage				
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	15	20	20	22							
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11							
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	8	8	8							
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6x18.55	113	113	35	75	35	95							
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	68	95	35	95							
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0							
Rajshahi Zone Total						2129	2129	582	833	604	974	620	220			
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage				
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling				
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	160	160	160	160	114		Coal Shortage				
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0							
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7x16x 2x3	113	113	34	77	34	85							
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0							
146	Majpara, Talulia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0							
147	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6x20	115	115	0	115	0	113							
148	Lalmohar 30 MW Solar (Intraco)	Solar (IPP)	1x30	30	30	31	0	30	0							
Rangpur Zone Total						830	750	231	352	232	358	199	85			
Sub-total: Plants in operation						22088	21710	8691.0	10296	9737	11784	3639	2500			
(B) Plants under long term maintenance/ contract expired																
149	Jamulpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0							
150	Katpodi 52 MW PP (Sinha)	HFO (IPP)	7x7.50	51	0	0	0	0	0							
151	Bosila 108MW PPI(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0							
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0							
153	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0					Contract Expired on 12/11/2020		
154	Amritura 30 MW PP(Sinnal)	HFO (QRPP)	7x7.79	50	0	0	0	0	0					Contract Expired on 11/01/2022		
Sub-Total: Plants under long term maintenance/ contract expired						424	0	0	0	0	0					
Gross Total						22512	21710	8691	10296	9737	11784	3639	2500			
(C) Actual data of 30.11.22 (Yesterday) Wednesday :																
01.	Max. Demand at eve. peak (Generation end)	:	10390	MW,	at =	19:30	hrs	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand at eve. peak (Sub-station end)	:	9866	MW,	at =	19:30	hrs									
03.	Highest Generation (Generation end)	:	10296	MW,	at =	19:30	hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	
04.	Minimum Generation (Generation end)	:	7167	MW,	at =	5:00	hrs	Dhaka	3790	3728	62	Mymensingh	727	727	0	
05.	Day-peak Generation (Generation end)	:	8691	MW,	at =	12:00	hrs	Chattogram	1170	1170	0	Sylhet	400	400	0	
06.	Evening-peak Generation (Generation end)	:	10296	MW,	at =	19:30	hrs	Khulna	1050	1050	0	Barishal	263	263	0	
07.	Evening Peak Load-shed (Sub-station end)	:	87	MW,	at =	19:30	hrs	Rajshahi	895	895	0	Rangpur	611	611	0	
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7382	MW,	at =	5:00	hrs	Cumilla	961	936	25					
09.	Generation shortfall at evening peak due to :	:										Total	9866	9779	87	
a)	Gas/LF limitation	:	3256	MW												
d)	Coal supply Limitation	:	199	MW												
b)	Low water level in Kaptai lake	:	184	MW												
c)	Plants under shut down/ maintenance	:	2500	MW												
10.	Total Energy (Generation + India Import)	:	207.45	MKWh												
	By Gas =	108.413	MKWh	By Oil =	49.601	MKWh										
	By Coal =	24.537	MKWh	By Hydro =	1.123	MKWh										
	By Solar=	1.288	MKWh													
11.	Total Gas Supplied	:	874.90	MMCFD												
(D) Forecast of 01.12.22 (Today) Thursday :																
01.	Maximum Demand	:	10500	MW	(Generation end)			04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)			
02.	Maximum Generation	:	11784	MW	(Generation end)			05.	Total Generation	:	211.56	MKWh				
03.	Reserve / Shortage	:	1284	MW	(Generation end)			06.	Probable Max. Temperature in Dhaka :	:	28.7°	C</				

#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00