

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month December, 2022					Day : Thursday				Date : 08.12.22						
Probable Maximum Demand : 10200 MW					Probable Maximum Generation : 11061 MW				Rule Curve = 105.37 ft.						
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 89.28 ft Today = 89.20 ft										
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	07.12.22 (Yesterday)		08.12.22 (Today)		07.12.22 (Yesterday)		08.12.22 (Today)		Status of Machines under shut-down/ Maintenance	Description/ Remarks	Probable start-up date
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :						
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)					
(A) Plants in operation:															
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0			260	Under project work		
2	a) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0				Line Overload		
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180						
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	200	200	150	150						
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	3x43.35	108	108	22	21	22	22	87			Gas Shortage		
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105			Gas Shortage		
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0				Contract Expired		
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	307	293	310	300	67			Gas Shortage		
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225			Gas Shortage		
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115		Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	329	395	300	320	17			Gas Shortage		
11	Siddhirganj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210			Gas Shortage		
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	217	118		Gas Shortage		
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0	335			Gas Shortage		
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55						
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	33	50	33	50						
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	22	19	22						
17	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	40	48	49	49						
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25						
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	22	26	27	27						
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	50	49	50	50						
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	105	70	100						
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	32	32	32						
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54						
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	98	270	98	282						
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	96	91	100	135						
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	150						
27	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	50						
28	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	50						
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	17	35	55						
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	35	35	55						
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	55	65	55	65						
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	18	162	17	162						
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	28	0	30	0						
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	5	17	17						
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	62	69	60	70						
36	Meghnaghat 100 MW(HEL)	HFO (NENP)	12x8.9	100	100	49	51	55	55						
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	34	100	100						
Dhaka Zone Total					6004	5847	2084	2579	2166	2907	1263	493			
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	46	46	46	46	184			Low water level		
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180			Gas Shortage		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under maint.		
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	4	0	5	0							
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25						
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	18	0	20	0						
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	19	31	20	40						
44	Sikalbaha 105 MW PP (Baraka Sikabaha)	HFO (IPP)	6x18.415	105	105	34	84	17	105						
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150			Under maint.		
46	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	150	145	150	150	80			STG Under maint.		
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	292	300	150	300						
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	12	15	12	12						
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	51	68	50	50						
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	32	32	32	32						
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0	22			Gas Shortage		
*	Malancha, Cig.EP2 (United)	Gas	5x8.73+3x9.34			2	2	2	7						
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0						
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	36	36	36						
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	54	64	54	62						
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	12	12	12	12						
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	10	10	10	10						
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	89	89	89	89						
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			9	0	0	0				on test		
Chattogram Zone Total					2442	2382	876	959	730	976	386	410			
58	Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134			Gas Shortage		
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	20	30	10	30	15			Gas Shortage		
60	Ashuganj 225 MW CAPP	Gas (APSCCL)	1x142+117.5	221	221	184	221	185	220						
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	0	0	0	0	360			Under maint.		
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	340	370	340	340						
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCCL)	1x284	284	284	214	398	324	324						
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	0	0	0	0	55			Gas Shortage		
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+11'16	195	195	0	0	0	0	195			Gas Shortage		
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	5	5	5	5	46			Gas Shortage		
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	15	102	13	100						
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	29	30	35						
69	Chandpur 150 MW CAPP	Gas (PDB)	1x106+1x57	163	163	0	0	0	0	57			ST Under maint.		
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	31	17	200						
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	21	21	21						
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	10	10						
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	25	33	33						
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	8	8	8						
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	15	15	15						
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	9x14+6x1.515+15x1.098	200	200	0	0	0	100						
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	17	26	17	17						
78	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	109	99	113	113						
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17						
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	18	96	34	94						
**	Import (Tirupura)	India		160	160	102	112	143	166						
Cumilla Zone Total					3193	3169	1132	1615	1335	1848	445	417			
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	33	34	35	85	168			Gas Shortage		
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	11	11	11	11						
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	49	59	47	59						
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	47	58	50	57						
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0						
86	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	47	0	50	0						
87	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	12	12	12	12						
Mymensingh Zone Total					622	614	201	174	207	224	168	0			

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	07.12.22 (Yesterday)		08.12.22 (Today)		07.12.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)		
88	Fenchuganj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30		40	GT-1 Under maint.	
89	Fenchuganj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42		48	GT-4 Under maint.	
90	Fenchuganj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	22	51	53				
91	Kushiera 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0		54	STG Under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	8				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	32	34	33				
94	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	86	86				
96	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	219	219	218		220		
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	17	19		19		
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10		10		
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	13	24	21		24		
100	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	0	0	0		341	Major Inspection	31/12/2022
101	Bibiana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	422	419	400		400		
102	Bibiana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	400	260	260		260		
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0		100	Under project work	
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	11	11	11		11		
105	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	30	45	30		45		
Sylhet Zone Total					2522	2477	1257	1256	1135	1241	0	913
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0		0		
107	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0		0	410	Under maint.
108	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	45	0		38		
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	74	0		80		
110	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0		0		
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	0		50		
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	53	70	55		94		
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0		0		
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	70	0	100		0		
115	Khulna 115 MW PP (KFCL-2)	HFO (NENP)	7x17	115	115	21	89	83		114		
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0		0		
	Rampal 1320 MW	Coal (BIFPCL)				0	0	0		0		
	Khulna 330 MW CAPP	Gas/HSD (BPDB)				0	0	0		0		
**	Bheramara (H/DC)	India		1000	1000	911	905	919		919		
Khulna Zone Total					2388	2384	1055	1183	1157	1295	0	410
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	0		0	110	Line Overload
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	16	20	13		20		
119	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	187	183	187		187		
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	500	500	622		622		
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	26	0		35	124	Line Overload
	Barisal Electric 307 MW	Coal (IPP)				0	0	0		0		
122	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	221	216	200		220		
Barishal Zone Total					1958	1958	924	945	1022	1084	0	234
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0		0	71	Gas Shortage
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0		0	100	Gas Shortage
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	24	0		34		
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0		0		
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	4	0		25		
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	60	0		89		
128	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	40	0		40		
129	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	8	34	34		34		
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	34	0		35		
131	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	220	217	210		210		
132	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0		0	220	Gas Shortage
133	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0		0	220	Under maint.
134	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	427	370	330		350		
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	22	22		22		
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11		11		
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	43		43		
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	36	95	35		113		
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	50	94	94		94		
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6		0		
Rajshahi Zone Total					2129	2129	775	1013	785	1100	391	220
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0		0	85	Coal Shortage
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0		0	85	Under Overhauling
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	160	160	160		160	114	Coal Shortage
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0		0		
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	34	81	34		113		
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0		0		
146	Mejpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8		0		
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	36	111	35		113		
148	Lalmohithat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	26	0	30		0		
	Teesla Solar Limited	Solar (IPP)				68	0	0		0		
Rangpur Zone Total					830	750	330	352	267	386	199	85
Sub-total: Plants in operation					22088	21710	8634.0	10076	8804	11061	2852	3182
(B) Plants under long term maintenance/ contract expired												
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0		0		
150	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0		0		
151	Bossila 108MW PP(ELC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0		0		
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0		0		
153	Bogura 20 MW PP (Energyprima)	Gas (NENP)	5x3.3+5x2.0	20	0	0	0	0		0		Contract Expired on 12/11/2020
154	Amshura 90 MW PP(Sinha)	HFO (QRPP)	7x7.79	90	0	0	0	0		0		Contract Expired on 11/61/2022
Sub-Total: Plants under long term maintenance/ contract expired					424	0	0	0	0	0		
Gross Total					22512	21710	8634	10076	8804	11061	2852	3182
(C) Actual data of 07.12.22 (Yesterday) Wednesday :												
01.	Max. Demand at eve. peak (Generation end)	:	10076 MW, at =	18:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	9708 MW, at =	18:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	10076 MW, at =	18:00 hrs	Dhaka	3690	3690	0	Mymensingh	762	762	0
04.	Minimum Generation (Generation end)	:	6536 MW, at =	5:00 hrs	Chattogram	1129	1129	0	Sylhet	374	374	0
05.	Day-peak Generation (Generation end)	:	8634 MW, at =	12:00 hrs	Khulna	1101	1101	0	Barishal	253	253	0
06.	Evening-peak Generation (Generation end)	:	10076 MW, at =	18:00 hrs	Rajshahi	877	877	0	Rangpur	706	706	0
07.	Evening Peak Load-shed (Sub-station end)	:	0 MW, at =	18:00 hrs	Cumilla	816	816	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6500 MW, at =	5:00 hrs					Total	9708	9708	0
09.	Generation shortfall at evening peak due to :	:			13.	Fuel cost :	(a) Gas = 118138557 Taka (b) Oil = 548053812 Taka		(c) Coal = 143632448 Taka Total = 809824817 Taka			
	a) Gas/LF limitation	:	2469 MW		14.	Maximum Temperature in Dhaka was : 28.2° C						
	d) Coal supply Limitation	:	199 MW		15.	Export through East-West interconnections :						
	b) Low water level in Kaptai lake	:	184 MW			At evening peak-hour : 8634 MW, at 18:00 hrs						
	c) Plants under shut down/ maintenance	:	3182 MW			Maximum : 580 MW, at 7:00 hrs						
10.	Total Energy (Generation + India Import)	:	199.30 MMCFD			Energy : 0 MMCFD						
	By Gas = 114.154 MKWH			41.901 MKWH								
	By Coal = 17.547 MKWH			1.091 MKWH								
	By Solar= 1.647 MKWH											
11.	Total Gas Supplied	:	868.43 MMCFD									
(D) Forecast of 08.12.22 (Today) Thursday :												
01.	Maximum Demand	:	10200 MW	(Generation end)	04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)						
02.	Maximum Generation	:	11061 MW	(Generation end)	05.	Total Generation : 201.75 MMCFD						
03.	Reserve / Shortage	:	861 MW	(Generation end)	06.	Probable Max. Temperature in Dhaka : 27.2° C						

#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helatur Rahman