

POWER GRID COMPANY OF BANGLADESH LTD.									
NATIONAL LOAD DESPATCH CENTER									
DAILY REPORT									
Till now the maximum generation is :-					14782.0		21:00 Hrs on 16-Apr-22		Reporting Date : 10-Dec-22
The Summary of Yesterday's			9-Dec-22		Generation & Demand		Today's Actual Min Gen. & Probable Gen. & Demand		
Day Peak Generation :			7716.0 MW		Hour :		12:00		Min. Gen. at 5:00
Evening Peak Generation :			8874.0 MW		Hour :		19:00		Available Max Generation : 11461
E.P. Demand (at gen end) :			8874.0 MW		Hour :		19:00		Max Demand (Evening) : 9700
Maximum Generation :			8874.0 MW		Hour :		19:00		Reserve(Generation end) 1761
Total Gen. (MKWH) :			183.2		System Load Factor :		86.00%		Load Shed : 0
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR									
Export from East grid to West grid :- Maximum					290 MW		at 8:00		Energy
Import from West grid to East grid :- Maximum					- MW		-		Energy
Water Level of Kaptai Lake at 6:00 A M on 10-Dec-22									
Actual :			88.96		Ft.(MSL) ,		Rule curve :		105.19 Ft.(MSL)
Gas Consumed :			Total = 859.26		MMCFD.		Oil Consumed (PDB) :		
							HSD :		
							FO :		
Cost of the Consumed Fuel (PDB+Pvt) :			Gas :		Tk123,615,483				
			Coal :		Tk117,985,269		Oil : Tk398,896,547		Total : Tk640,497,300
Load Shedding & Other Information									
Area Yesterday Estimated Demand (S/S end) Today Estimated Shedding (S/S end) Rates of Shedding (On Estimated Demand)									
MW MW MW									
Dhaka 0 0:00 3362 0 0%									
Chittagong Area 0 0:00 952 0 0%									
Khulna Area 0 0:00 1257 0 0%									
Rajshahi Area 0 0:00 1115 0 0%									
Cumilla Area 0 0:00 949 0 0%									
Mymensingh Area 0 0:00 784 0 0%									
Sylhet Area 0 0:00 351 0 0%									
Barisal Area 0 0:00 286 0 0%									
Rangpur Area 0 0:00 619 0 0%									
Total 0 9677 0									
Information of the Generating Units under shut down.									
Planned Shut- Down Forced Shut-Down									
1) Barapukuria ST: Unit-1, 2									
2) Ghorasal-3, 4									
3) Ashuganj-5									
4) Baghabari-71,100 MW									
5) Raozan unit-1 & 2									
6) Siddhirganj 210 MW .									
7) Shahjibazar 330 MW									
8) Sirajganj-2									
9) Bibiana-II 341 MW CCPP (Summit)									
Outage Restore Additional Information of Machines, lines, interruption / Forced Load shed etc. Remark									
Time Time									
8:18 16:01 Joypurhat-Naogaon 132kV Ckt-1 Scheduled S/D from Naogaon 132/33kV end Due to Annual maintenance works. and from Joypurhat 132/33kV end Due to Annual Maintenance. 15.0MW load interrup. Naogaon 132/33kV end.									
8:19 17:22 Payra 400/132/33kV S/S 400/132/33 kV Auto Transformer-02 HT Scheduled S/D Due to Schedule shutdown.									
8:40 - Mongla 132/33kV S/S T-1 LT Project Work S/D Due to Transformer -1 Remove.									
8:40 - Mongla 132/33kV S/S T-1 HT Project Work S/D Due to Transformer-1 Remove.									
8:41 19:16 Hasnabad 230/132kV S/S AUTO TR-2 HT Scheduled S/D Due to Due to Annual maintenance.									
8:41 19:16 Hasnabad 230/132kV S/S AUTO TR-2 LT Scheduled S/D Due to Due to Annual maintenance.									
9:37 16:27 Matuail 132/33kV GT-2 SD for A/M.									
10:02 - Gopalgonj-Payra 400KV ckt-1 open for Rampal test.									
- 10:34 Rajshahi 132/33kV S/S Main Bus is restored.									
- 10:36 Rajshahi-Rajshahi(New) 132kV Ckt-1 is restored.									
- 10:38 HVDC Bheramera- Rajshahi 230kV Ckt-2 is restored.									
- 11:02 Sherpur 132/33kV S/S TR-02,132 Kv GCB(552B) is restored.									
- 11:03 Sherpur 132/33kV S/S Transformer- 02 LT is restored.									
- 11:49 Halishahar-Julda 132kV Ckt-1 is restored.									
- 11:50 Halishahar 132/33kV S/S 132 kV Single Bus is restored.									
- 11:53 Rampur 230/132/33 S/S Halishahar-2 is restored.									
- 11:53 Rampur 230/132/33 S/S Halishahar-1 is restored.									
- 11:55 Khulshi 132/33kV S/S Khulshi-Halishahar Ckt-3 is restored.									
- 14:38 Barishal 132/33kV S/S T-1 (405T) HT is restored.									
- 14:39 Barishal 132/33kV S/S T-1 (405T) LT is restored.									
14:45 16:47 Barishal 132/33kV S/S T-2 (415T) LT Scheduled S/D Due to Tan delta test.									
14:46 16:46 Barishal 132/33kV S/S T-2 (415T) HT Scheduled S/D Due to Tan delta test.									
- 15:26 Bogura(New)-Naogaon 132 kV Ckt-2 is restored.									
- 15:44 Bibiyana-Shahjibazar 230 kV Ckt-1 is restored.									
- 15:45 Cumilla(N)-Shahjibazar 230 kV Ckt-1 is restored.									
- 15:50 Thakurgaon 132/33kV S/S 412T HT is restored.									
- 15:50 Thakurgaon 132/33kV S/S 412T LT is restored.									
17:22 - Payra P/S to Payra Grid S/S 400 Kv Ckt-2 Shutdown withdraw.									
- 20:34 Bibiyana-Shahjibazar 230 kV Ckt-2 is restored.									
- 20:57 Cumilla(N)-Shahjibazar 230 kV Ckt-2 is restored.									
21:36 - Shahjibazar 100MW 230/11kV unit transformer charged at HT side.									
- 0:26 Ashugonj South ST sync.									
7:08 - Brahmanbaria-Shahjibazar 132 kV Ckt-2 Scheduled S/D from Shahjibazar 132/33kV end Due to Shoutdown taken by B.baria grid.									
7:08 - Brahmanbaria-Shahjibazar 132 kV Ckt-1 Scheduled S/D from Shahjibazar 132/33kV end Due to shoutdown taken by B.baria grid									
7:38 - B.Baria 132kV bus S/D due to C/M 66MW load interrup.									
Sub Divisional Engineer Network Operation Division					Executive Engineer Network Operation Division			Superintendent Engineer Load Despatch Circle	