

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date :		9-Dec-22		Page -2			
No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CCPP-Unit-3 (GT	PDB	1'260	260	0	0	Under maint.
2	Ghorasal Repowered CCPP Unit-4	PDB	1'210	180	0	0	Line O/L
3	Ghorasal TPP Unit-5	PDB	1'210	190	180	4359600	
4	Ghorasal 365 MW CCPP Unit-7	PDB	1'243+1'122	365	200	4808100	GBC problem
5	Ghorashal 78.5 MW PP(MAX)	QRPP	2'40	0	0	0	
6	Ghorashal 108MW PP (Regent)	IPP	34'3.35	108	22	542590	Gas shortage
7	Haripur GTPP	SBU, PDB	2'32	20	0	0	Under maint.
8	Haripur 412 MW CCPP	EGCB	1'273+1'139	412	395	9564160	Gas shortage
9	Haripur 360MW CCPP(HPL)	IPP	1'235+1'125	360	343	8140000	Gas shortage
10	Meghnaghat 450 MW CCPP(MPL)	IPP	2'150+1'150	450	225	5448000	GT-2 S/D due to Gas shortage
11	Meghnaghat 100 MW(IEI)	NENP	12'8.9	100	13	214080	Low demand
12	Meghnaghat CCPP(Summit)	IPP	2'110+1'110	335	0	0	Gas shortage
13	Madanganj 102 PP(Summit)	NENP	6'11	102	0	102412	
14	Madanganj-55 MW PP(Summit)	IPP	3'17.08+1'11.3	55	0	226452	Reserve
15	Keraniganj 100 MW PP (Powerpac)	QRPP	8'13.45	0	0	0	Contract Expired
16	Narsingdi 22 MW PP (Doreen)	SIPP, REB	8'2.90	22	13	302148	Engine problem
17	210 MW Siddhirgonj TPP	PDB	1'210	115	0	0	Under maint.
18	Siddhirgonj 2'120 MW GTTP	EGCB	2'105	210	0	0	Gas shortage
19	Siddhirgonj 100 PP(Dutch Bangla)	NENP	12'8.9	100	12	226560	Low demand
20	Siddhirgonj 335 MW CCPP	EGCB	1'217+118	335	0	0	Gas shortage
21	Gagnagar 102 MW PP (Digital Power)	IPP	12'8.924	102	50	850608	Fuel shortage
22	Kaipoti 52 MW PP (Sirsha)	IPP	7'7.9	0	0	0	Fuel shortage
23	Kamalaghat 54 MW PP(Banco Energy)	IPP	3'18	54	54	348480	
24	Kodda 150MW PP	BPDB-RPCL	9'17.06	149	0	97920	Reserve
25	Manikganj 55 MW PP (Northern)	IPP	3'19.3	55	55	468060	
26	Nabaganj 55 MW PP (Southern power)	IPP	3'19.3	55	17	412466	Engine problem
27	Bosila 108MW PP(CLC)	IPP	12'8.775+1'3.5	0	0	0	
28	Summit Power (Madhabdi+Ashulia)	SIPP, REB	3'3.67+4'8.73	80	66	1089240	Engine problem
29	Madona 33 MW PP(Summit)	SIPP, REB	4'8.73	33	16	462000	Engine problem
30	Rugganj 33 MW PP(Summit)	SIPP, REB	4'8.73	33	33	723300	
31	Gasipur 52 MW PP	RPCL	6'8.9	52	8	144480	Low demand
32	Tongi 80 MW GTTP	PDB	1' 105	105	0	0	Under maint.
33	Kodda 300 MW PP Unit-2 (Summit)	IPP	18'17.076	300	210	2616981	High voltage
34	Keraniganj 300 MW PP (APR)	IPP	256'1.4	300	0	0	Fuel conservation
35	Bramhanaganj 100 MW PP (Aggreko)	IPP	114'9.959	100	0	0	Fuel conservation
36	Aurahati 100MW PP (Aggreko)	IPP	0.85'23+0.95'91	100	0	0	Fuel conservation
37	Kodda 149 MW PP Unit-1 (Summit)	IPP	8'18.45+8.97	149	135	1327680	Engine problem
38	Gasipur 100 MW PP	RPCL	6'17.5	105	17	854400	High voltage
39	Meghnaghat 104 MW PP (OPCL)	IPP	18.5'6	104	55	1236480	Fuel shortage
40	Manikganj 162MW PP(MPGL)	IPP	9'18	162	54	610560	Fuel shortage
41	Spectra Solar Plant Ltd.	IPP	35	35	0	181945	
42	Kanchan Furibachal Power Generation Ltd.	IPP	18.4'3	55	4	183240	Fuel shortage
Dhaka area Total				5847	2167	45541942	
43	Chattogram TPP-1	PDB	1'210	180	0	0	Machine problem
44	Chattogram TPP-2	PDB	1'210	180	0	0	Gas shortage
45	Racozan 25 MW PP	RPCL	3'8.9	25	8	122666	High voltage
46	Teknaf 20MW PP (Solaritech)	IPP	20	20	0	120690	Gas shortage
47	Palenga 50MW PP (Baraka)	IPP	8'6.98	50	19	120960	High voltage
48	Kapita Hydro: Unit-1,2,3,4, 5	PDB	2'40+3'50	230	46	1099800	Low water level
49	Sikalbaha 225MW	PDB	1'150+1'175	225	151	3483004	ST Under maint
50	Sikalbaha Peaking GT	PDB	1'150	150	0	0	Under maint.
51	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	6'17.5	105	66	575418	High voltage
52	Halizhari 100 MW peaking PP	PDB	11'8.9	98	0	243888	Fuel shortage
53	Dohazari -Kalaish 100 MW Peaking	PDB	6'17	102	51	294722	Fuel shortage
54	Juldah 100 MW Unit-1 (Accorn)	NENP	8'13.45	100	10	264600	Fuel shortage
55	Juldah 100 MW PP Unit-3 (Accorn)	IPP	8'13.5	100	12	289920	Fuel shortage
56	Barabkundia 22 MW PP (Regent)	SIPP, PDB	8'2.90	22	0	0	Engine problem
57	Malancha, Ctr. EPZ Unit-1 (ECVP)	IPP	5'8.73+9.34	0	16	361920	
58	Chattogram 108 MW PP (ECVP)	IPP	16'7	108	0	0	Fuel shortage
59	Kapita 7 MW Solar PP	PDB	7.4 MW	7	0	24719	
60	Anwara 300 MW PP (United)	IPP	17'17+24	300	294	2456400	
61	Jodiac Power	IPP	3'18.55+1'3.6	54	36	662445	Engine problem
62	Karnaphuli Power Ltd.	IPP	18.415'6+8.5	110	72	1461121	Fuel shortage
63	Juldah unit-2 (Accorn)	IPP	8'13.6	100	12	302400	Low demand
64	Anilima Energy Ltd.	IPP	6'21.2	116	89	2154055	Engine problem
65	Minsharai 150 MW	BPDB-RPCL	18.5'9	0	0	0	On test.
Chattogram area Total				2382	882	14038728	
66	Ashuganj TPP Unit- 3	APSCL	1'150	0	0	0	Contract Expired
67	Ashuganj TPP Unit- 4	APSCL	1'150	0	0	0	Contract Expired
68	Ashuganj TPP Unit- 5	APSCL	1'150	134	0	0	Gas shortage
69	Ashuganj 225 MW CCPP	APSCL	1'142+1'175	221	183	4537000	Gas shortage
70	Ashuganj 450 MW CCPP(North)	APSCL	1'360	360	270	7467600	Gas shortage
71	Ashuganj 450 MW CCPP(South)	APSCL	1'360	360	75	1137000	
72	Ashuganj 420 MW CCPP(East)	APSCL	284'1+136'1	284	0	0	On test.
73	Ashuganj 50 MW PP	APSCL	14'3.968	45	44	1030608	
74	Ashuganj 55 MW PP (Precision)	QRPP	15'14	55	20	508800	Gas shortage
75	Ashuganj 195MW PP (APSCL-United)	IPP	20'9.73+1'16	195	118	2760000	Gas shortage
76	Ashuganj 51 MW PP (Midland)	IPP	6'9.34	51	5	426340	Gas shortage
77	Ashuganj 150MW PP (Midland)	IPP	23'7.015	150	98	819636	Fuel shortage
78	Titae 50 MW Peaking PP	PDB	6'8.92	52	0	252192	Reserve
79	Chandpur 150 MW CCPP	PDB	1'106+1'57	163	0	0	Machine problem
80	Chandpur 200MW (Desh energy)	IPP	12'18.4	200	34	933600	High voltage
81	Feni 22MW PP (Doreen)	SIPP, PDB	8'2.90	22	20	457380	
82	Feni 11 MW PP (Doreen)	SIPP, REB	4'2.90	11	8	195300	Engine problem
83	Import (Tripura)	Imported power	0	160	94	1952640	
84	Jangalia 33MW PP (Summit)	SIPP, PDB	4'8.73	33	33	814700	
85	Jangalia 52 MW PP (Lakshmi)	IPP	8'9.92	52	8	89789	Fuel shortage
86	Cumilla 25 MW PP (Summit)	SIPP, REB	3'3.67+2'6.97	25	15	322300	Engine problem
87	Daudkandi 200 MW PP (B.Trac)	IPP	154'1.4	200	0	0	Fuel conservation
88	Feni Lanka Power	IPP	7'18.415+1'9.78	114	0	93480	High voltage
89	Chowmuhani 113 MW	IPP	12'9.78+2'3.1	113	26	711480	High voltage
90	Bharat 54.5 MW	IPP	3'18.2	54	17	444400	Engine problem
91	Chandpur 115 (Doreen)	IPP	4'18.5+2'22.5	115	50	715200	High voltage
Cumilla Area Total				3169	1118	25669645	
92	RPCL 210MW CCPP	IPP	4'35+1'70	202	64	1800960	Gas shortage
93	Tangail 22 MW PP (Doreen)	SIPP, PDB	8'2.90	22	13	305028	Gas shortage
94	Jamalpur 95 MW PP(Powerpac)	IPP	12'8.924	0	0	0	Under maint.
95	Sarishabadi 3 MW Solar Plant	IPP	1'3	3	0	12600	
96	Mymensingh 200 MW PP (United)	IPP	9'78'21	200	57	1161600	Fuel shortage
97	Jamalpur 115 MW PP (United)	IPP	9'78'12	115	59	1100400	Fuel shortage
98	Sutiakhali 50 MW Solar PP	IPP	50	50	0	299160	
99	Tangail Pali Power Gen 22 MW	IPP	4'6.7	22	12	275760	Engine problem
Mymensingh Area Total				614	205	4955508	
100	Fenchuganj CCPP Phase-1	PDB	2'32+1'33	70	30	716000	Machine problem
101	Fenchuganj CCPP Phase-2	PDB	2'35+1'35	90	42	970800	Machine problem
102	Kushibara 163 MW CCPP (KP)	IPP	1'109+1'54	163	0	0	Gas shortage
103	Shajibazar 330 MW CCPP	PDB	3'110	330	0	0	Under maint.
104	Fenchuganj 51 MW PP (Barakattullah)	RPP	19'2.90	51	31	687600	Gas shortage
105	Fenchuganj 44MW (Energyprima)	NENP	12'3.3+5'2	50	49	1032912	
106	Haldiganj 11MW PP Confidence-E	SIPP, REB	4'2.90	11	8	192310	Engine problem
107	Shajibazar GTTP Unit- 3 & 9	PDB	2'35	66	33	708480	GT-8 under maint.
108	Shajibazar 86MW PP (Shajibazar)	RPP	32'2.90	86	81	583680	
109	Shajibazar 100 MW GTTP	PDB	1'100	100	0	0	Under maint.
110	Sylhet 225 MW CCPP	PDB	1'142+1'89	231	218	5261950	
111	Sylhet 20 MW GTTP	PDB	1'20	20	18	432000	
112	Sylhet 50MW PP (EPL)	NENP	27'2	50	0	273240	Gas shortage
113	Shahjahanulla 25 MW PP	SIPP, REB	3'9.34	25	24	532080	
114	Bibiana-II 341 MW CCPP (Summit)	IPP	1'222+1'119	341	0	0	Under maint.
115	Bibiyana-III 400 MW CCPP	PDB	400 MW	400	400	8747000	
116	Sylhet 10MW PP (Desh)	RPP	6'1.95	10	10	248040	
117	Bibiyana South 400 MW	PDB	400 MW	385	250	5675400	ST Under maint
Sylhet Area Total				2477	1205	28061492	
118	Bheramara GTTP Unit-3	PDB	1'20	16	0	0	Fuel shortage
119	Bheramara (HVDC)	Imported power	2'500	1000	795	14131636	
120	Khulna 115 PP MW (KPCL-2)	NENP	7'17	115	32	291840	High voltage
121	Fandpur 50 MW Peaking PP	PDB	8'6.89	54	0	0	Line O/L
122	Khulna 225 MW CCPP	NWPGCL	1'150+1'175	230	0	0	Fuel shortage
123	Gosairhat 100 MW Peaking PP	PDB	16'8.98	109	0	0	Line O/L
124	Bheramara 410 MW CCPP	NWPGCL	1'278+1'132	410	0	0	Under maint.
125	Noapara 40 MW PP (Khanjahan Ali)	NENP	5'8.5	40	0	11625	Fuel shortage
126	Noapara 100 MW PP (Bangla Trac)	IPP	70'1.4	100	0	0	Fuel conservation
127	Rupsha 105 MW PP (Orion rupsha)	IPP	6'18.445	105	74	1275840	Engine problem
128	Madhumati 100 MW PP	NWPGCL	6'18	105	0	0	Fuel shortage
129	Mongia Orion 100 MW Solar PP	IPP	100	100	0	439920	
130	Khulna 330 MW CC						