

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month December, 2022				Day : Wednesday				Date : 14.12.22						
Probable Maximum Demand : 10000 MW				Probable Maximum Generation : 11389 MW				Rule Curve = 104.80 ft.						
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 88.51 ft Today = 88.39 ft										
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	13.12.22 (Yesterday)		14.12.22 (Today)		13.12.22 (Yesterday)		14.12.22 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Machines shut down (MW)			
					Day	Evening	Day	Evening					Description/ Remarks	Probable start-up date
(A) Plants in operation:														
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260		Under project work	
2	a) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0				Line Overload	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180					
3	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	200	0	0					
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	3x43.35	108	108	56	47	64	64	61			Gas Shortage	
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105			Gas Shortage	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0				Contract Expired	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	349	312	320	320					
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225			Gas Shortage	
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115		Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	402	390	400	400					
11	Siddhirganj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210			Gas Shortage	
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	217	118		Gas Shortage	
13	Meghnaghat CAPP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0	335			Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	55	15	55					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	33	50	33	50					
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	19	19					
17	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	49	39	42	42					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	20	33					
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	32	32					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	50	44	50	50					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	70	70	105					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	48	32	64					
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	97	278	98	282					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	53	84	90	149					
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	150					
27	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	50					
28	Auraihat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	50					
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	17	17	17					
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	35	35	55					
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	54	58	55	58					
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	162	17	162					
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	22	0	30	0					
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	9	28	18	18					
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	55	55	50	87					
36	Meghnaghat 100 MW(HEL)	HFO (NENP)	12x8.9	100	100	26	33	35	42					
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	94	80	100	100					
Dhaka Zone Total				6004	5847	2009	2621	2064	2913	1153	493			
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	46	46	46	46	184			Low water level	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180			Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0					
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	17	25					
42	Teknaf 20MW PP (SolarTech)	Solar (IPP)	1x20	20	20	18	0	20	0					
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	20	0	20	20					
44	Sikalbaha 105 MW PP (Baraka Sikabaha)	HFO (IPP)	6x18.415	105	105	17	51	20	51					
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150			Under maint.	
46	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	147	150	150	78			STG Under maint.	
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x6.04	300	300	235	250	200	300					
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	12	12	12	12					
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	51	17	50					
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	32	0	22	40					
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0	22			Gas Shortage	
*	Malancha, Cig.EP2 (United)	Gas	5x8.73+3x9.34			2	18	5	10					
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0					
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	36	17	36					
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	54	92	54	92					
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	12	12	12	12					
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	10	10	10	10					
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	89	107					
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0				on test	
Chattogram Zone Total				2442	2382	628	857	716	961	386	408			
58	Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134			Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	30	30	30	30					
60	Ashuganj 225 MW CAPP	Gas (APSCCL)	1x142+117.5	221	221	214	203	200	200					
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	350	305	320	320					
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	0	0	0	0	360			Gas Shortage	
63	Ashuganj 420 MW CAPP(East)	Gas (APSCCL)	1x284+1x116	400	400	407	348	335	350	52			Gas Shortage	
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	5	5	5	5	50			Gas Shortage	
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+11'16	195	195	8	8	8	8	187			Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	5	5	5	5	46			Gas Shortage	
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	13	108	15	108	42			Gas Shortage	
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	37	0	30	35					
69	Chandpur 150 MW CAPP	Gas (PDB)	1x106+1x57	163	163	0	0	0	0	163			Under maint.	
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	51	34	200					
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	19	21	21					
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	10	10	10					
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	15	16	29	30					
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	8	8	8					
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	12	15	15					
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	9x1.4+8x1.515+15x1.098	200	200	0	0	0	100					
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	17	0	17	17					
78	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	99	65	65	113					
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17					
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	35	51	34	34					
**	Import (Tripura)	India		160	160	96	114	143	166					
Cumilla Zone Total				3309	3285	1411	1375	1341	1792	871	163			
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	33	53	70	75	149			Gas Shortage	
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	19	19					
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	58	59	47	59					
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	57	56	50	57					
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0					
86	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	43	0	50	0					
87	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	12	12	12	12					
Mymensingh Zone Total				622	614	224	199	250	222	149	0			

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	13.12.22 (Yesterday)		14.12.22 (Today)		13.12.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)		
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30		40	GT-1 Under maint.	
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42		48	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	11	45	11		40		
91	Kushlari 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0		54	STG Under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	8				
93	Shahjibazar GTTP Unit-8 & 9	Gas (PDB)	2x35	70	66	61	62	64				
94	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	45	84	20		86		
96	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	218	219	218				
97	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	18	18	19				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	21	22	22				
100	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	0	0	0		341	Major Inspection	31/12/2022
101	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	414	419	400				
102	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	260	260	260		123	ST Under maint.	
103	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0		100	Under project work	
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	11	11	11				
105	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	20	35	30		44		
Sylhet Zone Total					2522	2477	1169	1256	1145	1254	0	1036
106	Bheramara GTTP Unit-3	HSD (PDB)	1 x 20	20	16	0	0	0		0		
107	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0		410	Under maint.	
108	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0		38		
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	84	0		80		
110	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0		0		
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	0		50		
112	Rupsha 105 MW PP (Orion nupsha)	HFO (IPP)	6x18.445	105	105	17	64	17		75		
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0		0		
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	63	0	100		0		
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	16	32		66		
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	0	0		40		
	Rampal 1320 MW	Coal (BIFPCL)				554	506	550		550		
	Khulna 330 MW CAPP	Gas/HSD (BPDB)				0	0	0		0		
**	Bheramara (H/DC)	India		1000	1000	911	908	934		934		
Khulna Zone Total					2388	2384	1545	1578	1633	1833	0	410
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	0		110	Line Overload	
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	18	21	18		25		
119	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	177	160	187		187		
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	250	280	300		350		
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0		35	Line Overload	
	Barisal Electric 307 MW	Coal (IPP)				0	0	0		0		
122	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	160	220	220		220		
Barisal Zone Total					1958	1958	605	681	725	817	0	260
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	70	70	50		70		
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0		100	Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0		32		
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0		0		
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0		25		
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	42	0		89		
128	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	40	0		40		
129	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	42	50	16		50		
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	34	0		35		
131	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	150	115	180		210	Gas Shortage	
132	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0		220	Gas Shortage	
133	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0		0	Under maint.	
134	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	397	397	400		410		
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	7	11	11		11		
136	Uliapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	5	5		5		
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.52	52	52	8	8	8		8		
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6'18.55	113	113	35	35	35		113		
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	78	35		113		
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	3	0	6		0		
	Adani Power Jharkhand Ltd	Coal				0	0	0		0		
Rajshahi Zone Total					2129	2129	752	885	746	1211	415	220
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0		85	Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0		85	Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	159	160	160		160	Coal Shortage	
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0		0		
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	34	49	34		113		
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0		0		
146	Maipara, Tabulia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8		0		
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6'20	115	115	17	70	35		113		
148	Lalmohithal 30 MW Solar (Intraco)	Solar (IPP)	1'30	30	30	20	0	30		0		
	Teesa Solar Limited	Solar (IPP)				78	0	0		0		
Rangpur Zone Total					830	750	313	279	267	386	199	85
Sub-total: Plants in operation					22204	21826	8656.0	9740	8887	11389	3173	3075
(B) Plants under long term maintenance/ contract expired												
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0		0		
150	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0		0		
151	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0		0		
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0		0		
153	Amuria 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0		0		
Sub-Total: Plants under long term maintenance/ contract expired					404	0	0	0	0	0		
Gross Total					22608	21826	8656	9740	8887	11389	3173	3075
(C) Actual data of 13.12.22 (Yesterday) Tuesday :												
01.	Max. Demand at eve. peak (Generation end)	:	9740	MW, at =	18:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :					
02.	Max. Demand at eve. peak (Sub-station end)	:	9397	MW, at =	18:00 hrs		Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW
03.	Highest Generation (Generation end)	:	9740	MW, at =	18:00 hrs							Supply MW
04.	Minimum Generation (Generation end)	:	6336	MW, at =	5:00 hrs		Dhaka	3542	3542	0	Mymensingh	758
05.	Day-peak Generation (Generation end)	:	8656	MW, at =	12:00 hrs		Chattogram	1045	1045	0	Sylhet	362
06.	Evening-peak Generation (Generation end)	:	9740	MW, at =	18:00 hrs		Khulna	1097	1097	0	Barisal	219
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at =	18:00 hrs		Rajshahi	929	929	0	Rangpur	673
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6338	MW, at =	5:00 hrs		Cumilla	772	772	0		0
09.	Generation shortfall at evening peak due to :	:									Total	9397
	a) Gas/LF limitation	:	2790	MW								9398313
	d) Coal supply Limitation	:	199	MW								715052965
	b) Low water level in Kaptai lake	:	184	MW								Taka
	c) Plants under shut down/ maintenance	:	3075	MW								Taka
10.	Total Energy (Generation + India Import)	:	196.67	MKWh								
	By Gas = 109.574 MKWH			By Oil = 37.992 MKWh								
	By Coal = 24.305 MKWH			By Hydro = 1.092 MKWh								
	By Solar = 1.490 MKWH											
11.	Total Gas Supplied	:	852.13	MMCFD								
(D) Forecast of 14.12.22 (Today) Wednesday :												
01.	Maximum Demand	:	10000	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)	
02.	Maximum Generation	:	11389	MW	(Generation end)	05.	Total Generation	:	201.92	MKWh		
03.	Reserve / Shortage	:	1389	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	27.0° C			

#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helaur Rahman)
Deputy Secretary, Generation