

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month December, 2022				Day : Monday				Date : 19.12.22							
Probable Maximum Demand : 10200 MW				Probable Maximum Generation : 10974 MW				Rule Curve = 104.30 ft.							
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 87.91 ft		Today = 87.82 ft									
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	18.12.22 (Yesterday)		19.12.22 (Today)		18.12.22 (Yesterday)		19.12.22 (Today)		Status of Machines under shut-down/ Maintenance	Probable start-up date	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Machines shut down (MW)				
					Day	Evening	Day	Evening							
(A) Plants in operation:															
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work			
2	a) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0			Line Overload			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180						
3	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365		Gas Shortage			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	3x43.35	108	108	67	69	65	65	39		Gas Shortage			
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage			
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0			Contract Expired			
7	Haripur 360MW CAPP(HPL)	Gas (IPP)	1x235+1x125	360	360	160	318	270	260	42		Gas Shortage			
8	Meghnaghat 450 MW CAPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225		Gas Shortage			
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling			
10	Haripur 412 MW CAPP	Gas (EGCB)	1x273+1x139	412	412	418	403	390	380						
11	Siddhirganj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage			
12	Siddhirganj 335 MW CAPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	217	118	Gas Shortage			
13	Meghnaghat CAPP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0	335		Gas Shortage			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	15	0	15						
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	25	42	24	40						
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	22	22	22						
17	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	30	44	49	49						
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	30	30	30						
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33						
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	45	32	50	50						
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	105	50	100	100						
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	82	32	32	16						
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54						
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	30	95	30	285						
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	36	35	35	35						
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	150						
27	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	50						
28	Auraihat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	50						
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	55	17	55						
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	17	55						
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	53	55	55	55						
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	162	17	162						
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	30	0	30	0						
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17						
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	50	24	50	50						
36	Meghnaghat 100 MW(HEL)	HFO (NENP)	12x8.9	100	100	48	24	50	50						
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	30	0	100	100						
Dhaka Zone Total					6004	5847	1775	2051	1905	2633	1538	493			
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	46	46	46	46	184		Low water level			
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage			
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.			
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	4	4	5	0							
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	8	8	25						
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	18	0	20	0						
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	19	12	19	19						
44	Sikalbaha 105 MW PP (Baraka Sikabaha)	HFO (IPP)	6x18.415	105	105	17	51	17	51						
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.			
46	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	151	150	150	74		STG Under maint.			
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	51	274	51	300						
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	12	12	12	12						
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	34	0	50						
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	24	0	22	33						
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0	22		Gas Shortage			
*	Malancha, Cig.EP2 (United)	Gas	5x8.73+3x9.34			2	13	2	10						
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0						
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	36	17	36						
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	58	72	72	72						
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	12	12	12	12						
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	10	10	10	10						
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107						
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			37	0	0	0			on test			
Chattogram Zone Total					2442	2382	459	838	570	933	386	404			
58	Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage			
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	42	37	30	30						
60	Ashuganj 225 MW CAPP	Gas (APSCCL)	1x142+1175	221	221	196	183	0	0						
61	Ashuganj 450 MW CAPP(South)	Gas (APSCCL)	1x360	360	360	335	275	300	300						
62	Ashuganj 450 MW CAPP(North)	Gas (APSCCL)	1x361	360	360	0	0	0	0	360		Gas Shortage			
63	Ashuganj 420 MW CAPP(East)	Gas (APSCCL)	1x284+1x116	400	400	369	333	340	320						
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	5	5	50	50	50		Gas Shortage			
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+1'16	195	195	8	8	8	8	187		Gas Shortage			
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51						
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	13	122	12	110	28		Gas Shortage			
68	Titaz 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	21	25	25						
69	Chandpur 150 MW CAPP	Gas (PDB)	1x106+1x57	163	163	0	0	0	0	163		Under maint.			
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	105	17	100						
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	21	21						
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	10	10						
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	33	33	33						
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	8	8	8						
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	15	15	15	15						
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	9x14+6x1515+15x1.098	200	200	0	0	0	100						
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	17	0	17	17						
78	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	9	65	9	113						
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17						
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	36	58	34	58						
**	Import (Tirupura)	India		160	160	108	112	135	153						
Cumilla Zone Total					3309	3285	1302	1479	1132	1539	759	163			
81	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	71	108	70	100						
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	19	19	19						
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	49	56	47	57						
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	58	58	47	56						
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0						
86	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	49	0	50	0						
87	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	12	12	12	12						
Mymensingh Zone Total					622	614	257	253	247	244	0	0			

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derate/ Present Capacity (MW)	18.12.22 (Yesterday)		19.12.22 (Today)		18.12.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)		
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30		40	GT-1 Under maint.		
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42		48	GT-4 Under maint.		
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	11	16	22	22				
91	Kushlari 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0	109	54	STG Under maint.	
92	Hobigang 111MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
93	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	62	62	62				
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	50	84	50	86				
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	220	218	218	218				
97	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	18	19	0	19				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	24	22	22				
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	0	0	0	0		341	Major Inspection	
101	Bibiyan-II 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	395	414	400	400				
102	Bibiyan South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	388	398	400	400				
103	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	11	11	11	11				
105	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	20	45	30	30				
Sylhet Zone Total						2522	2477	1279	1381	1305	1360	109	913
106	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
107	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0		410	Under maint.	
108	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	40				
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	80				
110	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	0				
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	0	50				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	35	0	34				
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0				
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	59	0	100	0				
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	16	49	114				
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	0	0	40				
	Rampal 1320 MW	Coal (BIFPCL)				468	614	500	500				
	Khulna 330 MW CCPP	Gas/HSD (BPDB)				0	0	0	0				
**	Bheramara (H/DC)	India		1000	1000	916	915	928	928				
Khulna Zone Total						2388	2384	1443	1580	1577	1786	0	410
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	0	0		110	Line Overload	
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	18	23	17	24				
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	158	183	184	184				
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	250	430	450	480				
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	35		150	Line Overload	
	Barisal Electric 307 MW	Coal (IPP)				0	0	0	0				
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	108	108	0	220				
Barishal Zone Total						1958	1958	534	744	651	943	0	260
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	32				
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	25				
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	35	0	90				
128	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	40				
129	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	8	24	16	50				
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	35	0	35				
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	190	219	180	180				
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0		220	Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0			220	Under maint.
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	418	365	400	400		49	Gas Shortage	
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	15	17	18	18				
136	Uliapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	0	5	11	11				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	43	8	43				
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6'18.55	113	113	70	75	35	113				
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	70	94	35	113				
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0				
	Adani Power Jharkhand Ltd	Coal				0	0	0	0				
Rajshahi Zone Total						2129	2129	784	912	709	1150	440	220
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0			85	Under Overhauling
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	160	160	160	160		114	Coal Shortage	
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	35	107	40	113				
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Majpara, Tabulia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0				
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6'20	115	115	75	72	35	113				
148	Lalmohithal 30 MW Solar (Intraco)	Solar (IPP)	1'30	30	30	25	0	30	0				
	Teesha Solar Limited	Solar (IPP)				11.4	0	0	0				
Rangpur Zone Total						830	750	414	339	273	386	199	85
Sub-total: Plants in operation						22204	21826	8247.0	9577	8369	10974	3431	2948
(B) Plants under long term maintenance/ contract expired													
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
150	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
151	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
153	Amuria 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0				
Sub-Total: Plants under long term maintenance/ contract expired						404	0	0	0	0	0		
Gross Total						22608	21826	8247	9577	8369	10974	3431	2948
(C) Actual data of 18.12.22 (Yesterday) Sunday :													
01.	Max. Demand at eve. peak (Generation end)	:	9577 MW, at =	19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	9082 MW, at =	19:00 hrs		Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	9577 MW, at =	19:00 hrs		Dhaka	3315	3315	0	Mymensingh	756	756	0
04.	Minimum Generation (Generation end)	:	5929 MW, at =	5:00 hrs		Chattogram	999	999	0	Sylhet	351	351	0
05.	Day-peak Generation (Generation end)	:	8247 MW, at =	12:00 hrs		Khulna	1090	1090	0	Barishal	224	224	0
06.	Evening-peak Generation (Generation end)	:	9577 MW, at =	19:00 hrs		Rajshahi	920	920	0	Rangpur	644	644	0
07.	Evening Peak Load-shed (Sub-station end)	:	0 MW, at =	19:00 hrs		Cumilla	785	785	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6098 MW, at =	5:00 hrs									
09.	Generation shortfall at evening peak due to :	:								Total	9082	9082	0
	a) Gas/LF limitation	:	3048 MW		13.	Fuel cost :	(a) Gas = 107604225 Taka	(c) Coal = 95561883 Taka					
	d) Coal supply Limitation	:	199 MW			(b) Oil = 375160355 Taka		578326463 Taka					
	b) Low water level in Kaptai lake	:	184 MW										
	c) Plants under shut down/ maintenance	:	2948 MW		14.	Maximum Temperature in Dhaka was :	27.0° C						
10.	Total Energy (Generation + India Import)	:	183.98 MMCFD		15.	Export through East-West interconnections :							
	By Gas = 104.689 MKWH		By Oil = 29.057 MKWH			At evening peak-hour	:	8247 MW, at	19:00 hrs				
	By Coal = 24.910 MKWH		By Hydro = 1.103 MKWH			Maximum	:	72 MW, at	7:00 hrs				
	By Solar = 1.829 MKWH					Energy	:	0 MKWh					
11.	Total Gas Supplied	:	815.58 MMCFD										
(D) Forecast of 19.12.22 (Today) Monday :													
01.	Maximum Demand	:	10200 MW (Generation end)		04.	Maximum Load-shed	:	0 MW	At evening peak (Sub-station end)				
02.	Maximum Generation	:	10974 MW (Generation end)		05.	Total Generation	:	195.94 MMWh					
03.	Reserve / Shortage	:	774 MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	25.9° C						

* Coactive Power ** Imported Power
#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helaur Rahman)
Deputy Secretary, Generation