

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month December, 2022					Day : Thursday				Date : 22.12.22				
Probable Maximum Demand : 9800 MW					Probable Maximum Generation : 10911 MW								
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 87.59 ft		Today = 87.47 ft		Rule Curve = 104.00 ft.				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	21.12.22 (Yesterday)		22.12.22 (Today)		21.12.22 (Yesterday)		22.12.22 (Today)		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Machines shut down (MW)		
					Day	Evening	Day	Evening	Description/ Remarks		Probable start-up date		
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0			Line Overload	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	170	0	0	0		190	Under maint.	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	160	190	190			ST under maint.	
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	65	70	70	70		38	Gas Shortage	
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	Gas Shortage	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0			Contract Expired	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	353	313	315	315				
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225		225	Gas Shortage	
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	356	398	400	400				
11	Siddhirganj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0		210	Gas Shortage	
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0		217	Gas Shortage	
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0		335	Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	20	0	15				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	16	33	24	33				
16	Narshingsi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	22	19	22				
17	Summit Power,(Madhabdi+Ashula)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	42	33	45	49				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	28	28	25	30				
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	32	33	33				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	38	45	50	50				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	105	100	105				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	54	150	149	149				
23	Karnalaghat 54 MW PP (Barako Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	32	97	30	96				
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	35	35	35	35				
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	150				
27	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	50				
28	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	50				
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	35	17	55				
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	17	55				
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	17	17	17				
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	162	17	162				
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	23	0	30	0				
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	55	17	17	17				
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	33	33	33	33				
36	Meghnaghat 100 MW(IEL)	HFO (NENP)	12x8.9	100	100	33	33	33	33				
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	65	45	34	34				
Dhaka Zone Total				6004	5847	1861	2197	1942	2527	1130	683		
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	46	46	46	46		184	Low water level	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0				
41	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	12	8	25				
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0				
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	19	19	19	19				
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	57	17	51				
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.	
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	151	151	150	150		74	STG Under maint.	
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	50	286	51	300				
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	12	12	12	12				
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	0	50				
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	24	32	32	32				
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0		22	Gas Shortage	
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	8	5	10				
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	8	0	0				
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	36	17	36				
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	73	73	52	54				
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	12	13	12	12				
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	10	10	10	10				
57	Chattogram 116 MW PP (Anilima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	92	107	107	107				
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	7	0	0			on test	
Chattogram Zone Total				2442	2382	565	928	563	914	386	404		
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0		134	Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	38	35	35	35				
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1x75	221	221	0	0	200	200		221	under maint.	
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	320	320	320	320				
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	0	0	0	0		360	Gas Shortage	
63	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	377	400	320	320				
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	56	40	5	5				
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'16	195	195	55	55	8	8		140	Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51				
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	12	100	12	100		50	Gas Shortage	
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	29	25	25				
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163	Under maint.	
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	17	17	50				
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	20	21	21				
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	16	15	33	33				
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	8	8	8				
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	6	15	15	15				
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+40x1.515+15x1.056	200	200	0	0	0	100				
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	52	99	17	17				
78	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	9	9	9	9				
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17				
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	35	52	24	52				
**	Impoport (Tripura)	India		160	160	105	122	135	153				
Cumilla Zone Total				3309	3285	1204	1415	1283	1550	684	384		
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	35	45	45	100		157	Gas Shortage	
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	20	17	20				
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	49	59	49	59				
84	Myemensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	48	57	46	58				
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
86	Sutiakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	39	0	50	0				
87	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	12	12	12	12				
Myemensingh Zone Total				622	614	202	193	221	249	157	0		

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	21.12.22 (Yesterday)		22.12.22 (Today)		21.12.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/Coal/oil/ Water Limitation MW	Machines shut down (MW)		
88	Fenchugonj CCGP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30		40	GT-1 Under maint.	
89	Fenchugonj CCGP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42		48	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	11	31	11	30			
91	Kushiera 163 MW CCGP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0	109	54	STG Under maint.
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8			
93	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	59	64	65	65			
94	Shahjibazar 330 MW CCGP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330		Under maint.
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	50	86	50	86			
96	Sylhet 225 MW CCGP	Gas (PDB)	1x142+1x89	231	231	218	218	218	218			
97	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	18	19	19	19	19			
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10			
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	21	24	22	22			
100	Bibiana-II 341 MW CCGP (Summit)	Gas (IPP)	1x222+1x119	341	341	0	0	0	0	341	Major Inspection	31/12/2022
101	Bibiyana-III 400 MW CCGP	Gas (PDB)	1x285+1x115	400	400	420	420	400	400			
102	Bibiyana South 383 MW CCGP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400			
103	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0	100	Under project work	
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	15	15	15	15			
105	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	10	47	20	45			
Sylhet Zone Total					2522	2477	1311	1414	1310	1390	109	913
106	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
107	Bheramara 410 MW CCGP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410	Under maint.	
108	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	40			
109	Gopalgarj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	70			
110	Khulna 225 MW CCGP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	0			
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	0	50			
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	17	17	17			
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0			
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	64	0	100	0			
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	66	0	66			
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	24	0	40			
	Rampal 1320 MW	Coal (BIFPCL)				627	628	630	630			
	Khulna 330 MW CCGP	Gas/HSD (PDB)				0	0	0	0			
Bheramara (HVDCL)					1000	1000	917	917	934	934		
Khulna Zone Total					2388	2384	1608	1652	1681	1847	0	410
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	0	0			
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	16	19	19	19			
119	Bhola 225 MW CCGP	Gas (PDB)	2x63+1x68	194	194	180	158	184	184			
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	250	310	400	520			
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	35	150	Line Overload	
	Barisal Electric 307 MW	Coal (IPP)				0	0	0	0			
122	Bhola 220MW CCGP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	180	220	180	220			
Barisal Zone Total					1958	1958	626	707	783	978	0	260
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	32			
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0			
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	25			
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	51	0	51			
128	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	40	0	40			
129	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	34	42	25	50			
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	29	0	35			
131	Sirajgonj 225MW CCGP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	150	130	190	200			
132	Sirajgonj 225MW CCGP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	3	157	0	0	63	Gas Shortage	
133	Sirajgonj 225MW CCGP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220	220	Under maint.
134	Sirajgonj 400 MW CCGP Unit-4	Gas (IPP)	1x282+1x132	414	414	270	210	370	370	204	Gas Shortage	
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	17	17	17	17			
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8			
137	Natore 52 MW PP (Rajjanka)	HFO (IPP)	6x8.92	52	52	8	34	34	34			
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	37	95	35	113			
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	74	35	95			
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0			
	Adani Power Jharkhanda Ltd	Coal				0	0	0	0			
Raishahi Zone Total					2129	2129	566	887	720	1070	658	220
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	159	160	160	160	114	Coal Shortage	
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	34	100	34	113			
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
146	Majpara, Talata 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0			
147	Thakurgaon 115MW PP (Energypac)	HFO (QRPP)	6*20	115	115	115	115	35	113			
148	Lalmouri 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	21	0	30	0			
	Teesta Solar Limited	Solar (IPP)				103	0	0	0			
Rangpur Zone Total					830	750	437	375	267	386	199	85
Sub-total: Plants in operation					22204	21826	8380.0	9768	8770	10911	3323	3359
(B) Plants under long term maintenance/ contract expired												
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			
150	Kaipoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
151	Bossia 108MW PP(PCLCL)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0			
153	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.75	50	0	0	0	0	0			Contract Expired on 11/01/2022
Sub-Total: Plants under long term maintenance/ contract expired					404	0	0	0	0	0		
Gross Total					22608	21826	8380	9768	8770	10911	3323	3359
(C) Actual data of 21.12.22 (Yesterday) Wednesday :												
01.	Max. Demand at eve. peak (Generation end)	:	9768	MW, at =	18:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :					
02.	Max. Demand at eve. peak (Sub-station end)	:	9486	MW, at =	18:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply
03.	Highest Generation (Generation end)	:	9771	MW, at =	18:00 hrs		MW	MW	MW		MW	MW
04.	Minimum Generation (Generation end)	:	6286	MW, at =	5:00 hrs	Dhaka	3535	3535	0	Mymensingh	758	758
05.	Day-peak Generation (Generation end)	:	8380	MW, at =	12:00 hrs	Chattogram	1083	1083	0	Sylhet	363	363
06.	Evening-peak Generation (Generation end)	:	9768	MW, at =	18:00 hrs	Khulna	1114	1114	0	Barisal	264	264
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at =	18:00 hrs	Rajshahi	907	907	0	Rangpur	676	676
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6347	MW, at =	5:00 hrs	Cumilla	786	786	0			
09.	Generation shortfall at evening peak due to :	:								Total	9486	9486
	a) Gas/LF limitation	:	2940	MW								
	d) Coal supply Limitation	:	199	MW								
	b) Low water level in Kaptai lake	:	184	MW								
	c) Plants under shut down/ maintenance	:	3359	MW								
10.	Total Energy (Generation + India Import)	:	193.75	MW								
			By Gas = 112.020	MW								
			By Coal = 25.136	MW								
			By Solar = 1.626	MW								
11.	Total Gas Supplied	:	820.69	MMCFD								
(D) Forecast of 22.12.22 (Today) Thursday :												
01.	Maximum Demand	:	9800	MW	(Generation end)	04.	Maximum Load-shed					
02.	Maximum Generation	:	10911	MW	(Generation end)	05.	Total Generation					
03.	Reserve / Shortage	:	1111	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :					

* Captive Power ** Imported Power

#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation