

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month December, 2022					Day : Tuesday				Date : 27.12.22			
Probable Maximum Demand : 9800 MW					Probable Maximum Generation : 10484 MW				Rule Curve = 103.30 ft.			
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 86.95 ft Today = 86.89 ft							
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	26.12.22 (Yesterday)		27.12.22 (Today)		26.12.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	Probable start-up date
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW			
					Day	Evening	Day	Evening	Machines shut down (MW)	Description/ Remarks		
(A) Plants in operation:												
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work
2	a) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0			Line Overload
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0		190	Under maint.
3	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	200	200	200	200			ST under maint.
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	3x43.35	108	108	70	73	70	70	35		Gas Shortage
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			Contract Expired
7	Haripur 360MW CAPP(HPL)	Gas (IPP)	1x235+1x125	360	360	346	333	330	330			
8	Meghnaghat 450 MW CAPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225		Gas Shortage
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
10	Haripur 412 MW CAPP	Gas (EGCB)	1x273+1x139	412	412	403	402	400	400			
11	Siddhirganj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage
12	Siddhirganj 335 MW CAPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	217	118	Gas Shortage
13	Meghnaghat CAPP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0	335		Gas Shortage
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	20	0	20			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	16	16	16	16			
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	22	22	22			
17	Summit Power,(Madhabadi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	52	52	52	52			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	30	25	30			
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	28	28	28	28			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	49	48	50	50			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	105	105	90	105			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	32	32	32			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	32	95	32	95			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	35	35	35	35			
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	204	44	0	150			
27	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	92	50	0	50			
28	Auraihat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	87	70	0	50			
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	55	35	55			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	18	17	17	17			
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	162	17	162			
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	22	0	30	0			
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17			
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	16	16	16	16			
36	Meghnaghat 100 MW(HEL)	HFO (NENP)	12x8.9	100	100	0	17	17	17			
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	34	34	34	34			
Dhaka Zone Total					6004	5847	2216	2307	1842	2387	1127	683
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	30	30	30	200		Low water level
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	4	0	5	0	0			
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	10	17	17	17			
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	18	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	0	0	0			
44	Sikalbaha 105 MW PP (Baraka Sikabaha)	HFO (IPP)	6x18.415	105	105	17	51	17	51			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.
46	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	40	152	150	150		73	STG Under maint.
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	51	290	51	290			
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	12	12	12	12			
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	36	0	50			
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	40	0	40			
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0	22		Gas Shortage
*	Malancha, Cig.EP2 (United)	Gas	5x8.73+3x9.34			2	14	5	15			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	10	0	10			
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	35			
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	60	72	72	72			
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	12	12	12	12			
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	10	10	10	10			
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107			
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0			on test
Chattogram Zone Total					2442	2382	390	870	525	901	402	403
58	Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	5	0	5	5			
60	Ashuganj 225 MW CAPP	Gas (APSCCL)	1x142+117.5	221	221	218	131	150	150			
61	Ashuganj 450 MW CAPP(South)	Gas (APSCCL)	1x360	360	360	345	270	0	0			
62	Ashuganj 450 MW CAPP(North)	Gas (APSCCL)	1x361	360	360	0	10	330	330			
63	Ashuganj 420 MW CAPP(East)	Gas (APSCCL)	1x284+1x116	400	400	297	258	330	330			
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	0	0	5	5			
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+11'16	195	195	8	0	8	8	195		Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	6	72	3	70	78		Gas Shortage
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	30	21	25	30			
69	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163	Under maint.
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	51	17	51			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	21	21			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	10	10			
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	28	33	30	33			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	8	8	8			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	9	20	20	20			
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+8x15.15+15x1.08	200	200	85	10	0	100			
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	17	100	17	17			
78	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	9	9	8	9			
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17			
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	36	54	0	0			
**	Import (Tripura)	India		160	160	108	112	135	152			
Cumilla Zone Total					3309	3285	1317	1258	1190	1417	407	163
81	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	33	53	70	100	149		Gas Shortage
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	20	19	19			
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	28	47	28	47			
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	48	48	46	48			
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0			
86	Sutahkhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	35	0	50	0			
87	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	0	6	12	12			
Mymensingh Zone Total					622	614	164	174	227	226	149	0

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	26.12.22 (Yesterday)		27.12.22 (Today)		26.12.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gas/Coal/Water Limitation MW	Machines shut down (MW)		
						Day	Evening	Day	Evening			Description/ Remarks	Probable start-up date
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	GT-1 Under maint.	
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	31	43	43		59	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	51	53	53	53				
91	Kushiara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0	109	54	STG Under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
93	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	63	65	66				
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 66MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	30	86	40	86				
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	130	130	130	130				
97	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	19	19	19	19				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	16	16	16				
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	0	0	0	0		341	Major Inspection	31/12/2022
101	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	384	396	400	400				
102	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400				
103	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	24	24	24	24				
105	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	44	47	30	40				
Sylhet Zone Total						2522	2477	1190	1313	1268	1325	109	924
106	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
107	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	0	0	0	0		410	Under maint.	
108	Fandpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	13	0	40				
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	70	0	70				
110	Khulna 225 MW CCPP	HSD (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0				
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	10	0	50				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	12	18	18				
113	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	0	0				
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	73	0	100	0				
115	Khulna 115 MW PP (KFCL-2)	HFO (NENP)	7x17	115	115	0	66	0	99				
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	32	0	40				
	Rampal 1320 MW	Coal (BIFPCL)				468	522	420	520				
	Khulna 330 MW CCPP	Gas/HSD (BIFPCL)				243	0	0	0				
**	Bheramara (HVDC) India			1000	1000	785	904	838	934				
Khulna Zone Total						2388	2384	1569	1629	1376	1771	0	410
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	0	0		110	Line Overload	
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	18	24	18	24				
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	156	180	150	180				
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	300	380	300	400				
121	Potukhalhi 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	35		150	Line Overload	
	Barisal Electric 307 MW	Coal (IPP)				200	253	230	250				
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	108	140	110	110				
Barishal Zone Total						1958	1958	782	977	808	999	0	260
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	32	0	34				
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	10	0	100				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	6	0	25				
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	67	0	67				
128	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	16	40	0	40				
129	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	42	50	50	50				
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	0	32				
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	170	136	150	150		74	Gas Shortage	
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150+1x75	220	220	0	43	15	43		177	Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	0	0	0	0		220	Under maint.	
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	290	154	350	350		260	Gas Shortage	
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	16	18	20	20				
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	8	8	8				
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	75	35	75				
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	70	35	70				
140	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	4	0	6	0				
	Adani Power Jharkhanda Ltd	Coal				0	0	0	0				
Raishahi Zone Total						2129	2129	624	749	677	1072	902	220
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	159	159	160	160		115	Coal Shortage	
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	103	113	34	113				
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0				
147	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	115	115	115	115	35	113				
148	Lalmoinhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	17	0	30	0				
	Treesta Solar Limited	Solar (IPP)				66	0	0	0				
Rangpur Zone Total						830	750	465	387	267	386	200	85
Sub-total: Plants in operation						22204	21826	8717.0	9664	8180	10484	3296	3148
(B) Plants under long term maintenance/ contract expired													
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
150	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
151	Bosilia 108MW PPI(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
153	Ammura 30 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0				Contract Expired on 11/01/2022
	Sub-Total: Plants under long term maintenance/ contract expired			404	0	0	0	0	0				
Gross Total						22608	21826	8717	9664	8180	10484	3296	3148
(C) Actual data of 26.12.22 (Yesterday) Monday :													
01.	Max. Demand at eve. peak (Generation end)		: 9664 MW, at =	19:00 hrs									
02.	Max. Demand at eve. peak (Sub-station end)		: 9330 MW, at =	19:00 hrs									
03.	Highest Generation (Generation end)		: 9664 MW, at =	19:00 hrs									
04.	Minimum Generation (Generation end)		: 6243 MW, at =	5:00 hrs									
05.	Day-peak Generation (Generation end)		: 8717 MW, at =	12:00 hrs									
06.	Evening-peak Generation (Generation end)		: 9664 MW, at =	19:00 hrs									
07.	Evening Peak Load-shed (Sub-station end)		: 0 MW, at =	19:00 hrs									
08.	Minimum Generation Forecast up to 8:00 hrs.		: 5809 MW, at =	5:00 hrs									
09.	Generation shortfall at evening peak due to :												
	a) Gas/LF limitation		: 2896 MW										
	d) Coal supply Limitation		: 200 MW										
	b) Low water level in Kaptai lake		: 200 MW										
	c) Plants under shut down/ maintenance		: 3148 MW										
10.	Total Energy (Generation + India Import)		: 193.08 MKWh										
	By Gas =	106.864 MKWh	By Oil =	35.460 MKWh									
	By Coal =	28.104 MKWh	By Hydro =	0.720 MKWh									
	By Solar =	1.353 MKWh											
11.	Total Gas Supplied		: 834.57 MMCFD										
(D) Forecast of 27.12.22 (Today) Tuesday :													
01.	Maximum Demand		: 9800 MW	(Generation end)									
02.	Maximum Generation		: 10484 MW	(Generation end)									
03.	Reserve / Shortage		: 684 MW	(Generation end)									
04.	Maximum Load-shed		: 0 MW	At evening peak (Sub-station end)									
05.	Total Generation		: 195.80 MKWh										
06.	Probable Max. Temperature in Dhaka :		28.0° C										