

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month January, 2023					Day : Monday				Date : 02.01.23			
Probable Maximum Demand : 9800 MW					Probable Maximum Generation : 10145 MW				Rule Curve = 102.81 ft.			
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 86.47 ft Today = 86.23 ft							
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	01.01.22 (Yesterday)		02.01.23 (Today)		01.01.22 (Yesterday)		02.01.23 (Today)	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Machines shut down (MW)	
					Day	Evening	Day	Evening	Description/ Remarks		Probable start-up date	
(A) Plants in operation:												
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work
2	a) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	240	0	0	0			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0		190	Under maint.
3	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	Under maint.
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	3x43.35	108	108	72	76	70	76	32		Gas Shortage
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0			Contract Expired
7	Haripur 360MW CAPP(HPL)	Gas (IPP)	1x235+1x125	360	360	365	353	330	360			
8	Meghnaghat 450 MW CAPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225		Gas Shortage
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
10	Haripur 412 MW CAPP	Gas (EGCB)	1x273+1x139	412	412	395	398	400	400			
11	Siddhirganj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage
12	Siddhirganj 335 MW CAPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	217	118	Gas Shortage
13	Meghnaghat CAPP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0	335		Gas Shortage
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	15	0	30			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	16	16	16			
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	22	22	22			
17	Summit Power,(Madhabadi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	45	45	45	45			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	17	25	25	33			
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	31	28	33	33			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	41	50	50	50			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	105	105	105	105			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	32	32	32			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	32	97	32	97			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	35	34	35	35			
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	160	100	100	150			
27	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	50	80	100	50			
28	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	50	0	0	50			
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	55	35	55			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	0	17	17			
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	162	17	162			
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	25	0	30	0			
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17			
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	9	9	9	9			
36	Meghnaghat 100 MW(HEL)	HFO (NENP)	12x8.9	100	100	18	17	17	17			
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	34	34	34	34			
Dhaka Zone Total					6004	5847	2131	2104	1848	2229	1124	1048
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	3	23	46	46	207		Low water level
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	0	0	5	0			
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25			
42	Teknaf 20MW PP (SolarTech)	Solar (IPP)	1x20	20	20	19	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	19	20	19	19			
44	Sikalbaha 105 MW PP (Baraka Sikabaha)	HFO (IPP)	6x18.415	105	105	17	105	17	105			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.
46	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	151	151	151	151			
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	52	280	51	300			
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25			
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	0	51			
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	24	32	24	32			
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0	22		Gas Shortage
*	Malancha, Cig.EP2 (United)	Gas	5x8.73+3x9.34			25	40	10	20			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	25			
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17			
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	54	72	72	72			
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	25	25	25			
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	22	22	22	22			
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	51	51	68	68			
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			32	0	0	0			on test
Chattogram Zone Total					2442	2382	561	939	597	1003	409	330
58	Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	35	10	10	10			
60	Ashuganj 225 MW CAPP	Gas (APSCCL)	1x142+17x5	221	221	190	200	190	200			
61	Ashuganj 450 MW CAPP(South)	Gas (APSCCL)	1x360	360	360	0	0	0	0		360	Under maint.
62	Ashuganj 450 MW CAPP(North)	Gas (APSCCL)	1x361	360	360	320	330	310	320			
63	Ashuganj 420 MW CAPP(East)	Gas (APSCCL)	1x284+1x116	400	400	260	288	300	300			
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	5	5	20	20	50		Gas Shortage
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+1'16	195	195	16	16	16	16	179		Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	54	6	54	96		Gas Shortage
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	30	29	25	38			
69	Chandpur 150 MW CAPP	Gas (PDB)	1x106+1x57	163	163	0	0	0	0		163	Under maint.
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	17	17	17			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	21	21			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	10	10			
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	24	33	25	33			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	8	8	8			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	19	21	21	21			
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+8x15.15+1x1.098	200	200	0	50	100	100			
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	17	17	17	17			
78	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	100	55	105	108			
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17			
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	51	94	70	94			
**	Import (Tripura)	India		160	160	96	98	135	152			
Cumilla Zone Total					3309	3285	1287	1424	1474	1607	459	523
81	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	34	70	75	75	132		Gas Shortage
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	21	22	22			
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	28	47	29	47			
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	46	48	48	57			
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
86	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	39	0	50	0			
87	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	12	12	12	12			
Mymensingh Zone Total					622	614	183	196	238	213	132	0

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	01.01.22 (Yesterday)		02.01.23 (Today)		01.01.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Water Limitation MW	Machines shut down (MW)		
						Day	Evening	Day	Evening			Description/ Remarks	Probable start-up date
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	GT-1 Under maint.	
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	0	0		90	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	22	25	38	45				
91	Kushiara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	75	75	112	112		54	STG Under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	63	63	65	65				
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 66MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	5	83	50	86				
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	140	145	120	120				
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	19	19	19				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16				
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	0	0	0	0		341	Major Inspection	
101	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	245	280	280	280				
102	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	0	0	0	0				
105	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.4*5*2	50	50	20	40	44	44				
Sylhet Zone Total				2522	2477	1033	1194	1192	1235	0	955		
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
107	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	0	0	0	0		410	Under maint.	
108	Fandpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	28	0	40				
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	68	0	76				
110	Khulna 225 MW CCPP	HSD (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0				
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	0	50				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	7	17	17				
113	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	0	0				
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	35	0	100	0				
115	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	99	114	40	114				
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	8	40	40	40				
	Rampal 1320 MW	Coal (BIFPCL)				0	0	0	0				
	Khulna 330 MW CCPP	Gas/HSD (BPDB)				0	0	0	0				
**	Bheramara (HVDC) India			1000	1000	823	918	839	935				
Khulna Zone Total				2388	2384	965	1175	1036	1272	0	410		
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	15	0	55		95	Line Overload	
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	19	25	19	25				
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	154	0	68	68				
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	360	622	500	622				
121	Potukhalhi 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0		150	Line Overload	
	Barisal Electric 307 MW	Coal (IPP)				167	310	308	308				
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	190	100	220	220				
Barishal Zone Total				1958	1958	890	1072	1115	1298	0	245		
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	34	0	34				
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	100				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	18	0	25				
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	68	0	90				
128	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	6	40	0	40				
129	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	25	42	42	42				
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	35	0	35				
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0		210	Gas Shortage	
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	168	125	200	160		95	Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	0	0	0	0		220	Under maint.	
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	301	285	350	310		129	Gas Shortage	
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	22	22	22				
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	8	8	8				
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	55	35	55				
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	50	35	50				
140	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	4	0	6	0				
	Adani Power Jharkhanda Ltd	Coal				0	0	0	0				
Raishahi Zone Total				2129	2129	608	790	706	979	605	220		
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	160	160	160	160		114	Coal Shortage	
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	34	70	34	34				
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	4	0	8	0				
147	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	115	115	113	115	115	115				
148	Lalmoinihat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	20	0	30	0				
	Treesta Solar Limited	Solar (IPP)				138	0	0	0				
Rangpur Zone Total				830	750	469	345	347	309	199	85		
Sub-total: Plants in operation				22204	21826	8127.0	9239	8553	10145	2928	3816		
(B) Plants under long term maintenance/ contract expired													
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
150	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
151	Bosilia 108MW PPI(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
153	Ammurá 30 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022	
	Sub-Total: Plants under long term maintenance/ contract expired			404	0	0	0	0	0				
Gross Total				22608	21826	8127	9239	8553	10145	2928	3816		
(C) Actual data of 01.01.22 (Yesterday) Sunday :													
01.	Max. Demand at eve. peak (Generation end)	:	9239	MW, at =	19:30 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	8874	MW, at =	19:30 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	9239	MW, at =	19:30 hrs	Dhaka	3119	3119	0	Mymersingh	761	761	0
04.	Minimum Generation (Generation end)	:	5988	MW, at =	5:00 hrs	Chattogram	948	948	0	Sylhet	341	341	0
05.	Day-peak Generation (Generation end)	:	8127	MW, at =	12:00 hrs	Khulna	1105	1105	0	Barishal	260	260	0
06.	Evening-peak Generation (Generation end)	:	9239	MW, at =	19:30 hrs	Rajshahi	930	930	0	Rangpur	613	613	0
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at =	19:30 hrs	Cumilla	798	798	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	5954	MW, at =	5:00 hrs					Total	8874	8874	0
09.	Generation shortfall at evening peak due to :	:				13.	Fuel cost :	(a) Gas = 112834067 Taka (b) Oil = 470270924 Taka		(c) Coal = 127833072 Taka Total = 710938063 Taka			
	a) Gas/LF limitation	:	2522	MW		14.	Maximum Temperature in Dhaka was :	24.4° C					
	d) Coal supply Limitation	:	199	MW		15.	Export through East-West interconnections :						
	b) Low water level in Kaptai lake	:	207	MW			At evening peak-hour	:	8127	MW, at	19:30 hrs		
	c) Plants under shut down/ maintenance	:	3816	MW			Maximum	:	336	MW, at	18:00 hrs		
10.	Total Energy (Generation + India Import)	:	187.08	MKWh			Energy	:	0	MKWh			
	By Gas = 107.269 MKWh												
	By Coal = 22.474 MKWh												
	By Solar= 1.505 MKWh												
11.	Total Gas Supplied	:	827.82	MMCFD		</							

* Coactive Power ** Imported Power
#Remarks: