

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month January, 2023					Day : Wednesday					Date : 04.01.23				
Probable Maximum Demand : 10200 MW					Probable Maximum Generation : 10746 MW					Rule Curve = 10243 ft.				
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 86.16 ft		Today = 86.08 ft							
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	03.01.23 (Yesterday)		04.01.23 (Today)		03.01.23 (Yesterday)		04.01.23 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Machines shut down (MW)			
					Day	Evening	Day	Evening						
(A) Plants in operation:														
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260		Under project work	
2	a) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0					
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0		190		Under maint.	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	200	200	200	200		165		ST under maint.	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	3x43.35	108	108	76	73	70	76	35			Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105			Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0				Contract Expired	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	330	297	330	360					
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225			Gas Shortage	
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115		Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	399	394	400	400					
11	Siddhirganj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210			Gas Shortage	
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	217	118		Gas Shortage	
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0	335			Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	41	15	55					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	16	16	16					
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	14	19	19	19					
17	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	51	48	48	48					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	25	25					
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	28	28	30	30					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	24	50	24	50					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	105	105	105	105					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	16	16	16					
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	32	229	32	98					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	35	119	149	149					
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	150	0	150	150					
27	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0					
28	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0					
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	55	35	55					
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55					
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	17	0	17					
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	162	17	162					
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	7	0	30	0					
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17					
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	9	9	8	8					
36	Meghnaghat 100 MW(HEL)	HFO (NENP)	12x8.9	100	100	17	17	9	9					
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	34	50	34	51					
Dhaka Zone Total					6004	5847	1888	2329	2056	2450	1127	848		
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	18	30	30	30	200			Low water level	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180			Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	0	0	5	0					
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25					
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0					
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	20	19	19	19					
44	Sikalbaha 105 MW PP (Baraka Sikabaha)	HFO (IPP)	6x18.415	105	105	17	51	17	51					
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150		Under maint.	
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	151	151	151	151					
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	52	295	51	300					
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25					
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	0	51					
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	32	32	24	40					
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0	22			Gas Shortage	
*	Malancha, Cig.EP2 (United)	Gas	5x8.73+3x9.34			2	10	5	10					
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	8	0	10					
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17					
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	36	72	52	72					
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	25	25	25					
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	22	22	22	22					
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	51	46	51	51					
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			18	0	0	0				on test	
Chattogram Zone Total					2442	2382	531	879	539	899	402	330		
58	Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134			Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	29	35	5	5					
60	Ashuganj 225 MW CAPP	Gas (APSCCL)	1x142+17x5	221	221	203	182	190	200					
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	0	0	0	0	360			Under maint.	
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	350	300	350	350					
63	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	0	120	300	300					
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	56	5	5	5	50			Gas Shortage	
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+1'16	195	195	138	8	8	8	187			Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51					
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	6	55	6	55	95			Gas Shortage	
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	38	29	25	38					
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163			Under maint.	
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	0	0	0					
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	21	21	21					
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	10	10					
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	16	22	25	25					
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	8	8	8					
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	11	20	21	21					
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	96x1.4+6x1.515+15x1.098	200	200	110	0	100	100					
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	0	0	114	114					
78	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	60	29	105	108					
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17					
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	93	93	70	94					
**	Import (Tirupura)	India		160	160	96	108	135	152					
Cumilla Zone Total					3309	3285	1311	1113	1566	1682	466	523		
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	35	52	75	75	150			Gas Shortage	
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	18	22	22					
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	28	47	28	47					
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	37	47	48	57					
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0					
86	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	39	0	50	0					
87	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	12	12	12	12					
Mymensingh Zone Total					622	614	172	176	237	213	150	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	03.01.23 (Yesterday)		04.01.23 (Today)		03.01.23 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)			
						Day	Evening	Day	Evening			Description/ Remarks	Probable start-up date	
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	GT-1 Under maint.		
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	31	31	31	31		59	GT-4 Under maint.		
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	14	50	10	50					
91	Kushiara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		54	STG Under maint.		
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	8	8					
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	63	64	64					
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.		
95	Shahjibazar 66MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	86	30	84					
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	171	197	200	200					
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	19	19	19	19					
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10					
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	8	16	16					
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	20	15	0	0					
101	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	280	232	252	252					
102	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400					
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work		
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	0	0	0	0					
105	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	10	28	10	30					
Sylhet Zone Total				2522	2477	1044	1169	1080	1194	0	583			
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
107	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	0	0	0	0		410	Under maint.		
108	Fandpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	33	0	40					
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	20	0	76					
110	Khulna 225 MW CCPP	HSD (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0					
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	0	50					
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	17	17	17					
113	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	0	0					
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	68	0	100	0					
115	Khulna 115 MW PP (KFCL-2)	HFO (NENP)	7x17	115	115	16	16	0	32					
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	40	40	40	40					
	Rampal 1320 MW	Coal (BIFPCL)				189	544	500	500					
	Khulna 330 MW CCPP	Gas/HSD (B/PDB)				0	0	0	0					
**	Bheramara (HVDC) India			1000	1000	822	918	839	935					
Khulna Zone Total				2388	2384	1135	1588	1496	1690	0	410			
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	0	0		110	Line Overload		
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	19	24	19	25					
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	0	120	120	120					
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	530	600	500	622					
121	Potukhalhi 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0		150	Line Overload		
	Barisal Electric 307 MW	Coal (IPP)				276	295	308	308					
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	219	194	220	220					
Barishal Zone Total				1958	1958	1044	1233	1167	1295	0	260			
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage		
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Gas Shortage		
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	24	0	34					
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	79	0	0	100					
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	14	0	25					
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	69	0	65					
128	Katakhalhi 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	4	40	0	40					
129	Katakhalhi 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	42	42	42	50					
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	35	0	36					
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0		210	Gas Shortage		
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150+1x75	220	220	138	134	220	220		86	Gas Shortage		
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	0	0	0	0		220	Under maint.		
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	282	288	280	300		126	Gas Shortage		
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	17	20	22	22					
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8					
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	8	8	8					
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	18	35	35					
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	35	35	35					
140	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	1	0	6	0					
	Adani Power Jharkhanda Ltd	Coal				140	161	0	0					
Raishahi Zone Total				2129	2129	789	896	656	978	593	220			
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage		
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling		
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	160	160	160	160		114	Coal Shortage		
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	34	70	34	70					
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
146	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	4	0	8	0					
147	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	115	115	93	93	115	115					
148	Lalmoinhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	24	0	30	0					
	Treesta Solar Limited	Solar (IPP)				142	0	0	0					
Rangpur Zone Total				830	750	457	323	347	345	199	85			
Sub-total: Plants in operation				22204	21826	8371.0	9706	9144	10746	2937	3259			
(B) Plants under long term maintenance/ contract expired														
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0					
150	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0					
151	Bosilia 108MW PPI(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0					
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0					
153	Ammurá 30 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022		
	Sub-Total: Plants under long term maintenance/ contract expired			404	0	0	0	0	0					
Gross Total				22608	21826	8371	9706	9144	10746	2937	3259			
(C) Actual data of 03.01.23 (Yesterday) Tuesday :														
01.	Max. Demand at eve. peak (Generation end)		: 9706 MW, at =	19:00 hrs		12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)		: 9334 MW, at =	19:00 hrs			Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	
03.	Highest Generation (Generation end)		: 9706 MW, at =	19:00 hrs										
04.	Minimum Generation (Generation end)		: 6081 MW, at =	5:00 hrs			Dhaka	3397	3397	0	Mymensingh	785	785	0
05.	Day-peak Generation (Generation end)		: 8371 MW, at =	12:00 hrs			Chattogram	1010	1010	0		349	349	0
06.	Evening-peak Generation (Generation end)		: 9706 MW, at =	19:00 hrs			Khulna	1139	1139	0	Barisal	265	265	0
07.	Evening Peak Load-shed (Sub-station end)		: 0 MW, at =	19:00 hrs			Rajshahi	946	946	0	Rangpur	654	654	0
08.	Minimum Generation Forecast up to 8:00 hrs.		: 6129 MW, at =	5:00 hrs			Cumilla	789	789	0				
09.	Generation shortfall at evening peak due to :									Total	9334	9334	0	
	a) Gas/LF limitation		: 2538 MW			13.	Fuel cost :	(a) Gas = 111156782 Taka	(c) Coal = 146034513 Taka					
	d) Coal supply Limitation		: 199 MW					(b) Oil = 415924307 Taka	Total = 667415602 Taka					
	b) Low water level in Kaptai lake		: 200 MW											
	c) Plants under shut down/ maintenance		: 3259 MW			14.	Maximum Temperature in Dhaka was : 29.6° C							
10.	Total Energy (Generation + India Import)		: 192.05 MKWh			15.	Export through East-West interconnections :							
	By Gas = 105.196 MKWh	By Oil = 30.222 MKWh					At evening peak-hour : 8371 MW, at 19:00 hrs							
	By Coal = 33.264 MKWh	By Hydro = 0.804 MKWh					Maximum : 78 MW, at 7:00 hrs							
	By Solar= 1.705 MKWh						Energy : 0 MKWh							
11.	Total Gas Supplied		: 817.30 MMCFD											
(D) Forecast of 04.01.23 (Today) Wednesday :														
01.	Maximum Demand		: 10200 MW											