

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month January, 2023				Day : Saturday				Date : 07.01.23				
Probable Maximum Demand : 9300 MW				Probable Maximum Generation : 10460 MW								
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 85.92 ft	Today = 85.84 ft		Rule Curve = 101.86 ft					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	06.01.23 (Yesterday)		07.01.23 (Today)		06.01.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW			
					Day	Evening	Day	Evening	Machines shut down (MW)	Description/ Remarks		Probable start-up date
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Under maint.	
3	Ghorasal 55 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	200	200	200	200	165	ST under maint.	
4	Ghorashai 108MW PP (Regent)	Gas (IPP)	3x3.35	108	108	70	73	70	73	35	Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0		Contract Expired	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	269	265	270	270	95	Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	0	0	0	0	450	Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	331	371	370	371			
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	130	0	0	0	217	Gas Shortage	
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	15	167	60	170	168	Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	40	30	15	55			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	8	8	8			
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	13	22	19	22			
17	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	38	48	45	48			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25			
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	30	30	33			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	18	0	24	50			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	34	17	105	105			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	0	16	16			
23	Karnalaghat 54 MW PP (Baraka Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	263	278	280	280			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	17	17	17			
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	150			
27	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0			
28	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0			
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	55	35	55			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	55	35	55			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	17	17	17			
32	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	162	17	162			
33	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	7	0	30	0			
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17			
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	8	8	8	8			
36	Meghnaghat 100 MW(HEL)	HFO (NENP)	12x8.9	100	100	9	9	9	9			
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	17	0	48	48			
Dhaka Zone Total				6004	5847	1638	1928	1787	2318	1460	848	
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	30	30	30	200	Low water level	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	2	0	5	0				
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	0	25	25			
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	21	0	20	20			
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	51	17	17			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	151	151	151	151			
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	51	282	51	282			
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25			
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	0	0	51			
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	24	0	24	24			
51	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0	22	Gas Shortage	
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			25	30	10	20			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	10			
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17			
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	34	51	50	51			
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	25	25	25			
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	22	22	22	22			
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	52	51	51			
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0		on test	
Chattogram Zone Total				2442	2382	587	736	543	821	402	330	
58	Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	15	15	15	15			
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+175	221	221	190	189	210	210			
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	0	0	0	0	360	Under maint.	
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	300	295	300	300			
63	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	290	403	290	400			
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	5	5	5	5	50	Gas Shortage	
65	Ashuganj 199MW PP (APSCCL-United)	Gas (IPP)	20'9.73+1'16	195	195	8	8	8	8	187	Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	43	43	43			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	6	54	6	55	96	Gas Shortage	
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	36	0	31	31			
69	Chandpur 150 MW CCPP	Gas (PDB)	1x106+1x57	163	163	0	0	0	0	163	Under maint.	
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	0	0	0			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	21	21			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	10	10			
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	21	22	25	33			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	8	8	8			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	15	21	21	21			
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+60x1.915+15x1.098	200	200	0	0	100	100			
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	17	17	17	17			
78	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	9	9	9	9			
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17			
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	76	94	77	94			
**	Import (Tripura)	India		160	160	106	102	135	152			
Cumilla Zone Total				3309	3285	1193	1333	1348	1646	467	523	
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	35	105	100	105	97	Gas Shortage	
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	22	22	22			
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	42	47	28	47			
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	47	48	48	50			
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0			
86	Sutahali 50 MW Solar PP	Solar (IPP)	1x50	50	50	31	0	50	0			
87	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	12	12	12	12			
Mymensingh Zone Total				622	614	188	234	262	236	97	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	06.01.23 (Yesterday)		07.01.23 (Today)		06.01.23 (Yesterday)		Status of Machines under shut-down/ Maintenance			
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :					
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date		
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	0	0	0	0		70	GT-1 Under maint.			
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	31	31	31	31		59	GT-4 Under maint.			
90	Fenchugonj 51 MW PP (Barkatullah)	Gas (RPP)	19x2.90	51	51	28	28	10	28						
91	Kushiara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		163	Under maint.			
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	2	0	8	8						
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	62	62	64	64						
94	Shajibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.			
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	40	86	40	86						
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	195	199	200	200						
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	19	19	19						
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10						
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	0	12	12						
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	315	305	300	305		36	Under maint.			
101	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	150	0	0	0						
102	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400						
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work			
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	0	0	0	0						
105	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	35	35	30	35						
Sylhet Zone Total						2522	2477	1286	1175	1124	1198	0	758		
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0						
107	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0		410	Under maint.			
108	Fairidpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	41	0	40						
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	76						
110	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	0						
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	0	50						
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	0	17	17						
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0						
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	77	0	100	0						
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	16	16	0	16						
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	40	40	40						
	Rampal 1320 MW	Coal (BIFPCL)				417	453	540	540						
	Khulna 330 MW CCPP	Gas/HSD (BPDB)				0	0	0	0						
**	Bheramara (HSDC)	India		1000	1000	535	699	546	833						
Khulna Zone Total						2388	2384	1062	1249	1243	1612	0	410		
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	0	0		110	Line Overload			
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	20	24	19	25						
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	158	188	170	188						
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	360	500	500	622						
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0		150	Line Overload			
	Barisal Electric 307 MW	Coal (IPP)				180	151	250	250						
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	200	220	220	220						
Barishal Zone Total						1958	1958	918	1083	1159	1305	0	260		
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage			
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Gas Shortage			
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	32						
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	50						
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	25						
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	60	0	80						
128	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	16	0	0	40						
129	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	16	0	8	8						
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	36						
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0		210	Gas Shortage			
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	134	220	180	220						
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0		220	Under maint.			
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	400	360	360	360						
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	22	22	22						
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8						
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	8	8	8						
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	55	35	55						
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	1	35	35	35						
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	3	0	6	0						
	Adani Power Jharkhand Ltd	Coal				0	0	0	0						
Raishahi Zone Total						2129	2129	639	768	662	979	381	220		
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage			
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling			
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	160	160	160	160		114	Coal Shortage			
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	33	70	34	70						
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
146	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	3	0	8	0						
147	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	115	115	115	74	115	115						
148	Lalmohini 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	0	0	30	0						
	Teesta Solar Limited	Solar (IPP)				164	0	0	0						
Rangpur Zone Total						830	750	475	304	347	345	199	85		
Sub-total: Plants in operation						22204	21826	7986.0	8810	8475	10460	3006	3434		
(B) Plants under long term maintenance/ contract expired															
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0						
150	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0						
151	Bostia 108MW PP(KLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0						
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0						
153	Amthura 50 MW PP(Sinma)	HFO (QRPP)	7x7.79	50	0	0	0	0	0				Contract Expired on 11/01/2022		
Sub-Total: Plants under long term maintenance/ contract expired						404	0	0	0	0					
Gross Total						22608	21826	7986	8810	8475	10460	3006	3434		
(C) Actual data of 06.01.23 (Yesterday) Friday :															
01.	Max. Demand at eve. peak (Generation end)	:	8810	MW,	at =	19:30	hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	8486	MW,	at =	19:30	hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	8810	MW,	at =	19:30	hrs		MW	MW	MW		MW	MW	MW
04.	Minimum Generation (Generation end)	:	6092	MW,	at =	5:00	hrs	Dhaka	2880	2880	0	Mymensingh	774	774	0
05.	Day-peak Generation (Generation end)	:	7986	MW,	at =	12:00	hrs	Chattogram	907	907	0	Sylhet	332	332	0
06.	Evening-peak Generation (Generation end)	:	8810	MW,	at =	19:30	hrs	Khulna	1069	1069	0	Barishal	259	259	0
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW,	at =	19:30	hrs	Rajshahi	873	873	0	Rangpur	620	620	0
08.	Minimum Generation Forecast up to 8:00 hrs.	:	5671	MW,	at =	5:00	hrs	Cumilla	773	773	0				
09.	Generation shortfall at evening peak due to :	:										Total	8486	8486	0
	a) Gas/LF limitation	:	2607	MW				13.	Fuel cost :	(a) Gas = 107759231	Taka	(c) Coal = 121137949	Taka		
	d) Coal supply Limitation	:	199	MW						(b) Oil = 334235031	Taka	Total = 563132211	Taka		
	b) Low water level in Kaptai lake	:	200	MW											
	c) Plants under shut down/ maintenance	:	3434	MW				14.	Maximum Temperature in Dhaka was :	18.8° C					
10.	Total Energy (Generation + India Import)	:	179.18	MW				15.	Export through East-West interconnections :						
	By Gas = 103.922	MW	By Oil = 25.113	MW					At evening peak-hour	:	7986	MW,	at	19:30	hrs
	By Coal = 31.244	MW	By Hydro = 0.699	MW					Maximum	:	30	MW,	at	18:00	hrs
	By Solar= 1.805	MW							Energy	:	0.231	MW			
11.	Total Gas Supplied	:	788.75	MMCFD											
(D) Forecast of 07.01.23 (Today) Saturday :															
01.	Maximum Demand	:	9300	MW	(Generation end)			04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	10460	MW	(Generation end)			05.	Total Generation	:	189.14	MW			
03.	Reserve / Shortage	:	1160	MW	(Generation end)			06.	Probable Max. Temperature in Dhaka :	:	27.1° C				

* Coactive Power ** Imported Power
#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation