

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month January, 2023					Day : Sunday					Date : 08.01.23				
Probable Maximum Demand : 10000 MW					Probable Maximum Generation : 9879 MW					Rule Curve = 101.67 ft.				
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 85.84 ft Today = 85.76 ft									
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	07.01.23 (Yesterday)		08.01.23 (Today)		07.01.23 (Yesterday)		08.01.23 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Machines shut down (MW)			
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW		Description/ Remarks	Probable start-up date		
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage		
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0		190	Under maint.		
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	200	200	200	200		165	ST under maint.		
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	3x3.35	108	108	70	73	70	73	35		Gas Shortage		
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage		
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0			Contract Expired		
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	330	274	250	270	86		Gas Shortage		
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	0	0	0	0	450		Gas Shortage		
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	396	361	340	360					
11	Siddhirganj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage		
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	217	118	Gas Shortage		
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	158	160	150	160	175		Gas Shortage		
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	40	55	55	55					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	8	8	8					
16	Narsingdi 22 MW PP (Doreen)	Gas (SIIPP, REB)	8x2.90	22	22	22	19	19	22					
17	Summit Power,(Madhabdi+Ashulia)	Gas (SIIPP, REB)	6x3.67+7x8.73	80	80	48	48	45	48					
18	Maona 33 MW PP(Summit)	Gas (SIIPP, REB)	4x8.73	33	33	25	33	25	25					
19	Rupganj 33 MW PP(Summit)	Gas (SIIPP, REB)	4x8.73	33	33	31	28	30	33					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	24	24	50	50					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	70	88	105	105					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	16	16	16					
23	Karnalaghat 54 MW PP (Baraka Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	248	264	280	280					
25	Kodda 148 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	17	17	17					
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	207	150	0					
27	Bramhanagan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0					
28	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0					
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	55	35	55					
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	55	35	55					
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	0	17	17					
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	162	17	162					
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	5	0	30	0					
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17					
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	8	8	8	8					
36	Meghnaghat 100 MW(HEL)	HFO (NENP)	12x8.9	100	100	9	8	9	9					
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	26	48	48	48					
Dhaka Zone Total			6004	5847	1836	2282	2043	2147	1458	848				
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	30	30	30	200		Low water level		
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.		
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0					
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25					
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	0	20	0					
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x8.89	50	50	19	20	20	20					
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	25	17	17	17					
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.		
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	162	161	161	161					
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	51	280	51	282					
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25					
49	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	51					
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	16	24	24	24					
51	Barakunda 22 MW PP (Regent)	Gas (SIIPP, PDB)	8x2.90	22	22	0	0	0	0	22		Gas Shortage		
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	11	10	20					
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	10					
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	17	17	17					
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	34	17	50	51					
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	27	25	25					
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	22	22	22	22					
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	51	51	51	51					
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0			on test		
Chattogram Zone Total			2442	2382	491	778	604	831	402	330				
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage		
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	35	5	5	5					
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+175	221	221	185	227	210	210					
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	0	0	0	0	360		Under maint.		
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	300	280	330	320					
63	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	238	260	270	280					
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	35	5	5	5	50		Gas Shortage		
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'16	195	195	32	8	8	8	187		Gas Shortage		
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	43	51					
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	6	54	6	55	96		Gas Shortage		
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	31	36	31	31					
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163		Under maint.		
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	0	0	0					
71	Feni 22MW PP (Doreen)	Gas (SIIPP, PDB)	8x2.90	22	22	19	21	21	21					
72	Feni 11 MW PP (Doreen)	Gas (SIIPP, REB)	4x2.90	11	11	8	10	10	10					
73	Jangalia 33MW PP (Summit)	Gas (SIIPP, PDB)	4x8.73	33	33	21	20	25	33					
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	8	8	8					
75	Cumilla 25 MW PP (Summit)	Gas (SIIPP, REB)	3x3.67+2x6.97	25	25	12	21	21	21					
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+60x1.915+15x1.098	200	200	0	181	100	100					
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	17	17	17	0					
78	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	3	9	9	9					
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17					
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	52	94	94	94					
**	Impoport (Tripura)	India		160	160	45	106	135	152					
Cumilla Zone Total			3309	3285	1099	1430	1365	1430	467	523				
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	72	98	70	100	104		Gas Shortage		
82	Tangail 22 MW PP (Doreen)	Gas (SIIPP, PDB)	8x2.90	22	22	22	20	22	22					
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	28	47	28	47					
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	48	55	48	50					
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0					
86	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	0	0	0	50	0					
87	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	12	12	12	12					
Mymensingh Zone Total			622	614	183	232	232	231	104	0				

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	07.01.23 (Yesterday)		08.01.23 (Today)		07.01.23 (Yesterday)		Status of Machines under shut-down/ Maintenance			
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :					
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date		
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	0	0	0	0		70	GT-1 Under maint.			
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	31	31	31	31		59	GT-4 Under maint.			
90	Fenchugonj 51 MW PP (Barkatullah)	Gas (RPP)	19x2.90	51	51	31	48	45	45						
91	Kushiera 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		163	Under maint.			
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	8	8						
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	61	61	64	64						
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.			
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	40	86	40	86						
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	197	200	200	200						
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	19	19	19						
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10						
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	0	12	12						
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	290	300	310		51	Under maint.			
101	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	0	0	0	0						
102	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400						
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work			
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	0	0	0	0						
105	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	50	49	44	44						
Sylhet Zone Total						2522	2477	1127	1194	1173	773				
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0						
107	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0		410	Under maint.			
108	Fairdipor 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	39	0	40						
109	Gopalgarj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	53	0	76						
110	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	0						
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	85	0	50						
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	17	17	17						
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0						
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	71	0	100	0						
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	16	32	100						
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	24	40	40						
	Rampal 1320 MW	Coal (BIFPCL)				504	551	500	540						
	Khulna 330 MW CCPP	Gas/HSD (BPDB)				0	0	0	0						
**	Bheramara (HSDC) India			1000	1000	492	492	497	497						
Khulna Zone Total						2388	2384	1084	1277	1186	410				
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	0	0		110	Line Overload			
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	20	26	19	25						
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	187	188	170	180						
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	420	622	550	622						
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0		150	Line Overload			
	Barisal Electric 307 MW	Coal (IPP)				183	306	170	300						
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	210	210	220	220						
Barishal Zone Total						1958	1958	1020	1352	1129	260				
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage			
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Gas Shortage			
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	34	0	32						
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	42	0	50						
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	5	0	25						
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	35	0	80						
128	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	40	0	40						
129	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	8	8	8	8						
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	35	0	36						
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0		210	Gas Shortage			
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	161	163	200	180						
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0		220	Under maint.			
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	341	418	300	380						
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	22	22	22	22						
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8						
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	8	8	8						
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	55	35	55						
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	35	35	35						
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	1	0	6	0						
	Adani Power Jharkhand Ltd	Coal				0	0	0	0						
Raishahi Zone Total						2129	2129	619	908	622	381	220			
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage			
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling			
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	160	160	160	160		114	Coal Shortage			
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	34	70	34	70						
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
146	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	3	0	8	0						
147	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	115	115	115	112	105	115						
148	Lalmoinihat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	24	0	30	0						
	Teesta Solar Limited	Solar (IPP)				163	0	0	0						
Rangpur Zone Total						830	750	499	342	337	345	199	85		
Sub-total: Plants in operation						22204	21826	7958.0	9795	8691	9879	3011	3449		
(B) Plants under long term maintenance/ contract expired															
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0						
150	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0						
151	Bostia 108MW PP(KLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0						
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0						
153	Amthura 50 MW PP(Sinma)	HFO (QRPP)	7x7.79	50	0	0	0	0	0				Contract Expired on 11/01/2022		
Sub-Total: Plants under long term maintenance/ contract expired						404	0	0	0	0					
Gross Total						22608	21826	7958	9795	8691	9879	3011	3449		
(C) Actual data of 07.01.23 (Yesterday) Saturday :															
01.	Max. Demand at eve. peak (Generation end)	:	9795	MW,	at =	19:30	hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	9270	MW,	at =	19:30	hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	9795	MW,	at =	19:30	hrs	Dhaka	3349	3349	0	Mymensingh	818	818	0
04.	Minimum Generation (Generation end)	:	5671	MW,	at =	5:00	hrs	Chattogram	930	930	0	Sylhet	356	356	0
05.	Day-peak Generation (Generation end)	:	7958	MW,	at =	12:00	hrs	Khulna	1155	1155	0	Barishal	275	275	0
06.	Evening-peak Generation (Generation end)	:	9795	MW,	at =	19:30	hrs	Rajshahi	910	910	0	Rangpur	638	638	0
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW,	at =	19:30	hrs	Cumilla	838	838	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6079	MW,	at =	5:00	hrs					Total	9270	9270	0
09.	Generation shortfall at evening peak due to :	:						13.	Fuel cost :	(a) Gas = 110598242 Taka	(c) Coal = 127403841 Taka				
	a) Gas/LF limitation	:	2612	MW						(b) Oil = 401136888 Taka	Total = 639138971 Taka				
	d) Coal supply Limitation	:	199	MW											
	b) Low water level in Kaptai lake	:	200	MW											
	c) Plants under shut down/ maintenance	:	3449	MW											
10.	Total Energy (Generation + India Import)	:		MW				14.	Maximum Temperature in Dhaka was :	15.4° C					
	By Gas = 105.641 MKWH			By Oil = 28.713 MKWH				15.	Export through East-West interconnections :						
	By Coal = 32.507 MKWH			By Hydro = 0.743 MKWH					At evening peak-hour	:	7958	MW,	at	19:30	hrs
	By Solar= 1.443 MKWH								Maximum	:	14	MW,	at	23:00	hrs
11.	Total Gas Supplied	:	805.95	MMCFD					Energy	:	0	MW			
(D) Forecast of 08.01.23 (Today) Sunday :															
01.	Maximum Demand	:	10000	MW	(Generation end)			04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	9879	MW	(Generation end)			05.	Total Generation	:	187.34	MW			
03.	Reserve / Shortage	:	-121	MW	(Generation end)			06.	Probable Max. Temperature in Dhaka :	:	27.3° C				

* Cative Power ** Imported Power
#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation