

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month January, 2023					Day : Wednesday				Date : 11.01.23				
Probable Maximum Demand : 10300 MW					Probable Maximum Generation : 10421 MW				Rule Curve = 101.29 ft.				
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 85.66 ft Today = 85.60 ft								
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	10.01.23 (Yesterday)		11.01.23 (Today)		10.01.23 (Yesterday)		11.01.23 (Today)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :				
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date	
(A) Plants in operation:													
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work	
a)	Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage	
b)	Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190		Gas Shortage	
3	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	200	200	200	200		165	ST under maint.	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	3x43.35	108	108	70	73	70	73	35		Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			Contract Expired	
7	Haripur 360MW CAPP(HPL)	Gas (IPP)	1x235+1x125	360	360	271	269	260	270	91		Gas Shortage	
8	Meghnaghat 450 MW CAPP(MPL)	Gas (IPP)	2x140+1x170	450	450	0	0	0	0	450		Gas Shortage	
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
10	Haripur 412 MW CAPP	Gas (EGCB)	1x273+1x139	412	412	313	325	310	325	87		Gas Shortage	
11	Siddhirganj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage	
12	Siddhirganj 335 MW CAPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	217	118	Gas Shortage	
13	Meghnaghat CAPP(Summit)	GAS (IPP)	2x110+1x110	335	335	155	158	150	160	177		Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	30	30	30				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	8	8	8				
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	22	22	22				
17	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	39	39	46	46				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	30	30	33	33				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	49	50	50	50				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	105	88	88	105				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	48	16	16				
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	54	17	54				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	32	195	32	98				
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	91	35	91				
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	12	0	100				
27	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0				
28	Auraihat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0				
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	35	17	35				
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	55	17	55				
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	11	0	17				
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	162	17	162				
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	28	0	30	0				
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17				
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	15	8	8	8				
36	Meghnaghat 100 MW(HEL)	HFO (NENP)	12x8.9	100	100	8	9	9	9				
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	56	34	34	34				
Dhaka Zone Total					6004	5847	1590	2056	1549	2051	1742	658	
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	30	30	30	200		Low water level	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0				
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25				
42	Teknaf 20MW PP (SolarTech)	Solar (IPP)	1x20	20	20	19	0	20	0				
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	20	20	20	20				
44	Sikalbaha 105 MW PP (Baraka Sikabaha)	HFO (IPP)	6x18.415	105	105	17	51	17	51				
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.	
46	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	154	158	161	161				
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	52	300	51	300				
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25				
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	51				
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	25	33	25	33				
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0	22		Gas Shortage	
*	Malancha, Cig.EP2 (United)	Gas	5x8.73+3x9.34			2	8	5	10				
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0				
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17				
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	34	51	17	51				
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	25	25	25				
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	22	22	22	22				
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	34	34	34	34				
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0			on test	
Chattogram Zone Total					2442	2382	505	850	550	855	402	330	
58	Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	5	5	5	5	40		Gas Shortage	
60	Ashuganj 225 MW CAPP	Gas (APSCCL)	1x142+17x5	221	221	214	222	200	220				
61	Ashuganj 450 MW CAPP(South)	Gas (APSCCL)	1x360	360	360	0	0	0	0		360	Under maint.	
62	Ashuganj 450 MW CAPP(North)	Gas (APSCCL)	1x361	360	360	295	280	300	300				
63	Ashuganj 420 MW CAPP(East)	Gas (APSCCL)	1x284+1x116	400	400	268	309	300	310				
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	5	0	0	0	55		Gas Shortage	
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+1'16	195	195	8	0	0	0	195		Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51				
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	6	8	8	8	144		Gas Shortage	
68	Titaz 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	21	34	31	31				
69	Chandpur 150 MW CAPP	Gas (PDB)	1x106+1x57	163	163	0	0	0	0		163	Under maint.	
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	0	0	0				
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	18	21	21				
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	10	10				
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	19	26	21	26				
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	8	8	8				
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	21	21	21				
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	96x1.4+6x1.515+15x1.098	200	200	152	100	100	200				
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	0	0	0	0				
78	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	0	9	9	9				
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17				
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	49	94	50	94				
**	Import (Tripura)	India		160	160	92	112	135	153				
Cumilla Zone Total					3309	3285	1243	1322	1287	1484	568	523	
81	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	45	86	55	90	116		Gas Shortage	
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	21	22	22				
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	28	47	28	47				
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	48	48	48	48				
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
86	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	44	0	50	0				
87	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	12	12	12	12				
Mymensingh Zone Total					622	614	197	214	217	219	116	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	10.01.23 (Yesterday)		11.01.23 (Today)		10.01.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	0	0	0	0		70	GT-1 Under maint.	
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	31	31	31	31		59	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	53	53	51	51				
91	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		163	Under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	2	3	3	3				
93	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	59	61	62	62				
94	Shajibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	84	86	81	86				
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	195	190	203	203				
97	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	18	19	19	19				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	9	7	9				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	12	16	0	0				
100	Bibiiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	325	300	320				
101	Bibiyan-II 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	0	0	0	0		400	Under maint.	
102	Bibiyan South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400				
103	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	46	49	44	44				
Sylhet Zone Total						2472	2427	1210	1242	1201	1228	0	1122
105	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
106	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0		410	Under maint.	
107	Fandpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	30	0	30				
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	67	0	80				
109	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	0				
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	50	92	90	90				
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	17	17	17				
112	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0				
113	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	77	0	100	0				
114	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	16	66	16	83				
115	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	40	0	40				
116	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	532	495	540	540				
	Khulna 330 MW CCPP	Gas/HSD (BPDB)				0	0	0	0				
**	Bheramara (HSDC)	India		1000	1000	490	551	928	928				
Khulna Zone Total						3005	3001	1165	1358	1691	1808	0	410
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	32	0	100		78	Line Overload	
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	18	25	19	25				
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	123	132	135	135				
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	580	622	622	622				
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	17	0	17		133	Line Overload	
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	199	169	150	200				
123	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	107	223	210	215				
Barishal Zone Total						2265	2265	1027	1220	1136	1314	0	211
124	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Gas Shortage	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	34	0	32				
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	50				
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	17	0	25				
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	92	0	92				
129	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	16	40	0	40				
130	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	16	42	34	42				
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	28	0	36				
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0		210	Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	161	126	140	160				
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0		220	Under maint.	
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	417	379	400	400				
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	22	22	22				
137	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	11	10	11				
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	8	8	8				
139	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	75	35	75				
140	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	32	70	35	70				
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0				
	Adani Power Jharkhanda Ltd	Coal				0	0	0	0				
Rajshahi Zone Total						2129	2129	716	944	690	1063	381	220
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0			Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	160	250	250	250		24	Coal Shortage	
144	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	31	35	34	34				
146	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
147	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0				
148	Thakurgaon 119MW PP (Energygap)	HFO (IPP)	6*20	115	115	115	115	115	115				
149	Lalmohithal 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	30	0	30	0				
	Teesha Solar Limited	Solar (IPP)				158	0	0	0				
Rangpur Zone Total						830	750	499	400	437	399	109	85
Sub-total: Plants in operation						23078	22700	8152.0	9606	8758	10421	3318	3559
(B) Plants under long term maintenance/ contract expired													
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
151	Katpotti 32 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
152	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
153	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
154	Aminura 30 MW PP(Sinha)	HFO (GRPP)	7x7.79	50	0	0	0	0	0				
	Sub-Total: Plants under long term maintenance/ contract expired			404	0	0	0	0	0				
Gross Total						23482	22700	8152	9606	8758	10421	3318	3559
(C) Actual data of 10.01.23 (Yesterday) Tuesday :													
01.	Max. Demand at eve. peak (Generation end)	:	9800	MW, at =	20:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	9430	MW, at =	20:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	9606	MW, at =	20:00 hrs	Dhaka	3342	3342	0	Mymensingh	848	824	24
04.	Minimum Generation (Generation end)	:	6338	MW, at =	5:00 hrs	Chattogram	977	977	0	Barishal	357	357	0
05.	Day-peak Generation (Generation end)	:	8152	MW, at =	12:00 hrs	Khulna	1183	1183	0	Rangpur	273	273	0
06.	Evening-peak Generation (Generation end)	:	9606	MW, at =	20:00 hrs	Rajshahi	961	861	100	Barisal	653	598	55
07.	Evening Peak Load-shed (Sub-station end)	:	179	MW, at =	20:00 hrs	Cumilla	836	836	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6489	MW, at =	5:00 hrs					Total	9430	9251	179
09.	Generation shortfall at evening peak due to :	:				13.	Fuel cost :	(a) Gas = 112023628 Taka	(c) Coal = 148576064 Taka				
	a) Gas/LF limitation	:	3009	MW				(b) Oil = 448940154 Taka	Total = 709539846 Taka				
	d) Coal supply Limitation	:	109	MW									
	e) Low water level in Kaptai lake	:	200	MW									
	c) Plants under shut down/ maintenance	:	3559	MW		14.	Maximum Temperature in Dhaka was :	28.2° C					
10.	Total Energy (Generation + India Import)	:	192.97	MKWh		15.	Export through East-West interconnections :						
	By Gas = 107.228 MKWh	By Oil = 31.998 MKWh					At evening peak-hour	:	8152	MW, at	20:00 hrs		
	By Coal = 35.166 MKWh	By Hydro = 0.719 MKWh					Maximum	:	64	MW, at	7:00 hrs		
	By Solar= 2.316 MKWh						Energy	:	0	MKWh			
11. Total Gas Supplied						:	805.85	MMCFD					
(D) Forecast of 11.01.23 (Today) Wednesday :													
01.	Maximum Demand	:	10300	MW (Generation end)		04.	Maximum Load-shed	:	0	MW (At evening peak (Sub-station end)			
02.	Maximum Generation	:	10421	MW (Generation end)		05.	Total Generation	:	206.91	MKWh			
03.	Reserve / Shortage	:	121	MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	25.4° C					