

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month January, 2023					Day : Tuesday				Date : 17.01.23			
Probable Maximum Demand : 10200 MW					Probable Maximum Generation : 9565 MW				Rule Curve = 99.96 ft.			
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 85.20 ft Today = 85.08 ft							
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	16.01.23 (Yesterday)		17.01.23 (Today)		16.01.23 (Yesterday)		17.01.23 (Today)	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Water Limitation MW		Machines shut down (MW)	
					Day	Evening	Day	Evening	Description/ Remarks		Probable start-up date	
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage
3	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190		Gas Shortage
4	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	200	200	200	200		165	ST under maint.
5	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	76	77	74	77	31		Gas Shortage
6	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage
7	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			Contract Expired
8	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	230	196	240	250	164		Gas Shortage
9	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	0	0	0	0		450	Under Maint.
10	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
11	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	269	349	300	350			
12	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage
13	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	217	118	Gas Shortage
14	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	155	138	140	140	197		Gas Shortage
15	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	30			
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	8	8	8			
17	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	16	19	19	19			
18	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	49	49	49	49			
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	25	33			
20	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	30	33	33			
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	8	8	16			
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	70	88	70	88			
23	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	48	32	80			
24	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	54	0	54			
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	33	65	33	65			
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	35	35	35	35			
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	0			
28	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0			
29	Auraihat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0			
30	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	17	17	34			
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	55	0	34			
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	17	0	17			
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	17	17	17			
34	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	20	0	30	0			
35	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17			
36	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	9	9	8	9			
37	Meghnaghat 100 MW(HEL)	HFO (NENP)	12x8.9	100	100	9	8	8	8			
38	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	34	34	20	34			
Dhaka Zone Total					6004	5847	1343	1586	1398	1697	1294	1108
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	30	30	30	200		Low water level
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage
41	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
42	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0			
43	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	17	8	17			
44	Teknaf 20MW PP (SolarTech)	Solar (IPP)	1x20	20	20	19	0	20	0			
45	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	34	34	25	34			
46	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	34	68	34	68			
47	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.
48	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	154	156	160	160		75	ST Under maint.
49	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	51	284	51	284			
50	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25			
51	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	51			
52	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	32	32	32	32			
53	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0	22		Gas Shortage
*	Malancha, Ctg.EP2 (United)	Gas	5x8.73+3x9.34			2	9	5	10			
54	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0			
55	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17			
56	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	71	52	50	70			
57	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	25	25	25			
58	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	22	22	22	22			
59	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	34	68	34	107			
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0			on test
Chattogram Zone Total					2442	2382	562	890	594	952	402	405
60	Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage
61	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	3	0	0	0	45		Gas Shortage
62	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	196	171	180	180			
63	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	0	25	300	300		335	Under maint.
64	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	340	280	290	300			
65	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	290	148	0	0			
66	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	0	0	0	0	55		Gas Shortage
67	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	0	0	0	195		Gas Shortage
68	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
69	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	6	8	6	6	142		Gas Shortage
70	Tilas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	35	34	31	34			
71	Chandpur 150 MW CCPP	Gas (PDB)	1x106+1x57	163	163	0	0	0	0		163	Under maint.
72	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	17	17	17			
73	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	21	21			
74	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	10	10			
75	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	14	21	19	21			
76	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	0	0	8			
77	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	21	21	19	21			
78	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	8x14+8x1.515+15x1.098	200	200	0	0	0	0			
79	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	0	0			
80	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	117	9	113			
81	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17			
82	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.515+2x25.428	115	115	52	94	54	94			
**	Import (Tribuna)	India		160	160	110	114	135	153			
Cumilla Zone Total					3309	3285	1189	1147	1159	1346	571	498
83	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	47	101	50	100	101		Gas Shortage
84	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	21	22			
85	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	28	47	28	47			
86	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	46	48	48	48			
87	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0			
88	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	32	0	50	0			
89	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	7	6	6	6			
Mymensingh Zone Total					622	614	183	224	205	223	101	0

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	16.01.23 (Yesterday)		17.01.23 (Today)		16.01.23 (Yesterday)		Status of Machines under shut-down/ Maintenance					
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date				
						Day	Evening	Day	Evening	Gas/Coal/Oil/ Water Limitation MW	Machines shut down (MW)						
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	0	30	30	30		40	GT-1 Under maint.					
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	43	0	0	0		90	GT-4 Under maint.					
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	11	14	11	11								
91	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		163	Under maint.					
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0								
93	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	30	33	33	33								
94	Shajibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.					
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	30	81	50	84								
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	199	200	200	200								
97	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	19	19	0	19								
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10								
99	Shahjahanula 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	0	0	0								
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	290	300	300								
101	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	392	365	400	400								
102	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	389	400	400								
103	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work					
104	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	10	10	10	10								
Sylhet Zone Total						2472	2427	1454	1441	1444	1497	0	723				
105	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0								
106	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0		410	Under maint.					
107	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	33	0	33								
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	62	0	62								
109	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	0								
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	90	90	90								
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	17	0	18								
112	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0								
113	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	68	0	100	0								
114	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	16	66	16	99								
115	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	8	0	8								
116	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	0	0	0		617	Coal Shortage					
	Khulna 330 MW CCPP	Gas/HSD (BPDB)				0	0	0	0								
**	Bheramara (HSDC)	India		1000	1000	910	792	932	932								
Khulna Zone Total						3005	3001	994	1068	1138	1242	617	410				
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	64	110	48	110								
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	20	25	19	25								
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	126	134	135	135								
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	470	622	622	622								
121	Potukhalhi 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	54	100	150	150								
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0		307	Coal Shortage					
123	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220								
Barisal Zone Total						2265	2265	954	1211	1194	1262	307	0				
124	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage					
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Gas Shortage					
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	34	0	34								
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0								
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	26	0	26								
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	92	0	92								
129	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	0	32								
130	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	42	34	34	34								
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	37	0	37								
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0		210	Gas Shortage					
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	164	147	150	150		73	Gas Shortage					
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0		220	Gas Shortage					
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	366	333	350	350		81	Gas Shortage					
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	22	21	22								
137	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8								
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	52	52	8	8								
139	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6'18.55	113	113	35	35	35	35								
140	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	35	35	35								
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	3	0	6	0								
	Adani Power Jharkhanda Ltd	Coal				0	0	0	0								
Rajshahi Zone Total						2129	2129	688	887	647	863	755	0				
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	81	83	81	83		2	Coal Shortage					
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0			85	Under Overhauling				
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	250	250	250		24	Coal Shortage					
144	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0								
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	35	35	35	35								
146	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0								
147	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	1	0	8	0								
148	Thakurgaon 119MW PP (Energygap)	HFO (IPP)	6'20	115	115	115	115	115	115								
149	Lalmohithal 30 MW Solar (Intraco)	Solar (IPP)	1'30	30	30	5	0	30	0								
	Teesta Solar Limited	Solar (IPP)				119	0	130	0								
Rangpur Zone Total						830	750	606	483	649	483	26	85				
Sub-total: Plants in operation						23078	22700	7973.0	8937	8428	9565	4073	3229				
(B) Plants under long term maintenance/ contract expired																	
150	Jamalpur 95 MW PP (Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0								
151	Kalptodi 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0								
152	Bosilla 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0								
153	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0								
154	Ammura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0					Contract Expired on 11/01/2022			
Sub-Total: Plants under long term maintenance/ contract expired						404	0	0	0	0	0						
Gross Total						23482	22700	7973	8937	8428	9565	4073	3229				
(C) Actual data of 16.01.23 (Yesterday) Monday :																	
01.	Max. Demand at eve. peak (Generation end)	:	9970	MW, at =	20:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :											
02.	Max. Demand at eve. peak (Sub-station end)	:	9393	MW, at =	20:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW				
03.	Highest Generation (Generation end)	:	9017	MW, at =	22:00 hrs	Dhaka	3322	3008	314	Mymensingh	878	816	62				
04.	Minimum Generation (Generation end)	:	6445	MW, at =	5:00 hrs	Chattogram	898	888	10	Sylhet	362	304	58				
05.	Day-peak Generation (Generation end)	:	7973	MW, at =	12:00 hrs	Khulna	1157	920	237	Barisal	269	269	0				
06.	Evening-peak Generation (Generation end)	:	8937	MW, at =	20:00 hrs	Rajshahi	999	861	138	Rangpur	703	570	133				
07.	Evening Peak Load-shed (Sub-station end)	:	952	MW, at =	20:00 hrs	Cumilla	806	806	0								
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6615	MW, at =	5:00 hrs	Total							9393	8441	952		
09.	Generation shortfall at evening peak due to :	:				Total							9393	8441	952		
	a) Gas/LF Limitation	:	3847	MW		13. Fuel cost :											
	d) Coal supply limitation	:	26	MW		(a) Gas = 114229797 Taka							(c) Coal = 175943862 Taka	Taka			
	b) Low water level in Kaptai lake	:	200	MW		(b) Oil = 432881240 Taka							Total = 723054899 Taka	Taka			
	c) Plants under shut down/ maintenance	:	3229	MW		14. Maximum Temperature in Dhaka was :							24° C				
10.	Total Energy (Generation + India Import)	:	190.65	MKWh		15. Export through East-West interconnections :											
	By Gas = 111.353 /MKWh			By Oil = 32.661 /MKWh		At evening peak-hour							:	7973	MW, at	20:00 hrs	
	By Coal = 22.732 /MKWh			By Hydro = 0.703 /MKWh		Maximum							:	140	MW, at	7:00 hrs	
	By Solar= 1.574 /MKWh					Energy							:	0.0165	MKWh		
11.	Total Gas Supplied	:	842.61	MMCFD													
(D) Forecast of 17.01.23 (Today) Tuesday :																	
01.	Maximum Demand	:	10200	MW	(Generation end)	04.	Maximum Load-shed	:	585	MW	At evening peak (Sub-station end)						
02.	Maximum Generation	:	9565	MW	(Generation end)	05.	Total Generation	:	215.66	MKWh							
03.	Reserve / Shortage	:	-635	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	24.8° C									