

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month January, 2023					Day : Wednesday				Date : 18.01.23					
Probable Maximum Demand : 10300 MW					Probable Maximum Generation : 9629 MW				Rule Curve = 99.77 ft.					
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 85.08 ft		Today = 84.96 ft							
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	17.01.23 (Yesterday)		18.01.23 (Today)		17.01.23 (Yesterday)		18.01.23 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Machines shut down (MW)		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening						
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260		Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	100	100	100	80			Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190			Gas Shortage	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	200	110	0	0		255		ST under maint.	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	75	15	74	77	93			Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105			Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0				Contract Expired	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	220	225	280	250	135			Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	0	0	0	0		450		Under Maint.	
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115		Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	362	356	380	350					
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210			Gas Shortage	
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	217			Gas Shortage	
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	148	150	150	150	185			Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	15					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	8	8	8					
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	16	22	19	19					
17	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	28	50	49	49					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	25	33					
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	32	28	33	33					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	16	8	16					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	34	88	34	88					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	82	16	82					
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	54	0	54					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	32	263	33	100					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	35	72	70	70					
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	0					
27	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0					
28	Auraihat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0					
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	35	17	55					
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	55	0	35					
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	17	0	17					
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	17	17	17					
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	23	0	30	0					
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	34	17	17					
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	9	9	8	9					
36	Meghnaghat 100 MW(HEL)	HFO (NENP)	12x8.9	100	100	9	8	8	8					
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	34	68	68	68					
Dhaka Zone Total					6004	5847	1371	1930	1459	1720	1215	1198		
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	30	30	30	200			Low water level	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180			Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0					
41	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	17	8	17					
42	Teknaf 20MW PP (SolarTech)	Solar (IPP)	1x20	20	20	18	0	20	0					
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	27	34	32	32					
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	34	68	34	68					
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150		Under maint.	
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	160	161	160	160	75			ST Under maint.	
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	51	285	51	300					
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25					
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	68	0	51					
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	32	32	32	32					
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0	22			Gas Shortage	
*	Malancha, Ctg.EP2 (United)	Gas	5x8.73+3x9.34			3	14	5	10					
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0					
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17					
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	52	68	50	85					
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	25	25	25					
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	22	22	22	22					
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	68	107	107					
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0				on test	
Chattogram Zone Total					2442	2382	615	934	623	981	402	405		
58	Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134			Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	0	38	35	35					
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*175	221	221	141	182	200	200					
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	145	0	0	0		360		Under maint.	
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	295	310	320	320					
63	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	148	0	0	0					
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	0	34	50	50	21			Gas Shortage	
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	0	187	185	185					
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51					
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	6	8	6	6	142			Gas Shortage	
68	Tilas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	10	30	35	35					
69	Chandpur 150 MW CCPP	Gas (PDB)	1x106+1x57	163	163	0	0	0	0		163		Under maint.	
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	17	17	17					
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	20	21	21					
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	10	10					
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	14	22	25	25					
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	8	0	8					
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	21	21	19	21					
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	8x14+8x1.515+15x1.098	200	200	0	0	0	0					
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	0	0					
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	0	112	55	113					
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17					
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.515+2x25.428	115	115	53	94	54	94					
**	Import (Tripura)	India		160	160	104	114	135	152					
Cumilla Zone Total					3309	3285	1043	1275	1235	1360	297	523		
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	44	103	50	100	99			Gas Shortage	
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	21	21	22					
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	28	47	28	47					
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	48	48	48	48					
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0					
86	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	39	0	50	0					
87	Tangail 22 MW PP(PPLG)	HFO (IPP)	4x6.7	22	22	6	6	6	6					
Mymensingh Zone Total					622	614	189	225	205	223	99	0		

Sl. No.	Name of Power Station			Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	17.01.23 (Yesterday)		18.01.23 (Today)		17.01.23 (Yesterday)		Status of Machines under shut-down/ Maintenance												
							Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :														
							Day	Evening	Day	Evening	Gas/Coal/Oil/ Water Limitation MW	Machines shut down (MW)													
88	Fenchugonj CCPP Phase-1	Gas	(PDB)	2x32+1x33	97	70	30	30	30	30		40	GT-1 Under maint.												
89	Fenchugonj CCPP Phase-2	Gas	(PDB)	2x35+1x35	104	90	0	0	0	0		90	GT-4 Under maint.												
90	Fenchugonj 51 MW PP (Barakatullah)	Gas	(RPP)	19x2.90	51	51	14	31	44	44															
91	Kushara 163 MW CCPP (KP)	Gas	(IPP)	1x109+1x54	163	163	0	0	0	0		163	Under maint.												
92	Hobiganj 11MW PP Confidence-E	Gas	(SIPP, REB)	4x2.90	11	11	0	0	0	0															
93	Shahjibazar GTTP Unit- 8 & 9	Gas	(PDB)	2x35	70	66	32	32	33	33															
94	Shajibazar 330 MW CCPP	Gas	(PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.												
95	Shahjibazar 86MW PP (Shahjibazar)	Gas	(RPP)	32x2.90	86	86	81	81	81	81															
96	Sylhet 225 MW CCPP	Gas	(PDB)	1x142+1x89	231	231	200	200	200	200															
97	Sylhet 20 MW GTTP	Gas	(PDB)	1 x 20	20	20	0	0	0	19															
98	Sylhet 10MW PP (Desh)	Gas	(RPP)	6x1.95	10	10	9	10	10	10															
99	Shahjahanula 25 MW PP	Gas	(CIPP, REB)	3x9.34	25	25	0	0	0	0															
100	Bibiana-II 341 MW CCPP (Summit)	Gas	(IPP)	1x222+1x119	341	341	295	300	0	300															
101	Bibiyan-II 400 MW CCPP	Gas	(PDB)	1x285+1x115	400	400	363	365	400	400															
102	Bibiyan South 383 MW CCPP	Gas	(PDB)	1x252+1x131	383	383	400	400	400	400															
103	Shahjibazar 100 MW GTTP	Gas	(PDB)	1x100	100	100	0	0	0	0		100	Under project work												
104	Fenchuganj 44MW (Energyprima)	Gas	(NENP)	12'3.3+5'2	50	50	10	30	44	44															
Sylhet Zone Total							2472	2427	1434	1479	1242	1561	0	723											
105	Bheramara GTTP Unit- 3	HSD	(PDB)	1 x 20	20	16	0	0	0	0															
106	Bheramara 410 MW CCPP	Gas	(NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0		410	Gas Shortage												
107	Fairdipor 50 MW Peaking PP	HFO	(PDB)	8x6.98	54	54	0	33	0	33															
108	Gopalganj 100 MW Peaking PP	HFO	(PDB)	16x6.98	109	109	0	72	0	62															
109	Khulna 225 MW CCPP	HSD	(NWPGL)	1 x 150+1x75	230	230	0	0	0	0															
110	Noapara 100 MW PP (Bangla Trac)	HSD	(IPP)	70x1.4+7x1.5+15	100	100	0	60	0	90															
111	Rupsha 105 MW PP (Orion rupsha)	HFO	(IPP)	6x18.445	105	105	0	18	0	18															
112	Madhumati 100 MW PP	HFO	(NWPGL)	6x18.415	105	105	0	0	0	0															
113	Mongla Orion 100 MW Solar PP	Solar	(IPP)		100	100	64	0	100	0															
114	Khulna 115 MW PP (KPCL-2)	HFO	(NENP)	7x17	115	115	16	65	0	99															
115	Noapara 40 MW PP (Khanjahan Ali)	HFO	(NENP)	5'8.5	40	40	0	8	0	8															
116	Maitree Super Thermal 1320 MW PP (U-1)	Coal	(BIFPCL)	1x617	617	617	0	0	0	0		617	Coal Shortage												
	Khulna 330 MW CCPP	Gas/HSD	(BPDB)				0	0	0	0															
**	Bheramara (HSDC)	India			1000	1000	909	861	925	925															
Khulna Zone Total							3005	3001	989	1117	1025	1235	1027	0											
117	Barisal 110 MW PP (Summit)	HFO	(IPP)	7 x 17.076	110	110	110	99	110	110															
118	Bhola 33 MW PP (Venture)	Gas	(NENP)	1x34.50	40	40	19	25	19	25															
119	Bhola 225 MW CCPP	Gas	(PDB)	2x63+1x68	194	194	132	136	135	135															
120	Payra 1320 MW TPP	Coal	(BCPCL)	2x622	1244	1244	622	622	622	622															
121	Potukhali 150MW PP (UPPL)	HFO	(IPP)	8x18.415+1x9.78	150	150	100	150	35	100															
122	Barisal Electric 307 MW	Coal	(IPP)	1x307	307	307	0	0	0	0		307	Coal Shortage												
123	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD	(IPP)	2x75+1x70	220	220	190	222	220	220															
Barishal Zone Total							2265	2265	1173	1254	1141	1212	307	0											
124	a) Baghabari 71 MW GTTP	Gas	(PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage												
	b) Baghabari 100 MW GTTP	Gas	(PDB)	1 x 100	100	100	0	0	0	0		100	Gas Shortage												
125	Baghabari 50 MW Peaking PP	HFO	(PDB)	6x8.9	52	52	0	8	0	34															
126	Baghabari 200 MW PP (Paramount)	HSD	(IPP)	135x1.6	200	200	0	0	0	0															
127	Bera 70 MW Peaking PP	HFO	(PDB)	9x8.29	71	71	0	31	0	31															
128	Chapainawabganj 100 MW Peaking PP	HFO	(PDB)	12x8.924	104	104	7	43	0	92															
129	Katakhali 50 MW Peaking PP	HFO	(PDB)	6x8.7	50	50	0	40	0	40															
130	Katakhali 50 MW PP (Northern)	HFO	(QRPP)	6x8.9	50	50	25	24	42	42															
131	Santahar 50 MW Peaking PP	HFO	(PDB)	6x8.7	50	50	0	37	0	37															
132	Sirajgonj 225MW CCPP Unit-1	Gas	(NWPGL)	1x150+1x75	210	210	0	0	0	0		210	Gas Shortage												
133	Sirajgonj 225MW CCPP Unit-2	Gas	(NWPGL)	1x150 + 1x75	220	220	166	135	140	150		85	Gas Shortage												
134	Sirajgonj 225MW CCPP Unit-3	Gas	(NWPGL)	1x141+1x79	220	220	0	0	0	0		220	Gas Shortage												
135	Sirajgonj 400 MW CCPP Unit-4	Gas	(IPP)	1x282+1x132	414	414	367	334	300	320		80	Gas Shortage												
136	Bogra 22 MW PP (GBB)	Gas	(RPP)	6x4.0	22	22	18	22	21	22															
137	Ullapara 11 MW PP (Summit)	Gas	(SIPP, REB)	4x2.90	11	11	8	8	8	8															
138	Natore 52 MW PP (Rajlanka)	HFO	(IPP)	6x8.92	52	52	0	24	0	8															
139	Bagura 113 MW (Confidence) U-1	HFO	(IPP)	6'18.55	113	113	18	35	35	35															
140	Bagura 113 MW PP (Confidence) U-2	HFO	(IPP)	6x18.55	113	113	0	35	35	35															
141	Sirajgonj 6.55 MW Solar	Solar	(NWPGL)	1x6	6	6	4	0	6	0															
	Adani Power Jharkhanda Ltd	Coal					0	0	0	0															
Rajshahi Zone Total							2129	2129	613	776	587	854	766	0											
142	a) Barapukuria TPP Unit-1	Coal	(PDB)	1 x 125	125	85	85	83	81	83		2	Coal Shortage												
	b) Barapukuria TPP Unit-2	Coal	(PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling												
143	Barapukuria 275 MW TPP Unit-3	Coal	(PDB)	1 x 274	274	274	248	250	250	250		24	Coal Shortage												
144	Rangpur 20 MW GTTP	HSD	(PDB)	1 x 20	20	20	0	0	0	0															
145	Rangpur 113 MW PP (Confidence)	HFO	(IPP)	7'16x 2'3	113	113	27	34	35	35															
146	Saidpur 20 MW GTTP	HSD	(PDB)	1 x 20	20	20	0	0	0	0															
147	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar	(IPP)	1 x 8	8	8	1	0	8	0															
148	Thakurgaon 119MW PP (Energygap)	HFO	(IPP)	6'20	115	115	115	115	115	115															
149	Lalmorhat 30 MW Solar (Intraco)	Solar	(IPP)	1'30	30	30	23	0	30	0															
	Teesta Solar Limited	Solar	(IPP)				57	0	130	0															
Rangpur Zone Total							830	750	556	482	649	483	26	85											
Sub-total: Plants in operation							23078	22700	7983.0	9472	8166	9629	4139	2934											
(B) Plants under long term maintenance/ contract expired																									
150	Jamalpur 95 MW PP (Powerpac)	HFO	(IPP)	12x8.924	95	0	0	0	0	0															
151	Kalptotti 32 MW PP (Sinha)	HFO	(IPP)	7x7.90	51	0	0	0	0	0															
152	Bosilla 108MW PP (CLC)	HFO	(IPP)	12x8.775+1x3.5	108	0	0	0	0	0															
153	Keraniganj 100 MW PP (Powerpac)	HFO	(QRPP)	8x13.45	100	0	0	0	0	0															
154	Ammura 50 MW PP (Sinha)	HFO	(QRPP)	7x7.79	50	0	0	0	0	0				Contract Expired on 11/01/2022											
Sub-Total: Plants under long term maintenance/ contract expired							404	0	0	0	0	0													
Gross Total							23482	22700	7983	9472	8166	9629	4139	2934											
(C) Actual data of 17.01.23 (Yesterday) Tuesday :																									
01.	Max. Demand at eve. peak (Generation end)	:	10094	MW, at =	20:00 hrs																				
02.	Max. Demand at eve. peak (Sub-station end)	:	9604	MW, at =	20:00 hrs																				
03.	Highest Generation (Generation end)	:	9472	MW, at =	20:00 hrs																				
04.	Minimum Generation (Generation end)	:	6615	MW, at =	5:00 hrs																				
05.	Day-peak Generation (Generation end)	:	7983	MW, at =	11:00 hrs																				
06.	Evening-peak Generation (Generation end)	:	9472	MW, at =	20:00 hrs																				
07.	Evening Peak Load-shed (Sub-station end)	:	573	MW, at =	20:00 hrs																				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6590	MW, at =	5:00 hrs																				
09.	Generation shortfall at evening peak due to :	:																							
	a) Gas/LF Limitation	:	3913	MW																					
	d) Coal supply Limitation	:	26	MW																					
	b) Low water level in Kaptai lake	:	200	MW																					
	c) Plants under shut down/ maintenance	:	2934	MW																					
10.	Total Energy (Generation + India Import)	:	194.74	MKWh																					
	By Gas =	110.640	MKWh	By Oil =	34.828	MKWh																			
	By Coal =	23.651	MKWh	By Hydro =	0.711	MKWh																			
	By Solar =	1.618	MKWh																						
11.	Total Gas Supplied	:	838.87	MMCFD																					
(D) Forecast of 18.01.23 (Today) Wednesday :																									
01.	Maximum Demand	:	10300	MW	(Generation end)																				
02.	Maximum Generation	:	9629	MW	(Generation end)																				
03.	Reserve / Shortage	:	-671	MW	(Generation end)																				
04.	Maximum Load-shed	:	580	MW	At evening peak (Sub-station end)																				
05.	Total Generation	:	211.77	MKWh																					
06.	Probable Max. Temperature in Dhaka :	:	25.0° C																						