

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month January, 2023					Day : Thursday				Date : 19.01.23				
Probable Maximum Demand : 10200 MW					Probable Maximum Generation : 10004 MW								
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 84.96 ft		Today = 84.87 ft		Rule Curve = 99.58 ft.				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	18.01.23 (Yesterday)		19.01.23 (Today)		18.01.23 (Yesterday)		19.01.23 (Today)		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Status of Machines under shut-down/ Maintenance		
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date	
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	150	150	150				
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190		Gas Shortage	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	ST under maint.	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	77	76	77	77	32		Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			Contract Expired	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	349	324	350	330				
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	0	0	0	0		450	Under Maint.	
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	391	396	400	400				
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage	
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	217	118	Gas Shortage	
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	155	155	155	155	180		Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	15				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	8	8	8				
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	10	19	19	19				
17	Summit Power(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	49	42	49	49				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	25	25	33				
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	31	33	33				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	16	8	16				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	34	88	34	88				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	48	16	48				
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	33	65	33	100				
25	Kodda 140 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	39	35	36	36				
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x11.4	300	300	0	0	0	0				
27	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0				
28	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0				
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	17	17	35				
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	55	0	55				
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	16	0	17				
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	162	17	162				
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	22	0	30	0				
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17				
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	9	8	8	9				
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	17	9	8	8				
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	68	68	68	68				
Dhaka Zone Total			6004	5847	1434	1899	1590	1982	934	1308			
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	30	30	30	200		Low water level	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	4	0	5	0					
41	Razcan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	17	8	17				
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	17	0	20	0					
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	32	34	32	32				
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	34	68	34	68				
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.	
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	152	160	160	160		75	ST Under maint.	
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	16	285	51	300				
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25				
49	Dohazari-Kalash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	85	85	68	68				
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	25	30	32	32				
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0	22		Gas Shortage	
*	Malancha Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	10	5	10				
52	Chattogram 108 MW PP (IECPV)	HFO (IPP)	16x7.00	108	108	0	6	0	0				
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17				
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	53	92	50	85				
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	25	25	25				
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	22	22	22	22				
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107				
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0			on test	
Chattogram Zone Total			2442	2382	654	1013	691	998	402	405			
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	35	41	35	41				
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1x75	221	221	203	205	200	200				
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	0	0	0	0		360	Under maint.	
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	355	280	330	330				
63	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	0	0	0	0				
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	47	47	50	50				
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'116	195	195	190	190	185	185				
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51				
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	6	6	6	6	144		Gas Shortage	
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	36	33	35	35				
69	Chandpur 150 MW CCPP	Gas (PDB)	1x106+1x57	163	163	0	0	0	0		163	Under maint.	
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	17	17	17				
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	21	21	21				
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	10	10				
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	21	25	25	25				
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	8	0	8				
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	21	21	19	21				
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x1.4+6x1.015+10x1.08	200	200	0	0	0	0				
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	0	0	0	0				
78	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	46	109	55	113				
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17				
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	53	89	54	94				
**	Import (Tripura)	India		160	160	118	106	135	152				
Cumilla Zone Total			3309	3285	1221	1276	1245	1376	278	523			
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	45	109	50	110	93		Gas Shortage	
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	21	21	22				
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	28	47	28	47				
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	48	48	48	48				
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
86	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	43	0	50	0	0				
87	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	6	6	6	6				
Mymensingh Zone Total			622	614	191	231	205	233	93	0			

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	18.01.23 (Yesterday)		19.01.23 (Today)		18.01.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	GT-1 Under maint.	
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	22	0	0		68	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	52	53	44	44				
91	Kushira 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		163	Under maint.	
92	Hobiganj 111MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	0	0				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	61	64	64	64				
94	Shajibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	81	84	81	81				
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	198	196	200	200				
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	20	20	20				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	15	16	0	0				
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	0	50	300	300				
101	Bibiyan-II 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	421	364	400	400				
102	Bibiyan South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	50	50	44	44				
Sylhet Zone Total						2472	2427	1326	1367	1593	1593	0	701
105	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
106	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0		410	Gas Shortage	
107	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	13	39	0	33				
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	75	0	75				
109	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	0				
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	5	60	0	90				
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	18	0	18				
112	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0				
113	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	54	0	100	0				
114	Khulna 115 MW PP (KPLC-2)	HFO (NENP)	7x17	115	115	0	0	0	99				
115	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	24	0	8				
116	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	0	0	0		617	Coal Shortage	
	Khulna 330 MW CCPP	Gas/HSD (BFPDB)				0	0	0	0				
**	Bheramara (H/DC)	India		1000	1000	909	909	930	930				
Khulna Zone Total						3005	3001	981	1125	1030	1253	1027	0
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	110	110	110	110				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	20	25	19	25				
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	131	136	135	135				
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	570	622	622	622				
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	35	150	35	100				
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0		307	Coal Shortage	
123	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	221	220	220	220				
Barishal Zone Total						2265	2265	1087	1263	1141	1212	307	0
124	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Gas Shortage	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	17	0	34				
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	4	36	0	31				
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	76	50	0	92				
129	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	16	40	0	40				
130	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	42	42	42	42				
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	10	36	0	37				
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0		210	Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	142	132	140	150		88	Gas Shortage	
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0		220	Gas Shortage	
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	357	344	330	340		70	Gas Shortage	
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	17	22	21	22				
137	Uliapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	0	8				
139	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	35	35	35				
140	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	3	35	35	35				
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0				
Adani Power Jharkhanda Ltd								0	0				
Rajshahi Zone Total						2129	2129	714	805	617	874	759	0
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	82	82	81	83		3	Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	250	250	250		24	Coal Shortage	
144	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	35	34	35	35				
146	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
147	Maipara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0				
148	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	115	115	115	115				
149	Lalmohithai 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	25	0	30	0				
Teesta Solar Limited								143	0	130	0		
Rangpur Zone Total						830	750	655	481	649	483	27	85
Sub-total: Plants in operation						23078	22700	8263.0	9460	8761	10004	3827	3022
(B) Plants under long term maintenance/ contract expired													
150	Jamulpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
151	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
152	Bosilia 108MW PP(CLLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
153	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
154	Amirhat 30 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0				
Sub-Total: Plants under long term maintenance/ contract expired						404	0	0	0	0			Contract Expired on 11/01/2022
Gross Total						23482	22700	8263	9460	8761	10004	3827	3022
(C) Actual data of 18.01.23 (Yesterday) Wednesday :													
01.	Max. Demand at eve. peak (Generation end)	:	10094	MW, at =	20:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	9617	MW, at =	20:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	9460	MW, at =	20:00 hrs	Dhaka	3376	3295	81	Mymensingh	963	873	90
04.	Minimum Generation (Generation end)	:	6590	MW, at =	4:00 hrs	Chattogram	942	942	0	Sylhet	351	311	40
05.	Day-peak Generation (Generation end)	:	8263	MW, at =	12:00 hrs	Khulna	1165	1033	132	Barishal	269	269	0
06.	Evening-peak Generation (Generation end)	:	9460	MW, at =	20:00 hrs	Rajshahi	1036	902	134	Rangpur	692	585	107
07.	Evening Peak Load-shed (Sub-station end)	:	584	MW, at =	20:00 hrs	Cumilla	822	822	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6695	MW, at =	5:00 hrs								
09.	Generation shortfall at evening peak due to :	:								Total	9617	9033	584
	a) Gas/LF limitation	:	3600	MW		13.	Fuel cost :	(a) Gas = 121413697 Taka		(c) Coal = 185033881 Taka			
	d) Coal supply Limitation	:	27	MW				(b) Oil = 482554077 Taka		Total = 789001655 Taka			
	b) Low water level in Kaptai lake	:	200	MW									
	c) Plants under shut down/ maintenance	:	3022	MW		14.	Maximum Temperature in Dhaka was : 23.4° C						
10.	Total Energy (Generation + India Import)	:	194.08	MKWh		15.	Export through East-West interconnections :						
	By Gas =	108.691	MKWh	By Oil =	35.642	MKWh	At evening peak-hour : 8263 MW, at 20:00 hrs						
	By Coal =	23.732	MKWh	By Hydro =	0.720	MKWh	Maximum : 510 MW, at 6:00 hrs						
	By Solar =	1.839	MKWh				Energy : 0 MKWh						
11.	Total Gas Supplied	:	841.45	MMCFD									
(D) Forecast of 19.01.23 (Today) Thursday :													
01.	Maximum Demand	:	10200	MW	(Generation end)	04.	Maximum Load-shed : 181 MW At evening peak (Sub-station end)						
02.	Maximum Generation	:	10004	MW	(Generation end)	05.	Total Generation : 209.26 MKWh						
03.	Reserve / Shortage	:	-196	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka : 24.7° C						