

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month January, 2023					Day : Sunday				Date : 29.01.23				
Probable Maximum Demand : 10300 MW					Probable Maximum Generation : 10482 MW					Rule Curve = 97.60 ft.			
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 83.91 ft. Today = 83.83 ft.								
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	28.01.23 (Yesterday)		29.01.23 (Today)		28.01.23 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :				
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)		Description/ Remarks	Probable start-up date
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	130	140	180	180				
3	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Gas Shortage		
4	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	under maint.		
5	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	59	74	74	74	34	Gas Shortage		
6	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage		
7	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		Contract Expired		
8	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	308	221	220	200				
9	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	0	0	0	0	450	Under Maint.		
10	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling		
11	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	70	350	350				
12	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	90	62	0	0	148	Gas Shortage		
13	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	Under Maint.		
14	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	148	152	150	150	183	Gas Shortage		
15	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	20	15	15				
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	50	50	50	50				
17	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	10	19	19	19				
18	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	48	48	51	51				
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
20	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	30	30	30				
21	Gezipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	16	8	16				
22	Gezipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	52	34	52				
23	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	32	16	48				
24	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	35	17	35				
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	32	65	32	64				
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	35	17	34				
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	0				
28	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0				
29	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0				
30	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	35	17	55				
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	55	35	55				
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	57	55	35	53				
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	17	35	17				
34	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	27	0	30	0				
35	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17				
36	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	44	50	50	50				
37	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	52	50	50	50				
38	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	51	51	51	51				
Dhaka Zone Total			6004	5847	1323	1484	1616	1749	660	1525			
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	30	30	30	200	Low water level		
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage		
41	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.		
42	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0				
43	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	17	8	17				
44	Teknaf 20MW PP (Solarsch)	Solar (IPP)	1x20	20	20	19	0	20	0				
45	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	33	32	33	33				
46	Sikalbaha 105 MW PP (Baraka Sikabaha)	HFO (IPP)	6x18.415	105	105	24	87	17	85				
47	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.		
48	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	156	152	150	150				
49	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	104	284	100	284				
50	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25				
51	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	25	67	51	68				
52	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	32	31	32	32				
53	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0	22	Gas Shortage		
54	* Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			5	11	10	10				
55	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0				
56	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	36	17	17				
57	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	54	92	54	92				
58	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	25	25	25				
59	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	22	22	22	22				
60	Chattogram 116 MW PP (Anlima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	122	107	107	107				
61	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0		on test		
Chattogram Zone Total			2442	2382	705	1018	706	997	402	330			
62	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage		
63	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	35	38	38	38				
64	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1775	221	221	195	204	180	180				
65	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	0	0	0	0	360	Under maint.		
66	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	280	300	280	280				
67	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	308	320	350	320				
68	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	5	5	43	43	50	Gas Shortage		
69	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'116	195	195	0	0	0	0	195	Gas Shortage		
70	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51				
71	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	6	5	6	6	145	Gas Shortage		
72	Tilas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	25	28				
73	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under maint.		
74	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	34	34	34	34				
75	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	21	21				
76	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	6	7	8	8				
77	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	13	20	21	21				
78	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	14	0	8				
79	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	21	21	20	20				
80	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	96x1.4+4x0.1515+15x1.098	200	200	100	0	0	0				
81	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	17	17	17	17				
82	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	9	107	9	113				
83	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17				
84	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	35	93	35	94				
85	** Import (Tripura)	India		160	160	130	122	135	152				
Cumilla Zone Total			3309	3285	1283	1396	1290	1451	524	523			
86	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	45	102	45	70	100	Gas Shortage		
87	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	21	18	18				
88	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	28	47	28	47				
89	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	58	48	48	48				
90	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
91	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	0	0	50	0				
92	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	6	6	6	6				
Mymensingh Zone Total			622	614	158	224	197	189	100	0			

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	28.01.23 (Yesterday)		29.01.23 (Today)		28.01.23 (Yesterday)		Status of Machines under shut-down/ Maintenance													
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Oil/Water Limitation MW		Machines shut down (MW)	Description/ Remarks	Probable start-up date											
						Day	Evening	Day	Evening	Day	Evening														
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	GT-1 Under maint.													
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	43	0	0	43		90	GT-4 Under maint.													
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	14	11	51	11																
91	Kushihara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		163	Under maint.													
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0																
93	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	30	30	30	30																
94	Shajibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.													
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	10	84	81	81																
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	135	140	30	200																
97	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	18	18	19	19																
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10																
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	0	0	0																
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	285	310	300	300																
101	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	247	381	366	366																
102	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	300	400	400	400																
103	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work													
104	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	10	10	44	10																
Sylhet Zone Total						2472	2427	1132	1424	1361	1500	0	723												
105	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0																
106	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0		410		Gas Shortage												
107	Fairidpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	44	0	45																
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	74	0	80																
109	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	0																
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	0	0																
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	30	17	35																
112	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	15	85	50	100																
113	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	77	0	100	0																
114	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	16	0	16																
115	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	8																
116	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	0	0	0		617		Coal Shortage												
	Khulna 330 MW CCPP	Gas/HSD (BPDB)				120	247	0	0																
**	Bheramara (HSDC)	India		1000	1000	907	815	928	928																
Khulna Zone Total						3005	3001	1136	1311	1095	1212	1027	0												
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	16	16	16																
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	19	25	19	22																
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	181	180	180	180																
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1122	1110	1200	1244																
121	Potukhalhi 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	72	17	150																
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0		307		Coal Shortage												
123	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	222	220	220	220																
Barisal Zone Total						2265	2265	1560	1623	1652	1832	307	0												
124	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71		Gas Shortage												
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100		Gas Shortage												
125	Baghabari 50 MW Peaking PP	HSD (PDB)	6x8.9	52	52	0	34	0	34																
126	Baghabari 200 MW PP (Paramount)	HFO (IPP)	135x1.6	200	200	0	0	0	0																
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	4	11	0	17																
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	42	100	0	100																
129	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	16	40	0	40																
130	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	8	42	34	42																
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	12	36	0	34																
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0		210		Gas Shortage												
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0		220		Gas Shortage												
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	202	220	210	190																
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	430	419	350	380																
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	21	21	21	21																
137	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8																
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	8	0	8																
139	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	113	35	113																
140	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	50	50	50	50																
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	2	0	6	0																
	Adani Power Jharkhanda Ltd	Coal				0	0	0	0																
Rajshahi Zone Total						2129	2129	838	1102	714	1037	601	0												
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	80	80	80	80		5		Coal Shortage												
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0			85	Under Overhauling												
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	250	250	250		24		Coal Shortage												
144	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0																
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	37	84	34	70																
146	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0																
147	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	3	0	8	0																
148	Thakurgaon 119MW PP (Energygac)	HFO (IPP)	6*20	115	115	35	115	35	115																
149	Lalmorichal 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	8	0	30	0																
	Teesa Solar Limited	Solar (IPP)				55	0	130	0																
Rangpur Zone Total						830	750	468	529	567	515	29	85												
Sub-total: Plants in operation						23078	22700	8603.0	10111	9198	10482	3650	3186												
(B) Plants under long term maintenance/ contract expired																									
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0																
151	Kalptotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0																
152	Bosilla 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0																
153	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0																
154	Ammura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0					Contract Expired on 11/01/2022											
Sub-Total: Plants under long term maintenance/ contract expired						404	0	0	0	0	0														
Gross Total						23482	22700	8603	10111	9198	10482	3650	3186												
(C) Actual data of 28.01.23 (Yesterday) Saturday :																									
01.	Max. Demand at eve. peak (Generation end)	:	10209	MW, at =	20:00 hrs																				
02.	Max. Demand at eve. peak (Sub-station end)	:	9772	MW, at =	20:00 hrs																				
03.	Highest Generation (Generation end)	:	10111	MW, at =	20:00 hrs																				
04.	Minimum Generation (Generation end)	:	6711	MW, at =	5:00 hrs																				
05.	Day-peak Generation (Generation end)	:	8603	MW, at =	12:00 hrs																				
06.	Evening-peak Generation (Generation end)	:	10111	MW, at =	20:00 hrs																				
07.	Evening Peak Load-shed (Sub-station end)	:	90	MW, at =	20:00 hrs																				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6898	MW, at =	5:00 hrs																				
09.	Generation shortfall at evening peak due to :	:																							
a)	Gas/LF limitation	:	3421	MW																					
d)	Coal supply Limitation	:	29	MW																					
b)	Low water level in Kaptai lake	:	200	MW																					
c)	Plants under shut down/ maintenance	:	3186	MW																					
10.	Total Energy (Generation + India Import)	:	203.78	MKWh																					
	By Gas = 108.403 /MKWh			By Oil = 35.192	MKWh																				
	By Coal = 35.101			By Hydro = 0.742	MKWh																				
	By Solar= 1.231 /MKWh																								
11.	Total Gas Supplied	:	831.03	MMCFD																					
(D) Forecast of 29.01.23 (Today) Sunday :																									
01.	Maximum Demand	:	10300	MW	(Generation end)																				
02.	Maximum Generation	:	10482	MW	(Generation end)																				
03.	Reserve / Shortage	:	182	MW	(Generation end)																				
04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)																				
05.	Total Generation	:	207.58	MKWh																					
06.	Probable Max. Temperature in Dhaka :	:	29.9° C																						