

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 954667, 9551095

Month January, 2023					Day : Monday				Date : 30.01.23				
Probable Maximum Demand : 10500 MW					Probable Maximum Generation : 10855 MW					Rule Curve = 97.40 ft.			
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 83.83 ft. Today = 83.75 ft.								
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	29.01.23 (Yesterday)		30.01.23 (Today)		29.01.23 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Water Limitation MW				
					Day	Evening	Day	Evening	Machines shut down (MW)	Description/ Remarks		Probable start-up date	
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	211	120	210	210				
3	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Gas Shortage		
4	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.		
5	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	72	74	74	74	34	Gas Shortage		
6	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage		
7	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		Contract Expired		
8	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	218	212	290	290				
9	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	0	0	0	0	450	Under Maint.		
10	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling		
11	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	370	365	350	350				
12	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage		
13	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	Under Maint.		
14	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	150	150	150	150	185	Gas Shortage		
15	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	30	15	15				
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	50	50	48	48				
17	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	16	19	19				
18	Summit Power, Madhabdi-Ashulia	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	50	48	51	51				
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
20	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	28	28	30	30				
21	Gezipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	16	8	16				
22	Gezipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	52	34	52				
23	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	32	16	32				
24	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	35	35	35				
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	32	65	32	64				
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	35	17	35				
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	0				
28	Bramhanaganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0				
29	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0				
30	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	17	17	17	55			
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55				
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	55	55	55	55				
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	17	35	17				
34	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	29	0	30	0				
35	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17				
36	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	50	50	50	50				
37	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	50	49	50	50				
38	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	51	51	51	68				
Dhaka Zone Total				6004	5847	1680	1672	1752	1871	724	1525		
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	30	30	30	200	Low water level		
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage		
41	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		Under maint.		
42	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0				
43	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	17	8	17				
44	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0				
45	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	33	33	33	33				
46	Sikalbaha 105 MW PP (Baraka Sikabaha)	HFO (IPP)	6x18.415	105	105	17	68	34	85				
47	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.		
48	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	156	152	155	155	73	ST Under maint.		
49	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	105	282	100	300				
50	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25				
51	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	68	51	68				
52	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	38	32	32	32				
53	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0	22	Gas Shortage		
54	* Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			2	9	20	10				
55	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0				
56	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17				
57	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	54	92	54	92				
58	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	25	25	25				
59	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	22	22	22	22				
60	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	100	107	107	107				
61	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0		on test		
Chattogram Zone Total				2442	2382	656	979	738	1018	402	403		
62	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage		
63	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	38	41	42	42				
64	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1775	221	221	219	196	180	180				
65	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	0	0	0	0	360	Under maint.		
66	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	355	300	290	300				
67	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	430	300	350	320				
68	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	48	15	25	25	40	Gas Shortage		
69	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'116	195	195	0	0	45	45	195	Gas Shortage		
70	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51				
71	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	3	6	6	6	144	Gas Shortage		
72	Tilas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	29	21	25	28				
73	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under maint.		
74	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	34	34	34	34				
75	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	20	21	21				
76	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	5	7	8	8				
77	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	14	21	23	23				
78	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	1	8	8	8				
79	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	21	21	20	20				
80	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	96x1.4+40x1.515+15x1.098	200	200	0	0	0	0				
81	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	17	0	17	100				
82	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	7	117	9	113				
83	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17				
84	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	36	95	35	94				
85	** Import (Tripura)	India		160	160	120	116	135	152				
Cumilla Zone Total				3309	3285	1454	1386	1341	1587	513	523		
86	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	45	46	45	105		Gas Shortage		
87	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	22	22	22				
88	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	28	47	28	47				
89	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	48	53	48	48				
90	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0				
91	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	0	0	50	0				
92	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	6	6	6	6				
Mymensingh Zone Total				622	614	147	174	201	228	156	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	29.01.23 (Yesterday)		30.01.23 (Today)		29.01.23 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Water Limitation MW		Machines shut down (MW)	Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening					
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	GT-1 Under maint.		
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	31	31	43		59	GT-4 Under maint.		
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	53	53	51	51					
91	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		163	Under maint.		
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8					
93	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	20	30	30	30					
94	Shajibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.		
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	82	82	81	81					
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	30	150	190	200					
97	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	18	18	19	19					
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10					
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	16	0	0					
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	270	320	320					
101	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	305	367	366	366					
102	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	360	365	180	180					
103	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work		
104	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	45	44	44	44					
Sylhet Zone Total						2472	2427	1269	1474	1360	1382	0	692	
105	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
106	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0		410	Gas Shortage		
107	Fairdpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	37	0	45					
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	72	0	80					
109	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	0					
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	0	0					
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	33	17	35					
112	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	50	85	50	100					
113	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	87	0	100	0					
114	Khulna 115 MW PP (KPCLC-2)	HFO (NENP)	7x17	115	115	0	8	32	115					
115	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	8					
116	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	0	0	0		617	Coal Shortage		
	Khulna 330 MW CCPP	Gas/HSD (BPDB)				120	254	0	0					
**	Bheramara (HSDC)	India		1000	1000	909	839	928	928					
Khulna Zone Total						3005	3001	1183	1328	1127	1311	1027	0	
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	16	16					
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	17	24	19	22					
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	181	166	180	180					
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1090	1110	1200	1244					
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	150	17	150					
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0		307	Coal Shortage		
123	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	163	210	220	220					
Barisal Zone Total						2265	2265	1468	1676	1652	1832	307	0	
124	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage		
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Gas Shortage		
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	26	34	0	34					
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0					
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	4	7	0	17					
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	99	96	0	100					
129	Katakhalhi 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	40	40	0	40					
130	Katakhalhi 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	42	42	34	42					
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	36	31	0	34					
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0			Gas Shortage		
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0		220	Gas Shortage		
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	180	204	140	204					
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	357	447	400	420					
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	21	21	21	21					
137	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8					
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	8	8					
139	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	95	35	113					
140	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	50	50	50	50					
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0					
	Adani Power Jharkhanda Ltd	Coal				0	0	0	0					
Rajshahi Zone Total						2129	2129	902	1075	702	1091	601	0	
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	80	81	80	80		4	Coal Shortage		
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0			85	Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	250	250	250		24	Coal Shortage		
144	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	49	90	50	90					
146	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
147	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0					
148	Thakurgaon 119MW PP (Energygac)	HFO (IPP)	6*20	115	115	35	115	115	115					
149	Lalmorshat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	26	0	30	0					
	Teesa Solar Limited	Solar (IPP)				128	0	130	0					
Rangpur Zone Total						830	750	573	536	663	535	28	85	
Sub-total: Plants in operation						23078	22700	9332.0	10300	9536	10855	3758	3228	
(B) Plants under long term maintenance/ contract expired														
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0					
151	Katpotti 32 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0					
152	Bosilla 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0					
153	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0					
154	Ammura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0				Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired						404	0	0	0	0	0			
Gross Total						23482	22700	9332	10300	9536	10855	3758	3228	
(C) Actual data of 29.01.23 (Yesterday) Sunday :														
01.	Max. Demand at eve. peak (Generation end)	:	10455	MW, at =	19:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand at eve. peak (Sub-station end)	:	10023	MW, at =	19:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	
03.	Highest Generation (Generation end)	:	10300	MW, at =	19:00 hrs	Dhaka	3633	3633	0	Mymensingh	916	773	143	
04.	Minimum Generation (Generation end)	:	6898	MW, at =	5:00 hrs	Chattogram	987	987	0	Sylhet	363	363	0	
05.	Day-peak Generation (Generation end)	:	9332	MW, at =	12:00 hrs	Khulna	1168	1168	0	Barisal	270	270	0	
06.	Evening-peak Generation (Generation end)	:	10300	MW, at =	19:00 hrs	Rajshahi	1062	1062	0	Rangpur	767	767	0	
07.	Evening Peak Load-shed (Sub-station end)	:	143	MW, at =	19:00 hrs	Cumilla	858	858	0					
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6777	MW, at =	5:00 hrs									
09.	Generation shortfall at evening peak due to :	:				Total 10023 9880 143								
	a) Gas/LF limitation	:	3530	MW		13. Fuel cost : (a) Gas = 116152870 Taka (c) Coal = 287755458 Taka								
	d) Coal supply Limitation	:	28	MW		(b) Oil = 454817731 Taka Total = 858726060 Taka								
	b) Low water level in Kaptai lake	:	200	MW		14. Maximum Temperature in Dhaka was : 26.3° C								
	c) Plants under shut down/ maintenance	:	3228	MW		15. Export through East-West interconnections :								
10.	Total Energy (Generation + India Import)	:	211.83	MKWh		At evening peak-hour : 9332 MW, at 19:00 hrs								
	By Gas = 112.678 MKWh	By Oil =	37.656 MKWh		Maximum : 370 MW, at 16:00 hrs									
	By Coal = 35.127 MKWh	By Hydro =	0.735 MKWh		Energy : 0 MKWh									
	By Solar= 1.726 MKWh													
11.	Total Gas Supplied	:	846.02	MMCFD										
(D) Forecast of 30.01.23 (Today) Monday :														
01.	Maximum Demand	:	10500	MW (Generation end)		04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)			
02.	Maximum Generation	:	10855	MW (Generation end)		05.	Total Generation	:	215.95	MKWh				
03.	Reserve / Shortage	:	355	MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	:	29.7° C					