

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month February, 2023					Day : Wednesday				Date : 01.02.23				
Probable Maximum Demand : 10500 MW					Probable Maximum Generation : 10873 MW					Rule Curve = 97.00 ft.			
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 83.67 ft		Today = 86.59 ft.						
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	31.01.23 (Yesterday)		01.02.23 (Today)		31.01.23 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :				
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)		Description/ Remarks	Probable start-up date
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	160	220	220	220				
3	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Gas Shortage		
4	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.		
5	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	68	75	71	71	33	Gas Shortage		
6	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage		
7	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0				
8	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	227	183	180	180	177	Gas Shortage		
9	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	0	0	0	0	450	Under Maint.		
10	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling		
11	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	388	339	350	350				
12	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage		
13	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	Under Maint.		
14	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	152	145	150	150	190	Gas Shortage		
15	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	15				
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	50	50	48	48				
17	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	16	16	19	19				
18	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	48	49	51	51				
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
20	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	16	25	25				
21	Gezipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	16	8	16				
22	Gezipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	52	52	35	52				
23	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	48	32	48				
24	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	17	17	35				
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	48	147	32	145				
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	17	17	17				
27	Keranigonj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	0				
28	Bramhanigonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0				
29	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0				
30	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	17	17	55				
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55				
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	55	54	17	55				
33	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	17	17	17				
34	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	27	0	30	0				
35	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17				
36	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	42	50	50	50				
37	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	50	50	25	50				
38	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	51	51	17	17				
Dhaka Zone Total					6004	5847	1685	1749	1528	1791	905	1525	
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	30	30	30	200	Low water level		
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage		
41	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.		
42	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0				
43	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	17	8	17				
44	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0				
45	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	26	33	25	33				
46	Sikalbaha 105 MW PP (Baraka Sikabaha)	HFO (IPP)	6x18.415	105	105	34	88	34	85				
47	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.		
48	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	152	156	160	160	69	ST Under maint.		
49	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	105	273	100	300				
50	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25				
51	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	83	51	83				
52	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	32	32	24	32				
53	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0	22	Gas Shortage		
54	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			2	5	5	5				
55	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0				
56	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.5+1x3.6	54	54	17	17	17	17				
57	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	54	92	54	92				
58	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	25	25	25				
59	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	22	22	22	22				
60	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	92	107	107	107				
61	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			18	0	0	0		on test		
Chattogram Zone Total					2442	2382	666	1005	712	1033	402	399	
62	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage		
63	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	42	42	42	42				
64	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1775	221	221	0	94	100	100				
65	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	0	0	0	0	360	Under maint.		
66	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	345	285	300	300				
67	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	382	300	320	320				
68	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	51	52	51	51	3	Gas Shortage		
69	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'116	195	195	112	8	8	8	187	Gas Shortage		
70	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	25	25	25	25				
71	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	11	5	6	6	145	Gas Shortage		
72	Tilas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	21	20	25	25				
73	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under overhauling		
74	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	34	34	34	34				
75	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	19	19				
76	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	5	5	5	5				
77	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	14	23	23	23				
78	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	8	8	8				
79	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	21	21	20	20				
80	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	96x1.4+40x1.515+15x1.098	200	200	0	0	0	0				
81	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	17	17	17	17				
82	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	9	118	9	113				
83	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17				
84	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	36	72	17	94				
85	Import (Tripura)	India		160	160	110	114	135	152				
Cumilla Zone Total					3309	3285	1271	1279	1181	1379	469	523	
86	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	44	55	45	100	147	Gas Shortage		
87	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	22	22	22				
88	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	28	47	47	47				
89	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	57	58	48	55				
90	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
91	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	0	0	50	0				
92	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	6	6	6	6				
Mymensingh Zone Total					622	614	156	188	220	230	147	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	31.01.23 (Yesterday)		01.02.23 (Today)		31.01.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)		
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	GT-1 & ST-1 Under maint.	
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	43	43	43	43		47	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	22	0	0	0				
91	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	110	110		51	ST Under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
93	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	61	65	65	65				
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	84	84	60	81				
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	218	218	220	220				
97	Sylhet 20 MW GTTP	Gas (PDB)	1x20	20	20	18	18	19	19				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
99	Shahjibazar 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	0	0	0				
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	260	320	320				
101	Bibiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	238	402	400	400				
102	Bibiana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	220	400	400	400				
103	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12'3.4+5'2	50	50	46	0	0	0				
Sylhet Zone Total													
105	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
106	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410		Gas Shortage	
107	Fairidpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	45				
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	80				
109	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	0				
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	0	0				
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x8.445	105	105	17	53	17	54				
112	Madhumati 100 MW PP	HFO (NWPGL)	6x8.415	105	105	85	50	85	85				
113	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	64	0	100	0				
114	Khulna 115 MW PP (KPLC-2)	HFO (NENP)	7x17	115	115	0	49	16	49				
115	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	8	0	8				
116	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	0	0	0	617		Coal Shortage	
	Khulna 330 MW CCPP	Gas/HSD (BPDB)				50	121	120	120				
**	Bheramara (HSDC)	India		1000	1000	908	765	920	920				
Khulna Zone Total				3005	3001	1124	1046	1258	1361	1027	0		
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	16	16	16				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	19	24	19	25				
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	175	178	180	180				
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1122	1244	1200	1244				
121	Potukhalhi 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	54	17	50				
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0	307		Coal Shortage	
123	Bhola 220MW CCPP (Nutan Bidrut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	200	221	220	220				
Barisal Zone Total				2265	2265	1549	1737	1652	1635	307	0		
124	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	34	0	34				
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	5	20	0	20				
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	42	96	0	95				
129	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	16	40	0	40				
130	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	42	8	25	42				
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	6	35	0	35				
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	180	175	180	180	45		Gas Shortage	
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	424	439	400	400				
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	22	22	22				
137	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	8	8				
139	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6'18.55	113	113	35	75	35	75				
140	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	50	50	50	50				
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0				
	Adani Power Jharkhand Ltd	Coal				0	0	0	0				
Rajshahi Zone Total				2129	2129	831	1010	734	1009	646	0		
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	80	80	80	80	5		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	250	250	250	24		Coal Shortage	
144	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	56	78	49	84				
146	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
147	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0				
148	Thakurgaon 119MW PP (Energygap)	HFO (IPP)	6'20	115	115	35	115	115	115				
149	Lalmorhat 30 MW Solar (Intraco)	Solar (IPP)	1'30	30	30	24	0	30	0				
	Teesta Solar Limited	Solar (IPP)				136	0	130	0				
Rangpur Zone Total				830	750	586	523	662	529	29	85		
Sub-total: Plants in operation				23078	22700	9296.0	10187	9632	10873	3932	3100		
(B) Plants under long term maintenance/ contract expired													
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
151	Kaipoti 32 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
152	Bosilla 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
153	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
154	Ammura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired				404	0	0	0	0	0				
Gross Total				23482	22700	9296	10187	9632	10873	3932	3100		
(C) Actual data of 31.01.23 (Yesterday) Tuesday :													
01.	Max. Demand at eve. peak (Generation end)	:	10350 MW, at =	19:30 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand at eve. peak (Sub-station end)	:	9820 MW, at =	19:30 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	
03.	Highest Generation (Generation end)	:	10187 MW, at =	19:30 hrs	Dhaka	3648	3618	30	Mymensingh	919	799	120	
04.	Minimum Generation (Generation end)	:	6945 MW, at =	5:00 hrs	Chattogram	852	852	0	Sylhet	367	367	0	
05.	Day-peak Generation (Generation end)	:	9296 MW, at =	12:00 hrs	Khulna	1140	1140	0	Barisal	270	270	0	
06.	Evening-peak Generation (Generation end)	:	10187 MW, at =	19:30 hrs	Rajshahi	1043	1043	0	Rangpur	727	727	0	
07.	Evening Peak Load-shed (Sub-station end)	:	150 MW, at =	19:30 hrs	Cumilla	855	855	0					
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7246 MW, at =	5:00 hrs									
09.	Generation shortfall at evening peak due to :	:							Total	9820	9670	150	
a)	Gas/LF Limitation	:	3703 MW		13.	Fuel cost :	(a) Gas = 117102969 Taka	(c) Coal = 296030740 Taka					
b)	Coal supply Limitation	:	29 MW				(b) Oil = 443970154 Taka	Total = 857103863 Taka					
c)	Low water level in Kaptai lake	:	200 MW										
d)	Plants under shut down/ maintenance	:	3100 MW		14.	Maximum Temperature in Dhaka was :	29.6° C						
10.	Total Energy (Generation + India Import)	:	210.86 MKWh		15.	Export through East-West interconnections :							
	By Gas = 113.349 MKWh		By Oil = 35.539 MKWh			At evening peak-hour	:	9296 MW, at 19:30 hrs					
	By Coal = 36.038 MKWh		By Hydro = 0.726 MKWh			Maximum	:	670 MW, at 7:00 hrs					
	By Solar = 1.652 MKWh					Energy	:	0 MKWh					
11.	Total Gas Supplied	:	884.35 MMCFD										
(D) Forecast of 01.02.23 (Today) Wednesday :													
01.	Maximum Demand	:	10500 MW (Generation end)		04.	Maximum Load-shed	:	0 MW At evening peak (Sub-station end)					
02.	Maximum Generation	:	10873 MW (Generation end)		05.	Total Generation	:	217.34 MKWh					
03.	Reserve / Shortage	:	373 MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	:	30.5° C					

#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation