

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month February, 2023					Day : Monday				Date : 06.02.23				
Probable Maximum Demand : 10700 MW					Probable Maximum Generation : 11092 MW								
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 83.13 ft		Today = 82.89 ft		Rule Curve = 96.30 ft.				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	05.02.23 (Yesterday)		06.02.23 (Today)		05.02.23 (Yesterday)		06.02.23 (Today)		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Oil/Water Limitation		Machines shut down (MW)		
					Day	Evening	Day	Evening	Description/ Remarks		Probable start-up date		
(A) Plants in operation:													
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work	
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	180	170	180	180				
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190		Gas Shortage	
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	Under maint.	
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	75	78	75	77	30		Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0				
7	Haripur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	360	234	228	180	200	132		Gas Shortage	
8	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	0	0	140	140		450	Under Maint.	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
10	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	341	338	270	300				
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage	
12	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0		335	Under Maint.	
13	Meghnaghat CCGP(Summit)	GAS (IPP)	2x110+1x110	335	335	152	149	150	150	186		Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	30	15	15				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	50	50	48	50				
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	19	19				
17	Summit Power(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	47	48	47	47				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	22	22	22	22				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	16	8	16				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	52	35	52				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	48	64	64				
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	35	0	54				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	72	232	165	245				
25	Kodda 140 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	53	53	54	54				
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x11.4	300	300	0	0	0	0				
27	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0				
28	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0				
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	17	17	17				
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	55	17	55				
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	34	55	17	56				
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	17	17	17				
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	28	0	30	0				
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17				
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	50	50	50	50				
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	42	50	50	50				
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	17	17	17	17				
Dhaka Zone Total					6004	5847	1590	1879	1737	1997	853	1525	
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	30	30	30	200		Low water level	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	4	0	5	0					
41	Razcan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	17	8	17				
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	20	0					
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	27	27	26	26				
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	68	17	85				
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.	
46	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	150	158	160	160	67		ST Under maint.	
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	106	284	100	300				
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25				
49	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	51	82	68	85				
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	34	23	34	34				
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0	22		Gas Shortage	
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	0	0	0				
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0				
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	34	17	17				
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	74	73	55	72				
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	25	25	25				
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	22	22	22	22				
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107				
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0			on test	
Chattogram Zone Total					2442	2382	719	975	719	1005	402	397	
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	42	20	45	45				
60	Ashuganj 225 MW CCGP	Gas (APSCL)	1x142+1*75	221	221	176	225	190	200				
61	Ashuganj 450 MW CCGP(South)	Gas (APSCL)	1x360	360	360	0	0	0	0		360	Under maint.	
62	Ashuganj 450 MW CCGP(North)	Gas (APSCL)	1x361	360	360	350	290	300	300				
63	Ashuganj 420 MW CCGP(East)	Gas (APSCL)	1x284+1x116	400	400	282	342	400	350				
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	0	0	0	0				
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	0	0	0	0	195		Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	43	43				
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	6	6	6	6	144		Gas Shortage	
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	0		52	Under maint.	
69	Chandpur 150 MW CCGP	Gas (PDB)	1x106+1x57	163	163	0	0	0	0		163	Under overhauling	
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	34	34	34	34				
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	19	19	19				
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	12	15	20	20				
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	10	8	8				
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	21	21	20	21				
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x1.4+6x1.015+10x1.08	200	200	0	0	0	0				
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	34	17	34				
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	111	9	113				
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17				
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	15	94	17	94				
**	Import (Tripura)	India		160	160	114	126	135	152				
Cumilla Zone Total					3309	3285	1154	1415	1288	1464	473	575	
81	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	33	49	45	70	153		Gas Shortage	
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	19	22	22				
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	47	49	47	48				
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	28	46	28	46				
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0				
86	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	40	0	50	0				
87	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	6	6	6	6				
Mymensingh Zone Total					622	614	173	169	200	192	153	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	05.02.23 (Yesterday)		06.02.23 (Today)		05.02.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation	Machines shut down (MW)		
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	GT-1 & ST-1 Under maint.	
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	43	43	30	30		47	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	17	17	47	48				
91	Kushnara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112		51	ST Under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	61	64	65	65				
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	64	64	86				
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	218	218	218	218				
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	19	18	19	19				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	0	0	0				
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	280	300	300				
101	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	402	400	250	400				
102	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	393	385	180	400				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	15	15	49	49				
Sylhet Zone Total						2472	2427	1638	1664	1382	1775	0	568
105	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
106	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0		410	Gas Shortage	
107	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	38	0	45				
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	50	0	70				
109	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	0				
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	0	0				
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	57	56	53	75				
112	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	67	50	100				
113	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	83	0	100	0				
114	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	16	49	0	49				
115	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	0				
116	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	0	0	0		617	Coal Shortage	
	Khulna 330 MW CCPP	Gas/HSD (BIFDB)				120	120	120	120				
**	Bheramara (H/DC)	India		1000	1000	908	793	791	791				
Khulna Zone Total						3005	3001	1184	1173	1114	1250	1027	0
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	32	16	32				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	17	21	19	21				
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	176	172	180	180				
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1172	1182	1244	1244				
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	72	100	150				
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0		307	Coal Shortage	
123	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220				
Barisal Zone Total						2265	2265	1602	1699	1779	1847	307	0
124	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Gas Shortage	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	32	0	32				
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	4	32	0	31				
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	41	50	0	100				
129	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	8	40	40				
130	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	42	34	42				
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	11	25	0	36				
132	Sirajganj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0		210	Gas Shortage	
133	Sirajganj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0		220	Gas Shortage	
134	Sirajganj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	220	150	180	170				
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	428	306	400	400				
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	21	21	22	22				
137	Uliapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	10	10	10	10				
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	8	8				
139	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	113	35	95				
140	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	50	50	50	50				
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	3	0	6	0				
Adani Power Jharkhanda Ltd								0	0	0	0		
Rajshahi Zone Total						2129	2129	823	839	785	1036	601	0
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	80	80	81	81		5	Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	251	250	250		23	Coal Shortage	
144	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	31	92	35	80				
146	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
147	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0				
148	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	37	58	0	115				
149	Lalmohithai 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	3	0	30	0				
Teesta Solar Limited								49	0	130	0		
Rangpur Zone Total						830	750	460	481	534	526	28	85
Sub-total: Plants in operation						23078	22700	9343.0	10294	9538	11092	3844	3150
(B) Plants under long term maintenance/ contract expired													
150	Jamulpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
151	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
152	Bosilia 108MW PP(CLLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
153	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
154	Amirhat 30 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0				
Sub-Total: Plants under long term maintenance/ contract expired						404	0	0	0	0			
Gross Total						23482	22700	9343	10294	9538	11092	3844	3150
(C) Actual data of 05.02.23 (Yesterday) Sunday :													
01.	Max. Demand at eve. peak (Generation end)	:	10465 MW, at =	19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	9954 MW, at =	19:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed	
03.	Highest Generation (Generation end)	:	10294 MW, at =	19:00 hrs	Dhaka	3636	3636	0	Mymensingh	925	767	158	
04.	Minimum Generation (Generation end)	:	6823 MW, at =	5:00 hrs	Chattogram	928	928	0	Sylhet	348	348	0	
05.	Day-peak Generation (Generation end)	:	9343 MW, at =	12:00 hrs	Khulna	1176	1176	0	Barisal	265	265	0	
06.	Evening-peak Generation (Generation end)	:	10294 MW, at =	19:00 hrs	Rajshahi	1067	1067	0	Rangpur	734	734	0	
07.	Evening Peak Load-shed (Sub-station end)	:	158 MW, at =	19:00 hrs	Cumilla	875	875	0					
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6731 MW, at =	5:00 hrs					Total	9954	9796	158	
09.	Generation shortfall at evening peak due to :	:			13.	Fuel cost :	(a) Gas = 118307041 Taka (b) Oil = 392502575 Taka		(c) Coal = 296942570 Taka Total = 807752186 Taka				
	a) Gas/LF limitation	:	3616 MW		14.	Maximum Temperature in Dhaka was : 27.0° C							
	d) Coal supply Limitation	:	28 MW		15.	Export through East-West interconnections :							
	b) Low water level in Kaptai lake	:	200 MW			At evening peak-hour	:	9343 MW, at	19:00 hrs				
	c) Plants under shut down/ maintenance	:	3150 MW			Maximum	:	710 MW, at	20:00 hrs				
10.	Total Energy (Generation + India Import)	:	211.40 MKWh			Energy	:	0 MKWh					
	By Gas = 116.248 MKWh		By Oil = 33.051 MKWh										
	By Coal = 36.149 MKWh		By Hydro = 0.722 MKWh										
	By Solar= 1.779 MKWh												
11.	Total Gas Supplied	:	879.99 MMCFD										
(D) Forecast of 06.02.23 (Today) Monday :													
01.	Maximum Demand	:	10700 MW (Generation end)		04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)							
02.	Maximum Generation	:	11092 MW (Generation end)		05.	Total Generation : 219.74 MKWh							
03.	Reserve / Shortage	:	392 MW (Generation end)		06.	Probable Max. Temperature in Dhaka : 28.5° C							