

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month February, 2023					Day : Friday				Date : 10.02.23				
Probable Maximum Demand : 10000 MW					Probable Maximum Generation : 10660 MW								
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 82.55 ft		Today = 82.49 ft		Rule Curve = 95.74 ft.				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	09.02.23 (Yesterday)		10.02.23 (Today)		09.02.23 (Yesterday)		10.02.23 (Today)		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Status of Machines under shut-down/ Maintenance		
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date	
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	200	220	220	220				
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190		Gas Shortage	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365		under maint.	
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	79	81	81	81	27		Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0				
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	180	177	210	210	183		Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	180	180	200	200	270		Under Maint.	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115		Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412		Under maint.	
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	66	64	70	70				
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	108	111	135	135	224		Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	15				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	50	40	16	50				
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	16	16	16				
17	Summit Power(Madhab+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	46	46	47	47				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	21	17	25	25				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	25	42	25	42				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	52	90	52	90				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	48	16	48				
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	35	0	35				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	115	164	115	164				
25	Kodda 140 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	66	80	54	105				
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x11.4	300	300	0	0	0	0				
27	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0				
28	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0				
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	17	17	55				
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	55	0	55				
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	16	48	17	55				
32	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	162	17	162				
33	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	24	0	30	0				
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17				
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	41	41	50	50				
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	50	50	50	50				
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	48	49	51	51				
Dhaka Zone Total			6004	5847	1500	1898	1579	2081	939	1422			
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	30	30	30	200		Low water level	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	4	0	5	0					
41	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	17	8	17				
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	20	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	19	19	19	19				
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	23	85	17	85				
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.	
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	224	230	100	100				
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	105	300	100	300				
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25				
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	51	85	68	85				
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	22	65	34	65				
51	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0	22		Gas Shortage	
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			0	0	0	0				
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0				
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17				
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	66	92	55	92				
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	34	25	30				
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	22	22	22	22				
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107				
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0			on test	
Chattogram Zone Total			2442	2382	768	1128	652	994	402	330			
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	5	5	42	42	40		Gas Shortage	
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	207	220	210	220				
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	0	0	0	0	360		Under maint.	
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	335	300	330	330				
63	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	336	310	0	0				
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	5	5	35	35	50		Gas Shortage	
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	0	0	140	140	195		Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	43	43				
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	6	6	6	6	144		Gas Shortage	
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	26	31	10	31	21		Under maint.	
69	Chandpur 150 MW CCPP	Gas (PDB)	1x106+1x57	163	163	0	0	0	0	163		Under overhauling	
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	34	34	34	34				
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	19	19				
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	5	8	8				
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	8	20	25	25				
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	8	8	8				
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	21	21	21	21				
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x1.4+6x1.015+10x1.08	200	200	0	0	0	0				
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	114	17	114				
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	118	9	113				
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17				
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	18	94	17	94				
**	Import (Tripura)	India		160	160	134	122	135	152				
Cumilla Zone Total			3309	3285	1256	1492	1126	1452	563	544			
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	34	109	55	100	93		Gas Shortage	
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	14	13	22	22				
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	59	79	47	79				
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	94	75	75	75				
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
86	Sutiekhal 50 MW Solar PP	Solar (IPP)	1x50	50	43	0	50	0					
87	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	6	6	6	6				
Mymensingh Zone Total			622	614	252	282	257	282	93	0			

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	09.02.23 (Yesterday)		10.02.23 (Today)		09.02.23 (Yesterday)		Status of Machines under shut-down/ Maintenance					
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Machines shut down (MW)	Description/ Remarks	Probable start-up date			
						Day	Evening	Day	Evening								
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	GT-1 & ST-1 Under maint.					
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	31	31	30	30		59	GT-4 Under maint.					
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	25	0	22	22								
91	Kushnara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112		51	ST Under maint.					
92	Hobiganj 111MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8								
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	61	64	65	65								
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.					
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	50	86	84	86								
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	214	211	220	220								
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	19	19	19								
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10								
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	8	8	8								
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	320	270	300	300								
101	Bibiyan-II 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	397	401	0	0								
102	Bibiyan South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	394	400	380	400								
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work					
104	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	20	45	49	49								
Sylhet Zone Total						2472	2427	1698	1695	1337	1359	0	580				
105	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0								
106	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0		410	Gas Shortage					
107	Fairdpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	43	0	45								
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	30	0	83								
109	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	0								
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	0	0								
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	35	55	57	55								
112	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	105	85	105	105								
113	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	72	0	100	0								
114	Khulna 115 MW PP (KPLC-2)	HFO (NENP)	7x17	115	115	0	32	0	32								
115	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	8	0	16								
116	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	0	0	0		617	Coal Shortage					
	Khulna 330 MW CCPP	Gas/HSD (BIFDB)				0	0	0	0								
**	Bheramara (H/DC)	India		1000	1000	900	713	920	920								
Khulna Zone Total						3005	3001	1112	966	1182	1256	1027	0				
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	16	16	16								
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	17	22	16	22								
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	88	0	191	191								
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1244	1244	1244	1244								
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	35	150	116	150								
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0		307	Coal Shortage					
123	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	107	109	110	110								
Barisal Zone Total						2265	2265	1507	1541	1693	1733	307	0				
124	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage					
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Gas Shortage					
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	34	0	34								
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0								
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	25	0	31								
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	50	96	42	95								
129	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	39	40	40	40								
130	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	42	50	42	50								
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	23	30	0	36								
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	20	150		210	Gas Shortage					
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0		220	Gas Shortage					
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	31	151	140	150		69	Gas Shortage					
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	391	360	400	400								
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	16	21	21	21								
137	Uliapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11								
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	0	0								
139	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6'18.55	113	113	35	75	35	50								
140	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	50	50	50	50								
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0								
Adani Power Jharkhanda Ltd							0	0	0		0						
Rajshahi Zone Total						2129	2129	692	943	807	1118	670	0				
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage					
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling					
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	250	200	200		24	Coal Shortage					
144	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0								
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	42	78	42	70								
146	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0								
147	Maipara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0								
148	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6'20	115	115	0	113	0	115								
149	Lalmoharhat 30 MW Solar (Intraco)	Solar (IPP)	1'30	30	30	27	0	30	0								
Teesta Solar Limited							146	0	130	0							
Rangpur Zone Total						830	750	470	441	410	385	109	85				
Sub-total: Plants in operation						23078	22700	9255.0	10386	9043	10660	4110	2961				
(B) Plants under long term maintenance/ contract expired																	
150	Jamulpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0								
151	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0								
152	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0								
153	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0								
154	Amirhat 30 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0								
Sub-Total: Plants under long term maintenance/ contract expired						404	0	0	0	0			Contract Expired on 11/01/2022				
Gross Total						23482	22700	9255	10386	9043	10660	4110	2961				
(C) Actual data of 09.02.23 (Yesterday) Thursday :																	
01.	Max. Demand at eve. peak (Generation end)	:	10533	MW, at =	20:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :											
02.	Max. Demand at eve. peak (Sub-station end)	:	10114	MW, at =	20:00 hrs												
03.	Highest Generation (Generation end)	:	10386	MW, at =	20:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed				
04.	Minimum Generation (Generation end)	:	7150	MW, at =	5:00 hrs	Dhaka	3662	3632	30	Mymensingh	973	868	105				
05.	Day-peak Generation (Generation end)	:	9255	MW, at =	12:00 hrs	Chattogram	1048	1048	0	Sylhet	364	364	0				
06.	Evening-peak Generation (Generation end)	:	10386	MW, at =	20:00 hrs	Khulna	1141	1141	0	Barisal	281	281	0				
07.	Evening Peak Load-shed (Sub-station end)	:	135	MW, at =	20:00 hrs	Rajshahi	1035	1035	0	Rangpur	692	692	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7128	MW, at =	5:00 hrs	Cumilla	918	918	0								
09.	Generation shortfall at evening peak due to :	:				Total				10114	9979	135					
	a) Gas/LF limitation	:	3801	MW		13. Fuel cost : (a) Gas = 112323457 Taka (b) Oil = 537562819 Taka				(c) Coal = 313568341 Taka Total = 963474617 Taka							
	d) Coal supply Limitation	:	109	MW													
	b) Low water level in Kaptai lake	:	200	MW		14. Maximum Temperature in Dhaka was : 28.5° C											
	c) Plants under shut down/ maintenance	:	2961	MW													
10.	Total Energy (Generation + India Import)	:	213.59	MKWh		15. Export through East-West interconnections : At evening peak-hour : 9255 MW, at 20:00 hrs Maximum : 854 MW, at 7:00 hrs Energy : 0 MKWh											
	By Gas = 109.733 MKWh			By Oil = 40.447 MKWh													
	By Coal = 37.186 MKWh			By Hydro = 0.713 MKWh													
	By Solar = 2.008 MKWh																
11.	Total Gas Supplied	:	833.61	MMCFD													
(D) Forecast of 10.02.23 (Today) Friday :																	
01.	Maximum Demand	:	10000	MW (Generation end)		04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)						
02.	Maximum Generation	:	10660	MW (Generation end)		05.	Total Generation	:	205.65	MKWh							
03.	Reserve / Shortage	:	660	MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	:	29.4° C								