

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month February, 2023					Day : Monday				Date : 13.02.23				
Probable Maximum Demand : 10750 MW					Probable Maximum Generation : 10888 MW								
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 82.37 ft				Today = 82.30 ft				
					Rule Curve = 95.32 ft								
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	12.02.23 (Yesterday)		13.02.23 (Today)		12.02.23 (Yesterday)		13.02.23 (Today)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Machines shut down (MW)		
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW		Description/ Remarks	Probable start-up date	
(A) Plants in operation:													
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work	
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	150	200	200	200				
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190		Gas Shortage	
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	under maint.	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	78	81	81	81	27		Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0				
7	Haripur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	360	185	143	220	220	217		Gas Shortage	
8	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225		Gas Shortage	
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
10	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0		412	Under maint.	
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage	
12	Siddhirganj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	70	50	0	0	285		Gas Shortage	
13	Meghnaghat CCGP(Summit)	GAS (IPP)	2x110+1x110	335	335	126	110	150	150	225		Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	25				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	16	42	16	50				
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	19	19				
17	Summit Power(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	46	48	49	49				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	0	25	33	33				
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	20	22	22	22				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	34	41	25	42				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	90	88	90	90				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	64	82	64	82				
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	35	0	35				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	50	98	32	150				
25	Kodda 140 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	37	72	35	70				
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x11.4	300	300	0	0	0	0				
27	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0				
28	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0				
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	35	17	55				
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	55	0	55				
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	54	17	55				
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	126	17	162				
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	28	0	30	0				
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17				
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	33	50	50	50				
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	28	51	17	50				
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	51	34	34	34				
Dhaka Zone Total					6004	5847	1433	1818	1475	2021	1484	1152	
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	30	30	30	200		Low water level	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	4	0	5	0					
41	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	17	8	17				
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	19	0	20	0					
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	19	19	19	19				
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	85	17	85				
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.	
46	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	148	149	150	151		76	ST Under maint.	
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	0	285	100	300				
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	38	25	38				
49	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	85	68	85				
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	24	72	40	64				
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0	22		Gas Shortage	
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			0	0	0	0				
52	Chattogram 108 MW PP (ECPU)	HFO (IPP)	16x7.00	108	108	0	0	0	0				
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17				
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	55	92	55	92				
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	38	25	38				
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	22	33	22	33				
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107				
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0			on test	
Chattogram Zone Total					2442	2382	520	1067	708	1076	402	406	
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	10	10	10	10				
60	Ashuganj 225 MW CCGP	Gas (APSCL)	1x142+1*75	221	221	193	206	195	200				
61	Ashuganj 450 MW CCGP(South)	Gas (APSCL)	1x360	360	360	0	0	0	0		360	Under maint.	
62	Ashuganj 450 MW CCGP(North)	Gas (APSCL)	1x361	360	360	345	295	310	310				
63	Ashuganj 420 MW CCGP(East)	Gas (APSCL)	1x284+1x116	400	400	290	280	300	300		120	Under maint.	
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	0	0	0	0	55		Gas Shortage	
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187		Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	43	43				
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	6	6	6	6	144		Gas Shortage	
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	31	31	10	30				
69	Chandpur 150 MW CCGP	Gas (PDB)	1x106+1x57	163	163	0	0	0	0		163	Under overhauling	
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	34	34	34	34				
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	21	21				
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	14	17	21	21				
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	8	8	8				
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	21	21	21	21				
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x1.4+6x1.015+10x1.08	200	200	0	0	0	0				
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	34	114	17	114				
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	9	9	9				
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17				
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	18	72	17	94				
**	Import (Tripura)	India		160	160	132	136	135	153				
Cumilla Zone Total					3309	3285	1234	1336	1190	1407	520	643	
81	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	34	107	55	105	95		Gas Shortage	
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	10	14	11	11				
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	99	88	50	100				
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	150	79	100	50				
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
86	Sutiakehi 50 MW Solar PP	Solar (IPP)	1x50	50	50	37	0	50	0				
87	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	6	6	6	6				
Mymensingh Zone Total					622	614	338	294	274	272	95	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	12.02.23 (Yesterday)		13.02.23 (Today)		12.02.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 & ST-1 Under maint.	
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	43	43	43	43		47	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	31	51	31	51				
91	Kushiara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112		51	ST Under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	61	61	61	61				
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330		Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	84	86	84	86				
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	211	214	220	220				
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	19	19	19				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	9	10	10				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	8	8	8				
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	305	290	300	300				
101	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	80	406	400	400				
102	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	245	340	380	400				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0	100		Under project work	
104	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	50	50	50	50				
Sylhet Zone Total						2472	2427	1309	1740	1769	1811	0	555
105	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
106	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410		Gas Shortage	
107	Fairdipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	32	0	45				
108	Gopalgarj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	30	0	75				
109	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	0				
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	0	0				
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	54	17	55				
112	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	15	58	15	100				
113	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	83	0	100	0				
114	Khulna 115 MW PP (KPLC-2)	HFO (NENP)	7x17	115	115	0	32	0	32				
115	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	8	0	24				
116	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	0	0	0	617		Coal Shortage	
	Khulna 330 MW CCPP	Gas/HSD (BIFDB)				0	0	0	0				
**	Bheramara (H/DC)	India		1000	1000	904	707	668	621				
Khulna Zone Total						3005	3001	1019	921	800	952	1027	0
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	0	16	16				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	17	22	16	19				
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	183	185	190	190				
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1172	1244	1244	1244				
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	72	150	35	150				
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	180	180	300	300	127		Coal Shortage	
123	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	105	105	110	110				
Barisal Zone Total						2265	2265	1745	1886	1911	2029	127	0
124	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	28	34	0	34				
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	25	0	37				
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	50	96	42	96				
129	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	16	40	40	40				
130	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	42	42	42	42				
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	23	0	30				
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	156	179	179	182				
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage	
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	278	258	300	258	156		Gas Shortage	
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	22	18	22				
137	Uliapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	0	0				
139	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	57	35	55				
140	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	50	50	50	50				
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0				
Adani Power Jharkhand Ltd													
Rajshahi Zone Total						2129	2129	689	837	723	857	767	0
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	250	250	250	24		Coal Shortage	
144	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	49	93	49	100				
146	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
147	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0				
148	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	35	113	35	113				
149	Lalmohithai 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	25	0	30	0				
Teesta Solar Limited							129	0	130	0			
Rangpur Zone Total						830	750	493	456	502	463	109	85
Sub-total: Plants in operation						23078	22700	8780	10355	9352	10888	4531	2841
(B) Plants under long term maintenance/ contract expired													
150	Jamulpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
151	Katpodi 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
152	Bosilia 108MW PP(CLLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
153	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
154	Amirhat 30 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0				
Sub-Total: Plants under long term maintenance/ contract expired						404	0	0	0	0			
Gross Total						23482	22700	8780	10355	9352	10888	4531	2841
(C) Actual data of 12.02.23 (Yesterday) Sunday :													
01.	Max. Demand at eve. peak (Generation end)	:	10600 MW, at =	20:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	10085 MW, at =	20:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	
03.	Highest Generation (Generation end)	:	10355 MW, at =	20:00 hrs	Dhaka	3639	3579	60	Mymensingh	895	819	76	
04.	Minimum Generation (Generation end)	:	7227 MW, at =	5:00 hrs	Chattogram	1078	1078	0	Sylhet	345	345	0	
05.	Day-peak Generation (Generation end)	:	8780 MW, at =	12:00 hrs	Khulna	1162	1162	0	Barisal	289	289	0	
06.	Evening-peak Generation (Generation end)	:	10355 MW, at =	20:00 hrs	Rajshahi	1086	1046	40	Rangpur	674	624	50	
07.	Evening Peak Load-shed (Sub-station end)	:	226 MW, at =	20:00 hrs	Cumilla	918	918	0					
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7371 MW, at =	5:00 hrs					Total	10085	9859	226	
09.	Generation shortfall at evening peak due to :	:							(a) Gas =	111238227 Taka	(c) Coal =	299022144 Taka	
	a) Gas/LF limitation	:	4222 MW						(b) Oil =	515473868 Taka	Total =	925734239 Taka	
	d) Coal supply Limitation	:	109 MW										
	b) Low water level in Kaptai lake	:	200 MW										
	c) Plants under shut down/ maintenance	:	2841 MW										
10.	Total Energy (Generation + India Import)	:	210.99 MKWh		14.	Maximum Temperature in Dhaka was : 30° C							
	By Gas = 105.740 MKWh		By Oil = 39.084 MKWh		15.	Export through East-West interconnections :							
	By Coal = 39.867 MKWh		By Hydro = 0.718 MKWh						At evening peak-hour	:	8780 MW, at	20:00 hrs	
	By Solar = 1.955 MKWh								Maximum	:	776 MW, at	19:30 hrs	
									Energy	:	0 MKWh		
11.	Total Gas Supplied	:	846.67 MMCFD										
(D) Forecast of 13.02.23 (Today) Monday :													
01.	Maximum Demand	:	10750 MW (Generation end)		04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)							
02.	Maximum Generation	:	10888 MW (Generation end)		05.	Total Generation : 219.04 MKWh							
03.	Reserve / Shortage	:	138 MW (Generation end)		06.	Probable Max. Temperature in Dhaka : 28° C							