

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month February, 2023					Day : Tuesday				Date : 14.02.23				
Probable Maximum Demand : 10700 MW					Probable Maximum Generation : 11157 MW								
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 82.30 ft		Today = 82.23 ft		Rule Curve = 95.18 ft.				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	13.02.23 (Yesterday)		14.02.23 (Today)		13.02.23 (Yesterday)		14.02.23 (Today)		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Status of Machines under shut-down/ Maintenance		
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date	
(A) Plants in operation:													
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work	
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	160	130	130	130	50		Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	70	110	110	120		Gas Shortage	
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	under maint.	
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	81	52	20	20	56		Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0				
7	Haripur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	360	246	252	230	250	108		Gas Shortage	
8	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225		Gas Shortage	
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115		Under Overhauling	
10	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412		Under maint.	
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage	
12	Siddhirganj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335		Gas Shortage	
13	Meghnaghat CCGP(Summit)	GAS (IPP)	2x110+1x110	335	335	150	150	150	150	185		Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	25				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	16	50	16	50				
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	19	19				
17	Summit Power(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	47	47	49	49				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	21	21	22	22				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	25	42	25	42				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	52	88	90	88				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	48	64	64	82				
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	35	0	35				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	65	99	32	95				
25	Kodda 140 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	35	72	35	72				
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x11.4	300	300	0	0	0	0				
27	Bramhangsan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0				
28	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0				
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	35	17	55				
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	55	0	55				
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	54	17	55				
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	127	17	126				
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	33	0	30	0				
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17				
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	27	50	50	50				
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	30	50	17	50				
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	34	34	34	34				
Dhaka Zone Total					6004	5847	1431	1886	1464	1939	1394	1152	
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	60	60	30	30	170		Low water level	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0				
41	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	17	8	17				
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	20	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	19	19	19	19				
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	85	17	85				
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.	
46	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	151	151	150	151	74		ST Under maint.	
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	116	285	100	300				
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25				
49	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	81	68	85				
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	40	65	40	64				
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0	22		Gas Shortage	
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			0	0	0	0				
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0				
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17				
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	54	92	55	92				
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	28	25	25	25				
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	22	22	22	33				
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107				
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0			on test	
Chattogram Zone Total					2442	2382	688	1051	708	1050	372	404	
58	Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	10	10	10	10				
60	Ashuganj 225 MW CCGP	Gas (APSCCL)	1x142+1*75	221	221	188	195	220	200				
61	Ashuganj 450 MW CCGP(South)	Gas (APSCCL)	1x360	360	360	0	0	0	0	360		Under maint.	
62	Ashuganj 450 MW CCGP(North)	Gas (APSCCL)	1x361	360	360	290	325	310	310				
63	Ashuganj 420 MW CCGP(East)	Gas (APSCCL)	1x284+1x116	400	400	270	280	320	320				
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	0	0	0	0	55		Gas Shortage	
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187		Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	43	43				
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	33	132	75	150	18		Gas Shortage	
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	31	38	10	30				
69	Chandpur 150 MW CCGP	Gas (PDB)	1x106+1x57	163	163	0	0	0	0		163	Under overhauling	
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	34	34	34	34				
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	21	21				
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	13	16	21	21				
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	16	8	8				
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	21	21	21	21				
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	86x1.4+6x1.015+10x1.086	200	200	0	0	0	0				
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	114	114	114				
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	9	9	9				
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17				
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	18	73	17	94				
**	Import (Tripura)	India		160	160	118	124	135	153				
Cumilla Zone Total					3309	3285	1147	1482	1401	1571	394	523	
81	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	31	70	55	70	132		Gas Shortage	
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	13	13	11	11				
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	115	78	50	76				
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	65	74	65	75				
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	3	0	1.6	0				
86	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	51	0	50	0	0				
87	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	6	6	6	6				
Mymensingh Zone Total					622	614	284	241	239	238	132	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	13.02.23 (Yesterday)		14.02.23 (Today)		13.02.23 (Yesterday)		Status of Machines under shut-down/ Maintenance					
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gas/Coal/oil/ Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date				
						Day	Evening	Day	Evening								
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 & ST-1 Under maint.					
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	43	43	43	43		47	GT-4 Under maint.					
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	22	51	31	51								
91	Kushira 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112		51	ST Under maint.					
92	Hobiganj 111MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	8	8	8								
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	61	62	61	61								
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.					
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	40	86	84	86								
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	214	218	220	220								
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	19	19	19								
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	6	8	10	10								
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	8	8	8								
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	280	300	300								
101	Bibiya-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	400	406	400	400								
102	Bibiya South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	400	380	400								
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work					
104	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	50	49	50	50								
Sylhet Zone Total						2472	2427	1722	1793	1769	1811	0	555				
105	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0								
106	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0		410	Gas Shortage					
107	Fairdpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	38	0	45								
108	Gopalgarj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	30	0	75								
109	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	0								
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	0	0								
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	55	17	55								
112	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	15	50	67	100								
113	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	95	0	100	0								
114	Khulna 115 MW PP (KPLC-2)	HFO (NENP)	7x17	115	115	0	33	0	32								
115	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	16	0	24								
116	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	0	0	0		617	Coal Shortage					
	Khulna 330 MW CCPP	Gas/HSD (BIFDB)				0	0	0	0								
**	Bheramara (H/VC)	India		1000	1000	679	469	784	784								
Khulna Zone Total						3005	3001	789	691	968	1115	1027	0				
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	16	16	16								
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	16	21	16	21								
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	188	190	190	190								
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1022	1202	1244	1244								
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	35	150	35	150								
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	238	208	300	300								
123	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	108	107	110	110								
Barishal Zone Total						2265	2265	1623	1894	1911	2031	0	0				
124	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage					
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Gas Shortage					
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	34	0	34								
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0								
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	5	33	0	37								
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	50	98	42	96								
129	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	43	41	40	40								
130	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	42	50	42	42								
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	12	23	0	30								
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	186	170	179	182								
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0		220	Gas Shortage					
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0		220	Gas Shortage					
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	284	262	300	300		152	Gas Shortage					
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	21	18	22								
137	Uliapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11								
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	0	0								
139	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	75	35	75								
140	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	50	70	50	70								
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0								
	Adani Power Jharkhand Ltd	Coal				0	0	0	0								
Rajshahi Zone Total						2129	2129	741	888	723	939	763	0				
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage					
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0			Under Overhauling					
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	251	250	250		23	Coal Shortage					
144	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0								
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	42	93	49	100								
146	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0								
147	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0								
148	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	35	113	35	113								
149	Lalmohithai 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	34	0	30	0								
	Teesla Solar Limited	Solar (IPP)				162	0	130	0								
Rangpur Zone Total						830	750	528	457	502	463	108	85				
Sub-total: Plants in operation						23078	22700	8953	10383	9685	11157	4190	2719				
(B) Plants under long term maintenance/ contract expired																	
150	Jamulpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0								
151	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0								
152	Bosilia 108MW PP(CLLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0								
153	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0								
154	Amirhat 30 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0								
Sub-Total: Plants under long term maintenance/ contract expired						404	0	0	0								
Gross Total						23482	22700	8953	10383	9685	11157	4190	2719				
(C) Actual data of 13.02.23 (Yesterday) Monday :																	
01.	Max. Demand at eve. peak (Generation end)	:	10432	MW, at =	20:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :											
02.	Max. Demand at eve. peak (Sub-station end)	:	10019	MW, at =	20:00 hrs												
03.	Highest Generation (Generation end)	:	10383	MW, at =	20:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed				
04.	Minimum Generation (Generation end)	:	7371	MW, at =	5:00 hrs	Dhaka	3586	3586	0	Mymensingh	944	909	35				
05.	Day-peak Generation (Generation end)	:	8953	MW, at =	12:00 hrs	Chattogram	1016	1016	0	Sylhet	347	347	0				
06.	Evening-peak Generation (Generation end)	:	10383	MW, at =	20:00 hrs	Khulna	1145	1145	0	Barishal	278	278	0				
07.	Evening Peak Load-shed (Sub-station end)	:	45	MW, at =	20:00 hrs	Rajshahi	1101	1101	0	Rangpur	736	726	10				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7071	MW, at =	5:00 hrs	Cumilla	867	867	0								
09.	Generation shortfall at evening peak due to :	:				Total				10019	9974	45					
a)	Gas/LF limitation	:	3912	MW		(a) Gas = 114830334 Taka				(c) Coal = 279183874 Taka							
d)	Coal supply Limitation	:	108	MW		(b) Oil = 539671981 Taka				Total = 933686190 Taka							
b)	Low water level in Kaptai lake	:	170	MW													
c)	Plants under shut down/ maintenance	:	2719	MW													
10.	Total Energy (Generation + India Import)	:	212.49	MKWh		14. Maximum Temperature in Dhaka was : 28.0° C											
	By Gas = 110.024 MKWh			By Oil = 40.567 MKWh		15. Export through East-West interconnections :											
	By Coal = 38.875 MKWh			By Hydro = 1.109 MKWh													
	By Solar = 2.709 MKWh					At evening peak-hour : 8953 MW, at 20:00 hrs											
						Maximum : 216 MW, at 20:00 hrs											
						Energy : 0 MKWh											
11.	Total Gas Supplied	:	864.63	MMCFD													
(D) Forecast of 14.02.23 (Today) Tuesday :																	
01.	Maximum Demand	:	10700	MW (Generation end)		04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)						
02.	Maximum Generation	:	11157	MW (Generation end)		05.	Total Generation	:	218.98	MKWh							
03.	Reserve / Shortage	:	457	MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	:	27.1° C								